

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

INTEROFFICE COMMUNICATION

December 14, 2015

Briefing Memorandum to the NPDES Permit Decision-maker:

Re: Cadillac WWTP -- NPDES Permit No. MI0020257
Permit ID.v: 21871.1

Briefing Statement and History:

The application for NPDES permit reissuance from the City of Cadillac for the Cadillac WWTP located at 1121 Plett Road, Cadillac, Michigan 49601 has been processed in accordance with Act 451, Public Acts of 1994, as amended, Parts 31 and 41, and the Part 4 and Part 21 Rules (Rules 323.1041 through 323.1117 and 323.2101 through 323.2192 of the Michigan Administrative Code). Staff has determined that the attached permit is consistent with all applicable state and federal requirements and proposes it for reissuance. Also attached are other informational documents associated with this permit.

Staff received no objections to reissuance of this permit during the public comment period. However, the City has requested frequent clarification of monitoring and limits proposed for Lindane, Mercury, and Chronic Toxicity. Staff addressed these questions in writing and in meetings. Staff responded to concerns by careful review of all data, proposed quarterly monitoring for mercury (rather than monthly) a delayed limit (to February 1, 2006) for Lindane, and monitoring frequency reduction reopeners for Lindane and Mercury.

Conclusions and Recommendations:

Staff reviewed the basis for limit recommendations for Lindane, Mercury, and Chronic Toxicity. Sufficient discharge potential exists to support monitoring requirements and limits. Staff recommends reissuance of NPDES Permit No. MI0020257 to City of Cadillac for the Cadillac WWTP located at 1121 Plett Road, Cadillac, Michigan 49601.

Prepared by:

Concurred:

Diane Carlson
Permit Processor

Barry Burns, Acting Chief
Lakes Michigan and Superior Permits Unit
Date: _____

Attachments: Public Notice
Fact Sheet
Proposed Permit