

Permit No. MI0020257

FACT SHEET

PERMITTEE / SITE NAME: City of Cadillac / Cadillac WWTP

COUNTY: Wexford

DESCRIPTION OF EXISTING WASTEWATER TREATMENT FACILITIES

The Cadillac Wastewater Treatment Plant serves the City of Cadillac, Cherry Grove Township, Clam Lake Township, and Selma Township. Preliminary treatment consists of a flow equalization basin, a grit chamber, and a comminutor. After preliminary treatment, the wastewater then flows through primary clarifiers, an aeration basin with fine bubble diffusers, secondary clarifiers, rotating biological contactors, and tertiary filters. Ferric chloride is added during the treatment process to aid in phosphorus removal. The treated effluent is disinfected with ultraviolet light prior to being discharged to the Clam River. Sludge generated at the facility is stabilized in an anaerobic digester and stored until land applied.

MAP OF DISCHARGE LOCATION

Facility Coordinates: Latitude 44.265563, Longitude -85.397769



RECEIVING WATER

The Clam River is protected for agricultural uses, navigation, industrial water supply, public water supply in areas with designated public water supply intakes, warm-water fish, other indigenous aquatic life and wildlife, partial body contact recreation, total body contact recreation (May through October), and fish consumption.

The receiving stream flows used to develop effluent limitations are a 95 percent exceedance flow of 2.6 cfs, a harmonic mean flow of 13 cfs, and a 90-day, 10-year low flow of 3.4 cfs.

MIXING ZONE

For toxic pollutants, the volume of the Clam River used to ensure that effluent limitations are sufficiently stringent to meet Water Quality Standards is not more than 25 percent of the receiving water design flow for lotic systems, in accordance with R 323.1090(2).

For other pollutants, the volume of the Clam River used to ensure that effluent limitations are sufficiently stringent to meet Water Quality Standards is the applicable design flow of the receiving stream.

EXISTING EFFLUENT QUALITY: (from DMR data from November 1, 2017 to March 31, 2023)

Parameter	Minimum Daily	Maximum Monthly Average	Maximum 7-Day Average	Maximum Daily	Units
Flow	---	2.07	---	2.97	MGD
Carbonaceous Biochemical Oxygen Demand (CBOD5)					
June – September	---	7.41	---	16	mg/l
October – November	---	10.81	---	23.7	mg/l
December – March	---	11.28	---	27.3	mg/l
April – May	---	10.47	---	22.5	mg/l
Total Suspended Solids (TSS)					
June – September	---	13.1	20.2	20.2	mg/l
October – May	---	14.74	33.1	62	mg/l
Ammonia Nitrogen (as N)					
June – September	---	0.48	---	3.45	mg/l
October – November	---	1.88	---	19.8	mg/l
December – March	---	2.16	---	11.5	mg/l
April – May	---	1.179	---	3.28	mg/l
Total Phosphorus (as P)					
May – March	---	0.3736	---	3.51	mg/l
April	---	0.23	---	0.36	mg/l
Fecal Coliform Bacteria	---	36.4	509.3	2,420	cts/ 100 ml
Perfluorooctanesulfonic Acid (PFOS)	---	---	---	3.1	ng/l
Perfluorooctanoic acid (PFOA)	---	---	---	4.7	ng/l
Total Copper	---	19.98	---	24	ug/l
Total Nickel	---	---	---	10	ug/l
Total Selenium	---	5	---	---	ug/l
Bis(2-ethylhexyl)phthalate	---	11.6	---	---	ug/l
Total Mercury (12-month Rolling Average)	---	1.141	---	---	ng/l
		Minimum Monthly			
TSS Minimum Percent Removal					
October – May	80.63	86.66	---	---	%
pH	6.24	---	---	8.4	S.U.
Dissolved Oxygen					
May – November	6.5	---	---	---	mg/l
December – April	6.5	---	---	---	mg/l

PROPOSED EFFLUENT LIMITATIONS: (see draft permit)

BASIS FOR PROPOSED EFFLUENT LIMITATIONS: (see Basis for Decision Memo)

REGISTER OF INTERESTED PERSONS

Any person interested in receiving notification by e-mail of National Pollutant Discharge Elimination System (NPDES) or state surface water discharge permitting actions may register with the Permits Section of the Department of Environment, Great Lakes, and Energy (Department). To register, e-mail the contact identified below with your full name and the request that you be added to the Department's Public Notice Notification List. Once you are added to the list, you will receive an e-mail notification for every public-noticed NPDES or state surface water discharge permitting action in the state (or only those for which you've expressed a specific interest) unless/until you ask to be removed from the list.

PUBLIC COMMENT

Persons wishing to submit comments or request a public hearing should do so through MiEnviro Portal. Go to <https://miwaters.deq.state.mi.us>, select 'Public Notice Search,' search for this public notice by entering the permit number into the search field, click 'Search,' click 'View,' click 'Add Comment,' enter information into the fields, and then click 'Submit.' Comments or objections to the draft permit received by November 8, 2023, will be considered in the final decision to issue the permit, as will comments made at a public hearing should one be held by the Department on the draft permit.

Any person may request the Department to hold a public hearing on the draft permit. The request should include specific reasons for the request, indicating which portions of the draft permit constitute the need for a hearing. If submitted comments indicate significant public interest in the draft permit or if useful information may be produced, the Department may, at its discretion, hold a public hearing on the draft permit.

If a public hearing is scheduled, public notice of the hearing will be provided at least 30 days in advance. The hearing will normally be held in the vicinity of the discharge. Inquiries should be directed to Tom Braum, Permits Section, Water Resources Division, Department of Environment, Great Lakes, and Energy, P.O. Box 30458, Lansing, Michigan 48909-7958; telephone: 517-331-7377; or e-mail: BraumT2@michigan.gov.