

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/19/2017 1:02:41 PM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>; "Jankowski, Brian (DEQ)" <JANKOWSKIB@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: Ammonia violation (permit no. MI0020257)

Mr. Brady,

Per our conversation yesterday, I'm writing to inform you of an ammonia exceedance that occurred on 5/18. We had a 4.62 mg/L that exceeded our 2.0 mg/L limit. I believe that the issue was from a sample pump malfunction. I did a couple grab samples to check our outfall and the discharge was within our limits. I don't think we discharged at that concentration to the river. All of today's data is back within our limits.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841