

NPDES APPLICATION REVIEW CHECKLIST FOR TREATMENT WORKS TREATING DOMESTIC SEWAGE

Processor: Tom Braum
 Date: June 6, 2022
 Facility Designated Name: Cadillac WWTP
 Permit No.: MI0020257
 Application Received Date: March 25, 2022
 Permit Action: Reissuance

Y, N, NA, or NC (No Change)	Application Section	The Department must provide notification of deficiencies in new or increased use applications within 30 days of receipt and in reissuance applications within 90 days. An application is administratively complete when the appropriate and necessary information has been provided, including any required submittals. Required application submittals may include WET tests and toxicity scans. Applications with submittals that do not satisfy QA/QC requirements are considered administratively complete, even though they are not technically complete.
INFORMATION TO BE SUBMITTED WITH APPLICATION		
Y		For reissuances: Review the current permit and verify that any required submittals due with the application for reissuance were actually submitted with the application. If any are missing, immediately request these from the permittee. Were all required submittals included with app? Submittal for October 2019 Additional Monitoring Requirements was missing data. Request missing data be submitted.
GENERAL INFORMATION		
Y		Was the application accompanied by the required application fee?
Y	Application Type/Title	Confirm the facility has filled out the correct permit application?
Y	Permit #	Was the NPDES permit number generated correctly?
Y	Applicant Information	Does the application identify the name and address of the applicant?
Y	Facility Information	Did the applicant provide the address and location of the facility?
Y		Has the local unit of government (LUG) been identified, and a LUG contact person and email been provided? (Typically the clerk contact info should be provided; for individual permits, we use the clerk email for the Public Notice Notification email)
Y		Has the applicant indicated ("yes" or "no") that the facility has an EGLE-Certified Operator at the appropriate level?
NA		If the applicant indicated "no" to the previous question, did the applicant provide an explanation for why the facility does not have a certified operator?
N	Contacts	Has the applicant provided an application contact, facility contact, DMR contact, annual permit fee billing contact, and certified operator contact, at a minimum? Missing all but Certified Operator.
Y	Antidegradation	Has the applicant indicated if the discharge will be an increased loading of pollutants to the surface waters of the state?
NA		Has a Rule 1098 Demonstration or exemption statement been provided? (Not needed for reissuances if the following two things are true: 1) the facility is requesting the same authorized flow rate of the same wastewater types to the same location on the same receiving water as the current permit; and 2) the facility answered "none" to the question concerning increased loading)
N	Additional Information	Does the applicant hold any other environmental permits? (may not be needed for administrative completeness)
Y		Has a water flow diagram including type of water and water balance information been provided in sufficient detail appropriate for the site?

Y		Have a narrative description of the water flow through the facility and a description of wastewater treatment processes and/or manufacturing processes been provided?
Y		Has a map of the facility and exact location of the discharge(s) to the receiving waters been provided (USGS quad map level of detail, as a minimum)?
Y	Laboratory Services	Has the applicant provided a list of contract laboratories? (not necessary for administrative completeness)
Water Source and Discharge Type		
Y	1	Has the applicant provided Water Supply Information?
Y	2	Has the applicant provided the service area information by completing the applicable section for either Publicly Owned Treatment Works or Privately Owned Treatment Works? Request more information on population served.
Y	3 and Wastewater Stabilization Lagoon	Has the applicant indicated whether or not they have a WWSL, and if they do, completed the mandatory section for WWSLs? Once this mandatory section has been filled out and you've determined it's complete, assign the task named Exfil/Leakage Review is Needed by Compliance & Eng to District compliance manager and give them 3 weeks to complete it.
Y	4	Has the applicant included WET test data with the application if required? (Not applicable for new use sites)
Outfall Information and Effluent Characteristics		
Y	1	Has the outfall information been provided? (including outfall number, outfall description, receiving water name, and outfall latitude and longitude)
Y	1, 2	Has the discharge been identified as continuous or seasonal, and has the Annual Average Design Flow been provided?
Y	2	Is the discharge schedule and expected discharge flow information complete including information for batch dischargers when appropriate?
Y	3	Has the information for inflow and infiltration been provided?
N	4	Has the applicant provided effluent characteristics for conventional pollutants or submitted via DMRs? Adequate waiver requests not provided for TOC, COD, Temperature.
Y	5	Has the applicant provided a disinfection indicator?
Y	6	Has the applicant provided daily effluent characteristics for toxic pollutants that are known or believed to be present in the discharge? Application indicates these results have been previously provided to EGLE.
Y		IF the facility has an annual average design flow rate greater than or equal to one (1) MGD, OR an approved Federal Industrial Pretreatment Program (FIPP), OR is required to develop a FIPP, OR is otherwise required by EGLE: Has the applicant uploaded the results of a minimum of three (3) effluent analyses for each parameter identified in the Additional Monitoring Requirements section of their NPDES permit for each outfall through which effluent is discharged? (Not applicable for new use sites) Submittal for October 2019 Additional Monitoring Requirements was missing data. Request missing data be submitted.
Y	Collection System Information	Has the applicant provided CSO information where appropriate?
Y	Nondomestic Wastewater Information	Has the applicant provided information on septage, RCRA, and remediation wastewater?
Y		Has the applicant provided information on industrial/commercial sources of wastewater?
Y	Significant Industrial User Information	Has the applicant provided SIU data as appropriate?

Y	Biosolids Information	Has the applicant completed the Biosolids Information section of the application?
Y	Storm Water	Has the applicant indicated whether or not they are engaged in a regulated industrial activity? Note that all Treatment Works Treating Domestic Sewage with a design flow of 1.0 MGD or greater are required under 40 CFR 122.26(b)(14)(i)-(xi) to either obtain NPDES storm water coverage or certify a condition of no exposure.
Y		Has the applicant indicated whether or not storm water from this facility is discharged to a surface water of the state?
Y		Has the applicant indicated whether or not any industrial activities or materials are exposed to storm water at this facility?
Y		If they do not have such exposure, have they submitted an NEC with their application or have an in-effect NEC on file?
NA		(If ISW coverage is required) Does the applicant indicate they have an industrial storm water (ISW) certified operator? ISW coverage cannot be granted until an ISW certified operator has been obtained.
NA		(If ISW coverage is required) Does the applicant indicate that a SWPPP has been developed and implemented? ISW coverage cannot be granted until a SWPPP has been developed and implemented.
NA		Does the facility identify whether or not they discharge storm water to a surface water of the state or a municipal separate storm sewer system from a special use area? If applicant indicated secondary containment structures, the following question also applies:
NA		Did the facility provide a list of the materials stored in secondary containment structures?

Application review notes and comments:

REVIEW THE FOLLOWING FOR ASSISTANCE IN DETERMINING APPLICATION COMPLETENESS

The following table contains some alternate chemical names that may be helpful in your review of primary industry scans or additional monitoring requirements.

Name	CAS	Alternate Name
chlorodibromomethane	124-48-1	dibromochloromethane
dichlorobromomethane	75-27-4	bromodichloromethane
methyl bromide	74-83-9	bromomethane
methyl chloride	74-87-3	chloromethane
4,6-dinitro-O-cresol	534-52-1	4,6-dinitro-2-methyl phenol OR 2-methyl-4,6-dinitrophenol
p-chloro-M-cresol	59-50-7	4-chloro-3-methyl phenol
3,4-benzofluoranthene	205-99-2	benzo(b)fluoranthene
1,2-diphenylhydrazine	122-66-7	Hydrazobenzene (may accept azobenzene)
N-nitrosodimethylamine	62-75-9	dimethylnitrosamine

All POTWs must report BOD5 or CBOD5, fecal coliform, TSS, temperature*, and pH.

In addition to the above, all POTWs with a design flow of ≥ 0.1 MGD must also report ammonia (as N), TRC (if used), DO, phosphorus, and TDS*.

In addition to both of the above, all POTWs with a design flow of ≥ 1 MGD, or an approved IPP, or the requirement to develop an IPP, or otherwise required by the Department, must also report all toxic

pollutants required by the application AND barium and boron if barium and boron are listed in the Additional Monitoring Condition of the permit.

*Although these are requirements specified in 40 CFR 122, the permit writer may use judgment to determine that temperature and/or TDS data are not required for a complete application from a given POTW.