

BIOLOGIST NPDES APPLICATION REVIEW CHECKLIST FOR TREATMENT WORKS TREATING DOMESTIC SEWAGE

Processor: Glen Schmitt

Facility Designated Name: Cadillac WWTP

Permit No.: MI0020257

Submission ID: HPG-1ZSF-KC99G

Permit Action: Reissuance

Application Received Date: March 25, 2022

Date Application Review Task: April 26, 2022

Date of Application Review: May 9, 2022

Date of Correction Request: **Created a Correction Note on 6/1/2022 (See comments in red below)**

Y, N, NA, or NC (No Change)	Application Section	The Department must provide notification of deficiencies in new or increased use applications within 30 days of receipt and in reissuance applications within 90 days. An application is administratively complete when the appropriate and necessary information has been provided, including any required submittals. Required application submittals may include WET tests and toxicity scans. Applications with submittals that do not satisfy QA/QC requirements are considered administratively complete, even though they are not technically complete.
INFORMATION TO BE SUBMITTED WITH APPLICATION		
N/A		For reissuances: Review the current permit and verify that any required submittals due with the application for reissuance were actually submitted with the application. If any are missing, immediately request these from the permittee. Were all required submittals included with app?
GENERAL INFORMATION		
Y	Laboratory Services	Has the applicant provided a list of contract laboratories? (not necessary for administrative completeness)
Water Source and Discharge Type		
Y	4	Has the applicant included WET test data with the application if required? (Not applicable for new use sites) October 2019 WET Lab Report Filename: <u>19.10.EF.AddlMonit.WET.ERM.pdf</u> December 2019 WET Lab Report Filename: <u>19.12.Eff.FollowUp.WET.ERM.pdf</u> May 2020 WET Lab Report Filename: <u>20.05.Eff.AddlMonit.ERM.pdf</u> March 2021 WET Lab Report Filename: <u>21.03.Eff.AddlMonit.ERM.pdf</u> August 2021 WET Lab Report Filename: <u>21.08.Eff.AddlMonit.ERM.pdf</u>
Outfall Information and Effluent Characteristics		
Y	6	Has the applicant provided daily effluent characteristics for toxic pollutants that are known or believed to be present in the discharge?
Y		IF the facility has an annual average design flow rate greater than or equal to one (1) MGD, OR an approved Federal Industrial Pretreatment Program (FIPP), OR is required to develop a FIPP, OR is otherwise required by EGLE: Has the applicant uploaded the results of a minimum of three (3) effluent analyses for each parameter identified in the Additional Monitoring Requirements section of their NPDES permit for each outfall through which effluent is discharged? (Not applicable for new use sites)

	October 2019 Lab Report Filename: <u>19.Oct.Eff.AM.Paragon.pdf</u> a) No analytical results were reported for 2-chlorophenol (CAS# 95578) and Bis(2-chloroisopropyl)ether (CAS# 108601). b) The QL for Bis(2-ethylhexyl)phthalate was <10 ug/l. However, due to the mixing zone, this QL is likely sufficient. May 2020 Lab Report Filename: <u>20.05.Eff.AddlMonit.Parago.revised.pdf</u> March 2021 Lab Report Filename: <u>21.03.Eff.AddlMonit.Paragon.pdf and 21.03.Eff.AddlMonit Fibertec.pdf</u> a) The QL for Methyl Bromide (CAS# 74839) was <5.0 ug/l. However, due to the mixing zone, the QL is likely sufficient. August 2021 Lab Report Filenames: a) <u>21.08.16.Eff.AddlMonit.Paragon.pdf</u> b) <u>21.08.31.Eff.AddlMonit.MeritConfirm.pdf</u> c) <u>21.08.31.Eff.AddlMonit.ParagonRepeat.pdf</u> d) <u>21.08.Eff.AddlMonit.Fibertec.pdf</u> The QL for Bromomethane (CAS# 74839) of <5.0 ug/l is likely not sufficient, however, this parameter was not listed in the QL table. <u>Created a Correction Note on 6/1/2022</u> We request the following Correction Requests: 1) We request the permittee contact Paragon Labs to ask if the October 2019 lab report can be revised to include results for 2-chlorophenol (CAS# 95578) and Bis(2-chloroisopropyl)ether (CAS# 108601) or, The facility shall collect one final effluent sample in June 2022 and have the sample analyzed for 2-chlorophenol (CAS# 95578) and Bis(2-chloroisopropyl)ether (CAS# 108601). The October 2019 Additional Monitoring Requirements lab report did not include any results for 2-chlorophenol (CAS# 95578) and Bis(2-chloroisopropyl)ether (CAS# 108601).
--	--

Application review notes and comments:

REVIEW THE FOLLOWING FOR ASSISTANCE IN DETERMINING APPLICATION COMPLETENESS

The following table contains some alternate chemical names that may be helpful in your review of primary industry scans or additional monitoring requirements.

Name	CAS	Alternate Name
chlorodibromomethane	124-48-1	dibromochloromomethane
dichlorobromomethane	75-27-4	bromodichloromethane
methyl bromide	74-83-9	bromomethane
methyl chloride	74-87-3	chloromethane
4,6-dinitro-O-cresol	534-52-1	4,6-dinitro-2-methyl phenol OR 2-methyl-4,6-dinitrophenol
p-chloro-M-cresol	59-50-7	4-chloro-3-methyl phenol
3,4-benzofluoranthene	205-99-2	benzo(b)fluoranthene
1,2-diphenylhydrazine	122-66-7	Hydrazobenzene (may accept azobenzene)
N-nitrosodimethylamine	62-75-9	dimethylnitrosamine

All POTWs must report BOD5 or CBOD5, fecal coliform, TSS, temperature*, and pH.

In addition to the above, all POTWs with a design flow of ≥ 0.1 MGD must also report ammonia (as N), TRC (if used), DO, phosphorus, and TDS*.

In addition to both of the above, all POTWs with a design flow of ≥ 1 MGD, or an approved IPP, or the requirement to develop an IPP, or otherwise required by the Department, must also report all toxic pollutants required by the application AND barium and boron if barium and boron are listed in the Additional Monitoring Condition of the permit.

*Although these are requirements specified in 40 CFR 122, the permit writer may use judgment to determine that temperature and/or TDS data are not required for a complete application from a given POTW.