

PUBLIC NOTICE

Date: October 9, 2023
Permit No.: MI0020257
Designated Site Name: Cadillac WWTP

The Department of Environment, Great Lakes, and Energy (EGLE), Water Resources Division (WRD), proposes to reissue a permit to the City of Cadillac for the Cadillac Wastewater Treatment Plant located at 1121 Plett Road, Cadillac, Wexford County, Michigan 49601. The applicant collects wastewater from the City of Cadillac, Cherry Grove Township, Clam Lake Township, and Selma Township. The applicant discharges treated municipal wastewater to the Clam River.

The draft permit includes the following modifications to the previously issued permit: Permit language has been revised to incorporate updated references and terminology. The following new conditions have been added to the draft permit: Continuous Monitoring and PFAS Data Reporting Requirements. The parameters Perfluorooctanoic acid (PFOA) and Perfluorobutanesulfonic acid (PFBS) have been added to the Additional Monitoring Requirements section. Final effluent limitations have been revised for Carbonaceous Biochemical Oxygen Demand (CBOD5). Final effluent limitations for Total Selenium and Bis(2-ethylhexyl)phthalate have been removed. Reporting requirements for Total Nickel have been removed. Final effluent limitations for Total Copper have been changed to twice monthly reporting requirements. Final effluent limitations have been added for Total Arsenic, Total Beryllium, Total Cadmium, Total Silver, Chronic Toxicity, Available Cyanide, and Total Benzidine. Reporting requirements have been added for Chloride, Sulfate, Acute Toxicity, and Total Bromomethane. The monitoring frequency for Perfluorooctanesulfonic Acid (PFOS) has been revised to 3x Annual. Ammonia Nitrogen loading limits have been revised. Revised Ammonia Nitrogen limits developed in accordance with new chronic toxicity criterion take effect October 1, 2026.

The final effluent limitation for total mercury remains 2.0 nanograms per liter (ng/l), which is the discharge-specific level currently achievable based on a multiple discharger variance (MDV) from the water quality-based effluent limit of 1.3 ng/l, pursuant to R 323.1103(9) of the Part 4 Rules, Water Quality Standards, promulgated under Part 31, Water Resources Protection, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

Copies of the permit application, Public Notice, Fact Sheet, Basis for Decision Memo, draft permit, and other relevant documents associated with this proposed permitting action may be obtained via the Internet at <https://mienviro.michigan.gov/ncore/> (select 'Public Notice Search,' enter the permit number into the search field, and then click 'Search'), or at the WRD's Cadillac District Office located at 120 West Chapin Street, Cadillac, MI 49601-2158, telephone: 231-775-3960.

Persons wishing to submit comments on the draft permit should do so through MiEnviro Portal. Go to <https://mienviro.michigan.gov/ncore/>, select 'Public Notice Search,' search for this public notice by entering the permit number into the search field, click 'Search,' click 'View,' click 'Add Comment,' enter information into the fields, and then click 'Submit.' Comments or objections to the draft permit received by November 8, 2023, will be considered in the final decision to issue the permit, as will comments made at a public hearing should one be requested and held by the Department on the draft permit.

Any person may request the Department to hold a public hearing on the draft permit. The request should include specific reasons for the request, indicating which portions of the draft permit constitute the need for a hearing. If submitted comments indicate significant public interest in the draft permit or if useful information may be produced, the Department may, at its discretion, hold a public hearing on the draft permit. If a public hearing is scheduled, public notice of the hearing will be provided at least 30 days in advance. Inquiries should be directed to Tom Braum, Permits Section, WRD, EGLE, P.O. Box 30458, Lansing, Michigan 48909-7958; telephone: 517-331-7377; or e-mail: BraumT2@michigan.gov. The discharge-specific level currently achievable for total mercury was developed in accordance with the WRD's approved MDV. A copy of the MDV may be obtained via the Internet at <https://www.michigan.gov/egle/about/organization/water-resources/npdes> (under About NPDES, select Applicable Rules and Regulations), or at the WRD's Cadillac District Office.