

Report of Discharge (CSO/SSO/RTB)

version 1.15

(Submission #: HQN-NX4Y-ZMB09, version 1)

Digitally signed by:
MiEnviro Portal
Date: 2026.05.19 17:18:03 -04:00
Reason: Submission Data
Location: State of Michigan

Details

Submission ID HQN-NX4Y-ZMB09

Form Input

Report Details

Is this the initial or final discharge report?

Initial

Site/Facility Name:

Cadillac WWTP

Permit Number (if applicable):

MI0020257

Sewer System or Treatment Facility Owner

Organization Name

Cadillac Utilities Department

Phone Type	Number	Extension
------------	--------	-----------

Business	2317750181	124
----------	------------	-----

Email

utilities@cadillac-mi.net

Fax

2317750906

Address

200 N Lake St Ste 1

Cadillac, MI 49601-1864

United States

Facility Address

1121 PLETT RD

CADILLAC, MI 49601-1211

Sewer System or Treatment Facility Owner Location

44.2656,-85.3978

1121 PLETT RD, CADILLAC, MI

Discharge Details (1 of 1)

Other Discharge from Cadillac Wastewater Plant`OUTFL\_ID\_TXT`

Discharge Type:

Other Discharge

What type of discharge?

Partially treated Wastewater

Other Discharge

The reported discharge was of untreated or partially treated sewage (definition in Section 3112a) which is not characterized by RTB, CSO, or SSO Discharges.

Is the outfall or discharge area located at a private residential address?

NO

Outfall or Discharge Area Name

Cadillac Wastewater Plant

Outfall or Discharge Area Description

Wastewater Plant Outfall 001

Outfall or Discharge Area Location

44.26589948042667,-85.398202819768

Has the discharge ended?

YES

Volume Discharged	Unit	Was the volume estimated?
16.369	Million Gallons	No

Quality of Discharge

Partially Treated

Please describe the discharge, including the reason for Discharge

High Flow. All water was 100% treated in Primary and Secondary treatment. 72.5% of the flow stream was treated in tertiary treatment. All of waste stream went through disinfection process.

Were all effluent limits met during the event?

YES

Was the land or surface water impacted by the discharge?

Surface water impacted only

Name of Surface Water(s) Impacted:
Clam River

Discharge Event Start

Date	Time
04/16/2026	08:00 am

Discharge Event End

Date	Time
04/29/2026	08:00 am

Initial Notification

Organization	Date	Time
Local Health Department	05/07/2026	02:15 pm
Daily Local Newspaper	05/07/2026	02:15 pm

Was EGLE notified prior to this report being received?

EGLE was notified prior to this report being submitted

Prior EGLE notification that discharge has started

EGLE Notification Method	Person(s) notified	EGLE Notification Date	EGLE Notification Time	Comments
Phone	Aaron Kline	04/27/2026	11:00 am	Patrick Miller talked to Aaron

Email notification is only acceptable for CSO/RTB discharges and those discharges that have an alternative notification method previously approved by the Department

Notification that discharge has concluded.

Organization	Date	Time
Local Health Department	NONE PROVIDED	NONE PROVIDED
Daily Local Newspaper	NONE PROVIDED	NONE PROVIDED

Precipitation Type(s) (Select none if there was no precipitation)

Rain

Has the precipitation ended?

YES

Precipitation

Start Date	Start Time
04/01/2026	08:00 am

Precipitation Amount (Inches)	Precipitation End Date	Precipitation End Time
11.75	04/18/2026	08:00 am

Precipitation comments

Sustained rain over 17 days caused water to cover sewer system allowing infiltration

Was this discharge disinfected to meet fecal coliform limitations?

YES

Additional Details

Report Submitter

Prefix

Mr.

First Name

Jeffrey

Last Name

Dietlin

Title

NONE PROVIDED

Organization Name

Cadillac Utilities Department

Phone Type

Number

Extension

Business

2317750181

124

Email

utilities@cadillac-mi.net

Fax

2317750906

Address

200 N Lake St Ste 1

Cadillac, MI 49601-1864

[NO COUNTRY SPECIFIED]

Do you have any additional comments or uploads you would like to provide?

YES

Additional Information

I do not agree with having to submit this report. All waste has primary and secondary treatment. all of the waste stream had disinfection. Most plants in Michigan has those treatment processes.
Since Cadillac has tertiary treatment I believe we are being held to a higher standard.

Upload addition information, as needed.

NONE PROVIDED
Comment
NONE PROVIDED