

Digitally signed by:
MiEnviro Portal
Date: 2026.06.18 08:45:21 -04:00
Reason: Copy Of Record
Location: State of Michigan

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 7

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Prior to Disinfection (B)	Prior to Disinfection (B)	Conventional Daily	Conventional Daily	Prior to Disinfection (B)	Prior to Disinfection (B)
Limit	(Report) MGD	45 mg/L	1,200 lb/d	(Report) mg/L	(Report) lb/d	25 mg/L	670 lb/d
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
5/1/2026	3.34			4.40	122.44	3.00	
5/2/2026	3.04			3.60	91.25		
5/3/2026	2.88			4.00	96.12		
5/4/2026	2.97			6.00	148.37	3.15	
5/5/2026	3.11			3.60	93.31	3.00	
5/6/2026	2.89			2.80	67.37	3.50	
5/7/2026	2.83	4.06	101.88	4.00	94.32	3.30	80.23
5/8/2026	2.76	3.77	92.29	2.40	55.29	3.50	79.66
5/9/2026	2.81	3.77	91.31	3.60	84.41		79.66
5/10/2026	2.44	3.43	82.23	1.60	32.54		79.66
5/11/2026	2.39	3.03	70.16	3.20	63.91	3.95	79.86
5/12/2026	2.39	3.03	67.11	3.60	71.90	4.30	81.49
5/13/2026	2.44	3.20	69.09	4.00	81.26	5.00	84.96
5/14/2026	2.36	3.31	69.09	4.80	94.34	5.20	89.83
5/15/2026	2.40	3.54	72.61	4.00	79.95	6.30	98.89
5/16/2026	2.27	3.49	69.22	3.20	60.66		98.89
5/17/2026	2.09	3.77	73.54	3.60	62.76		98.89
5/18/2026	2.12	4.06	77.57	5.20	92.13	6.05	104.55
5/19/2026	2.48	4.40	85.02	6.00	124.01	5.00	108.05
5/20/2026	2.39	4.40	84.82	4.00	79.86	4.70	106.50
5/21/2026	2.29	4.17	80.08	3.20	61.20	4.80	104.42

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/22/2026	2.21	4.11	78.16	3.60	66.48	4.60	96.23
5/23/2026	2.15	3.94	74.61	2.00	35.79		96.23
5/24/2026	1.98	3.77	71.32	2.40	39.73		96.23
5/25/2026	2.11	3.49	66.20	3.20	56.32	4.65	91.16
5/26/2026	2.12	3.03	55.56	2.80	49.54	3.20	81.81
5/27/2026	2.23	2.86	51.59	2.80	52.08	3.90	77.55
5/28/2026	2.41	3.26	60.10	6.00	120.75	4.00	75.29
5/29/2026	2.35	3.09	57.33	2.40	47.09	4.30	75.17
5/30/2026	2.18	3.54	65.72	5.20	94.50		75.17
5/31/2026	1.96	3.54	65.65	2.40	39.27		75.17

Set: 2 of 7

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Available Cyanide
Mon. Loc.	Conventional Daily	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lb/d	(Report) mg/L	(Report) lb/d	(Report) mg/L	(Report) lb/d	(Report) ug/L	(Report) lb/d
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
5/1/2026	83.48	4.43	123.27	0.24	6.65		
5/2/2026							
5/3/2026							
5/4/2026	77.89	1.58	39.07	0.31	7.72	3.00	0.0742
5/5/2026	77.76	3.23	83.72	0.23	5.83		
5/6/2026	84.21	1.94	46.68	0.10	2.48		
5/7/2026	77.82	1.62	38.20	0.23	5.52		
5/8/2026	80.63	1.29	29.72	0.18	4.15		
5/9/2026							
5/10/2026							
5/11/2026	78.89	0.90	17.89	0.30	5.89		
5/12/2026	85.89	0.94	18.86	0.23	4.67	1.60	0.0320

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/13/2026	101.58	1.45	29.46	0.20	4.12		
5/14/2026	102.20	1.02	20.05	0.26	5.05		
5/15/2026	125.91	1.17	23.38	0.27	5.34		
5/16/2026							
5/17/2026							
5/18/2026	107.19	0.50	8.91	0.30	5.32		
5/19/2026	103.34	1.18	24.39	0.27	5.50		
5/20/2026	93.84	0.56	11.10	0.30	5.93		
5/21/2026	91.80	0.38	7.29	0.24	4.67		
5/22/2026	84.95	0.34	6.19	0.32	5.95		
5/23/2026							
5/24/2026							
5/25/2026	81.84	0.10	1.78	0.19	3.34		
5/26/2026	56.61	0.21	3.63	0.25	4.48		
5/27/2026	72.54	0.04	0.69	0.26	4.74		
5/28/2026	80.50	0.10	1.95	0.33	6.56		
5/29/2026	84.37	0.07	1.28	0.31	6.14		
5/30/2026							
5/31/2026							

Set: 3 of 7

Parameter	Total Arsenic	Total Arsenic	Total Beryllium	Total Beryllium	Total Cadmium	Total Cadmium	Total Cadmium
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Conventional Daily
Limit	(Report) ug/L	(Report) lb/d	(Report) ug/L	(Report) lb/d	12 ug/L	0.32 lb/d	(Report) lb/d
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily
5/1/2026							
5/2/2026							
5/3/2026							
5/4/2026	1.00	0.0247	1.00	0.0247	0.20		0.00495

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/5/2026							
5/6/2026							
5/7/2026						0.00495	
5/8/2026						0.00495	
5/9/2026						0.00495	
5/10/2026						0.00495	
5/11/2026						0.00495	
5/12/2026						0.00495	
5/13/2026						0.00495	
5/14/2026						0.00495	
5/15/2026	1.00	0.0200	1.00	0.0200	0.20	0.00400	0.00400
5/16/2026	1.00	0.0190	1.00	0.0190	0.20	0.00389	0.00379
5/17/2026						0.00389	
5/18/2026						0.00389	
5/19/2026						0.00389	
5/20/2026						0.00389	
5/21/2026	1.00	0.0191	1.00	0.0191	0.20	0.00387	0.00383
5/22/2026						0.00381	
5/23/2026						0.00383	
5/24/2026						0.00383	
5/25/2026						0.00383	
5/26/2026						0.00383	
5/27/2026	1.00	0.0186	1.00	0.0186	0.20	0.00377	0.00372
5/28/2026						0.00372	
5/29/2026						0.00372	
5/30/2026						0.00372	
5/31/2026						0.00372	

Set: 4 of 7

Parameter	Total Copper	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank
-----------	--------------	---------------	---------------	--------------------------------	---------------------------------------	--------------------------------	---

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
 Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
 DMR Period: 5/1/2026 - 5/31/2026
 DMR Version: 1

Mon. Loc.	Prior to Disinfection (B)	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent
Limit	(Report) ug/L	(Report) ng/L	(Report) lb/d	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
5/1/2026		*g	*g	*g	*g	*g	*g
5/2/2026							
5/3/2026							
5/4/2026	7.60						
5/5/2026							
5/6/2026							
5/7/2026							
5/8/2026							
5/9/2026							
5/10/2026							
5/11/2026							
5/12/2026							
5/13/2026							
5/14/2026							
5/15/2026	9.30						
5/16/2026	7.90						
5/17/2026							
5/18/2026							
5/19/2026							
5/20/2026							
5/21/2026	7.50						
5/22/2026							
5/23/2026							
5/24/2026							
5/25/2026							
5/26/2026							
5/27/2026	9.40						
5/28/2026							
5/29/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/30/2026							
5/31/2026							

Set: 5 of 7

Parameter	Total Silver	Total Silver	Acute Toxicity (Ceriodaphnia dubia)	Acute Toxicity (fathead minnow)	Chronic Toxicity (fathead minnow)	Chronic Toxicity (Ceriodaphnia dubia)	Perfluorooctane Sulfonate (PFOS)
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)
Limit	(Report) ug/L	(Report) lb/d	(Report) TUA	(Report) TUA	(Report) TUC	(Report) TUC	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Individual Chronic Value	Individual Chronic Value	Maximum Daily
5/1/2026			*g	*g	*g	*g	
5/2/2026							
5/3/2026							
5/4/2026	0.50	0.0124					
5/5/2026							
5/6/2026							
5/7/2026							
5/8/2026							
5/9/2026							
5/10/2026							
5/11/2026							
5/12/2026							
5/13/2026							2.50
5/14/2026							
5/15/2026	0.50	0.0100					
5/16/2026	0.50	0.0095					
5/17/2026							
5/18/2026							
5/19/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/20/2026							
5/21/2026	0.50	0.0096					
5/22/2026							
5/23/2026							
5/24/2026							
5/25/2026							
5/26/2026							
5/27/2026	0.50	0.0093					
5/28/2026							
5/29/2026							
5/30/2026							
5/31/2026							

Set: 6 of 7

Parameter	Chloride	Sulfate	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) mg/L	(Report) mg/L	400 #/100mL	(Report) #/100mL	(Report) %	6.5 SU	9.0 SU
Stat. Base	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily
5/1/2026				13.40	97.18	6.90	6.90
5/2/2026							
5/3/2026							
5/4/2026				3.10	96.43	6.94	6.94
5/5/2026				13.40	97.91	6.89	6.89
5/6/2026			6.45	3.10	95.63	6.94	6.94
5/7/2026			5.57	7.50	98.00	7.05	7.05
5/8/2026			3.95	1.00	98.80	7.02	7.02

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/9/2026			3.95				
5/10/2026			4.20				
5/11/2026			2.20	1.00	97.33	6.94	6.94
5/12/2026			1.65	1.00	98.45	6.92	6.92
5/13/2026			1.00	1.00	98.11	6.94	6.94
5/14/2026			1.00	1.00	96.47	7.05	7.05
5/15/2026			1.00	1.00	97.44	7.00	7.00
5/16/2026			1.00				
5/17/2026			1.00				
5/18/2026			1.00	1.00	96.58	6.99	6.99
5/19/2026			1.00	1.00	96.94	6.96	6.96
5/20/2026	140.00	54.00	1.00	1.00	97.14	7.10	7.10
5/21/2026			1.00	1.00	97.78	7.15	7.15
5/22/2026			1.00	1.00	98.16	7.23	7.23
5/23/2026			1.00				
5/24/2026			1.00				
5/25/2026			1.00	1.00	97.95	7.33	7.33
5/26/2026			1.00	1.00	98.51	7.13	7.13
5/27/2026			1.00	1.00	98.89	7.20	7.20
5/28/2026			1.00	1.00	96.81	7.33	7.33
5/29/2026			1.25	3.00	96.58	7.46	7.46
5/30/2026			1.25				
5/31/2026			1.32				

Set: 7 of 7

Parameter	Dissolved Oxygen	Benzidine	Benzidine	Bromomethane			
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)			
Limit	6.0 mg/L	(Report) ug/L	(Report) lb/d	(Report) ug/L			
Stat. Base	Minimum Daily	Maximum Daily	Maximum Daily	Maximum Daily			
5/1/2026	6.57			*g			
5/2/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE			
TYPED OR PRINTED			2319126200				
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

5/3/2026						
5/4/2026	6.92					
5/5/2026	6.09					
5/6/2026	7.10					
5/7/2026	7.01	0.099	0.00233			
5/8/2026	7.35					
5/9/2026						
5/10/2026						
5/11/2026	7.31					
5/12/2026	7.37					
5/13/2026	6.73					
5/14/2026	7.59					
5/15/2026	6.86					
5/16/2026						
5/17/2026						
5/18/2026	7.30					
5/19/2026	7.05					
5/20/2026	7.79	0.100	0.00200			
5/21/2026	7.66					
5/22/2026	7.85					
5/23/2026						
5/24/2026						
5/25/2026	8.38					
5/26/2026	8.50					
5/27/2026	8.49					
5/28/2026	8.41					
5/29/2026	8.37					
5/30/2026						
5/31/2026						

DMR Instructions:
DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
				2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.48	3.34	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	77.32	101.88	lb/d	*****	3.71	4.40	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1,200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	87.30	108.05	lb/d	*****	4.26	6.30	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	450 Maximum Monthly Average	670 Maximum 7-Day Average		*****	17 Maximum Monthly Average	25 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	25.59	123.27	lb/d	*****	1.10	4.43	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	130 Maximum Monthly Average	REPORT Maximum Daily		*****	4.8 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	5.24	7.72	lb/d	*****	0.25	0.33	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Available Cyanide (01257) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0531	0.0742	lb/d	*****	2.3	3	ug/L		Monthly	Grab
	PERMIT REQUIREMENT	0.16 Maximum Monthly Average	REPORT Maximum Daily		*****	5.9 Maximum Monthly Average	REPORT Maximum Daily			Monthly	Grab
Total Arsenic (01002) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	0.0203	0.0247	lb/d	*****	1	1	ug/L		2X Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.43 Maximum Monthly Average	REPORT Maximum Daily		*****	16 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composite
Total Beryllium (01012) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	0.0203	0.0247	lb/d	*****	1	1	ug/L		2X Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.11 Maximum Monthly Average	REPORT Maximum Daily		*****	4.1 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composite
Total Cadmium (01027) Prior to Disinfection (B)	SAMPLE MEASUREMENT	0.00406	0.00495	lb/d	*****	0.2	0.2	ug/L		2X Monthly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	0.11 Maximum Monthly Average	0.32 Maximum 7-Day Average		*****	4.1 Maximum Monthly Average	12 Maximum Daily			2X Monthly	24-Hr Composit e
Total Copper (01042) Prior to Disinfection (B)	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	9.4	ug/L		2X Monthly	24-Hr Composit e
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			2X Monthly	24-Hr Composit e
Total Mercury (71900) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lb/d	*****	*g	*g	ng/L		Quarterly	Calculat ion
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculat ion
Total Mercury (71900) Hg Calculation (X)	SAMPLE MEASUREMENT	*g	*****	lb/d	*****	*g	*****	ng/L		Quarterly	Calculat ion
Lab ID:	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculat ion
Total Silver (01077) Prior to Disinfection (B)	SAMPLE MEASUREMENT	0.0101	0.0124	lb/d	*****	0.5	0.5	ug/L		2X Monthly	24-Hr Composit e
Lab ID:	PERMIT REQUIREMENT	0.037 Maximum Monthly Average	REPORT Maximum Daily		*****	1.4 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composit e

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200	AREA CODE	NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Acute Toxicity (Ceriodaphnia dubia) (61425) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*g	TUA		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Quarterly	24-Hr Composite
Acute Toxicity (fathead minnow) (TSI6C) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*g	TUA		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Quarterly	24-Hr Composite
Chronic Toxicity (fathead minnow) (TTK6C) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*g	*g	TUC		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	1.1 Maximum Monthly Average	REPORT Individual Chronic Value			Quarterly	24-Hr Composite
Chronic Toxicity (Ceriodaphnia dubia) (03599) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*g	*g	TUC		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	1.1 Maximum Monthly Average	REPORT Individual Chronic Value			Quarterly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS)	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	2.5	ng/L		3X Annually	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	2319126200			
			AREA CODE	NUMBER	YEAR	MO
					DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(51526) Final Effluent (1)	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			3X Annually	Grab
Lab ID:											
Chloride (00940) Prior to Disinfection (B)	SAMPLE MEASUREMENT	*****	*****		*****	*****	140	mg/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT Maximum Daily			Monthly	24-Hr Composite
Sulfate (00945) Prior to Disinfection (B)	SAMPLE MEASUREMENT	*****	*****		*****	*****	54	mg/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT Maximum Daily			Monthly	24-Hr Composite
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****		*****	2.79	6.45	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal (81011)	SAMPLE MEASUREMENT	*****	*****		97.48	*****	95.63	%		Monthly	Calculation
Percent Removal (K)	PERMIT REQUIREMENT	*****	*****	*****	85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
Lab ID:											
pH (00400) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	6.89	*****	7.46	SU		5X Weekly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY
			2319126200			

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 5/1/2026 - 5/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	6.09	*****	*****	mg/L		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		6.0 Minimum Daily	*****	*****			5X Weekly	Grab
Benzidine (39120) Final Effluent (1)	SAMPLE MEASUREMENT	0.00217	0.00233	lb/d	*****	0.1	0.1	ug/L		2X Monthly	Grab
Lab ID:	PERMIT REQUIREMENT	0.0032 Maximum Monthly Average	REPORT Maximum Daily		*****	0.12 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	Grab
Bromomethane (38677) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*g	ug/L		Quarterly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Quarterly	Grab

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

Permit Number: MI0020257 v7.0 **DMR Version:** 1 Generated: 6/18/2026 8:45 AM

Page 6 of 5

Submission Identifier: DMR-MI0020257-20260531-1

Submission Signature Hash: T2sCd/MCuEC1sbZ04n8Yw3YK19tRUQl8agQOse3rcYs=

Submitter Name: Patrick Miller

Submitter Email: pmiller@cadillac-mi.net

Submitted Date/Time: 6/18/2026 8:45:20 AM