

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	25 mg/L	670 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
5/1/2020	1.68	6.00	84.05	2.88	38.32	8.40	117.7
5/2/2020	1.68			2.00	25.60		
5/3/2020	1.40			2.00	25.60		
5/4/2020	1.42	3.20	37.79	2.00	25.60	4.83	57.0
5/5/2020	1.63	2.80	37.95	1.92	23.87	4.40	59.6
5/6/2020	1.63	0.40	5.42	1.92	23.02	8.10	109.8
5/7/2020	1.58	2.00	26.40	2.48	29.80	7.20	95.0
5/8/2020	1.53	1.60	20.45	2.48	29.53	7.45	95.2
5/9/2020	1.40			2.88	34.33		
5/10/2020	1.26			2.88	34.33		
5/11/2020	1.25	2.80	29.11	2.88	34.33	6.93	72.0
5/12/2020	1.44	2.80	33.72	3.52	43.18	4.90	59.0
5/13/2020	1.47	3.20	39.34	3.84	53.65	8.00	98.3
5/14/2020	1.50	2.00	25.04	3.84	56.77	8.80	110.2
5/15/2020	1.48	3.60	44.46	3.92	59.12	10.90	134.6
5/16/2020	1.41			3.44	53.74		
5/17/2020	1.24			3.44	53.74		
5/18/2020	1.47	6.00	73.33	3.44	53.74	8.96	109.5
5/19/2020	2.35	4.40	86.06	2.96	48.03	5.13	100.3
5/20/2020	2.06	3.20	54.97	2.64	37.76	4.10	70.4
5/21/2020	1.84	2.40	36.78	2.48	33.60	3.80	58.2

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2020	06	12
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/22/2020	1.75	1.20	17.55	2.48	33.04	3.80	55.6
5/23/2020	1.61			2.80	37.60		
5/24/2020	1.57			2.80	37.60		
5/25/2020	1.49	3.60	44.77	2.80	37.60	5.40	67.2
5/26/2020	1.49	2.80	34.74	2.60	35.81	4.00	49.6
5/27/2020	1.71	2.40	34.15	2.53	36.17	3.30	47.0
5/28/2020	1.70	2.40	33.99	2.60	37.18	3.00	42.5
5/29/2020	1.73	2.80	40.38	2.80	40.38	<3.000	<43.261
5/30/2020	1.61						
5/31/2020	1.41						

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
5/1/2020	87.8	1.13	15.83	0.21	2.94		
5/2/2020	83.3						
5/3/2020	83.3						
5/4/2020	83.3	1.57	18.54	0.18	2.13		
5/5/2020	86.3	0.30	4.07	0.20	2.71		
5/6/2020	86.2	0.30	4.07	0.16	2.17		
5/7/2020	83.9	0.30	3.96	0.15	1.98	11.3	0.149
5/8/2020	87.0	0.30	3.83	0.13	1.66		
5/9/2020	94.8						
5/10/2020	94.8						
5/11/2020	94.8	0.30	3.12	0.16	1.66		
5/12/2020	102.3	0.30	3.61	0.20	2.41		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 124 NUMBER	DATE 2020 06 12 YEAR MO DAY
--	---	--	--	---------------------------------	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/23/2021 3:58 AM

Page 2 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/13/2020	110.6	0.30	3.69	0.18	2.21	15.5	0.191
5/14/2020	105.0	0.30	3.76	0.17	2.13		
5/15/2020	94.6	0.30	3.71	0.20	2.47		
5/16/2020	78.8						
5/17/2020	78.8						
5/18/2020	78.8	0.30	3.67	0.28	3.42	17.50	0.21
5/19/2020	70.3	1.31	25.62	0.32	6.26		
5/20/2020	60.2	0.30	5.15	0.20	3.44		
5/21/2020	55.5	0.30	4.60	0.12	1.84		
5/22/2020	52.4	0.30	4.39	0.18	2.63		
5/23/2020	51.6					11.6	0.156
5/24/2020	51.6						
5/25/2020	51.6	0.30	3.73	0.19	2.36		
5/26/2020	46.4	0.30	3.72	0.26	3.23	13	0.161
5/27/2020	56.6	0.30	4.27	0.23	3.27		
5/28/2020	85.8	0.30	4.25	0.22	3.12		
5/29/2020	107.5	0.30	4.33	0.25	3.61		
5/30/2020	107.5						
5/31/2020							

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(report) ng/L	(report) lbs/day	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
5/1/2020	*G	*G	*G	*G	*G	*G	
5/2/2020							
5/3/2020							
5/4/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124	DATE 2020 06 12										
			<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">AREA CODE</td> <td style="width: 10%;">NUMBER</td> <td style="width: 10%;">YEAR</td> <td style="width: 10%;">MO</td> <td style="width: 10%;">DAY</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	AREA CODE	NUMBER	YEAR	MO	DAY						
AREA CODE	NUMBER	YEAR	MO	DAY										

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/5/2020							
5/6/2020							
5/7/2020							<5.000
5/8/2020							
5/9/2020							
5/10/2020							
5/11/2020							
5/12/2020							
5/13/2020							<5.000
5/14/2020							
5/15/2020							
5/16/2020							
5/17/2020							
5/18/2020							<5.000
5/19/2020							
5/20/2020							
5/21/2020							
5/22/2020							
5/23/2020							<5.000
5/24/2020							
5/25/2020							
5/26/2020							<5.000
5/27/2020							
5/28/2020							
5/29/2020							
5/30/2020							
5/31/2020							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2020	06	12
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) ug/L	(report) lbs/day	(report) ng/L	(report) lbs/day	(report) ng/L	(report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
5/1/2020				*G	*G	*G	*G
5/2/2020							
5/3/2020							
5/4/2020							
5/5/2020							
5/6/2020							
5/7/2020	<0.066	<2.000	<0.026				
5/8/2020							
5/9/2020							
5/10/2020							
5/11/2020							
5/12/2020							
5/13/2020	<0.061	<2.000	<0.025				
5/14/2020							
5/15/2020							
5/16/2020							
5/17/2020							
5/18/2020	<0.061	<2.000	<0.024				
5/19/2020							
5/20/2020							
5/21/2020							
5/22/2020							
5/23/2020	<0.067	<2.000	<0.027				
5/24/2020							
5/25/2020							
5/26/2020	<0.062	<2.000	<0.025				
5/27/2020							
5/28/2020							
5/29/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2020 06 12
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/30/2020							
5/31/2020							

Set: 5 of 6

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis (2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily (report) #/100mL	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL	(report) #/100mL	(report) %	6.5 SU	9.0 SU	6.0 mg/L	(report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
5/1/2020	1.0	1.000	97.692	6.78	6.8	9.7	
5/2/2020	1.0						
5/3/2020	1.0						
5/4/2020	1.0	1	98.919	6.88	6.9	9.5	
5/5/2020	1.0	1	95.882	7.18	7.2	9.5	
5/6/2020	1.0	1	99.783	7.02	7.0	9.6	
5/7/2020	1.0	1	99.351	7.02	7.0	9.4	
5/8/2020	1.0	1	99.5	6.84	6.8	9.3	
5/9/2020	1.0						
5/10/2020	1.0						
5/11/2020	1.0	1	99.626	6.62	6.6	9.7	
5/12/2020	1.0	1	99.136	6.59	6.6	9.6	
5/13/2020	1.0	1	98.806	6.73	6.7	9.6	
5/14/2020	1.0	1	99.606	6.71	6.7	9.2	<4,500
5/15/2020	1.0	1	98.714	6.73	6.7	9.0	
5/16/2020	1.0						
5/17/2020	1.0						
5/18/2020	1.0	1	97.414	6.53	6.5	9.2	
5/19/2020	1.0	1	98.889	6.86	6.9	9.3	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2020	06	12
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/20/2020	1.0	1	98.261	7.06	7.1	9.5	
5/21/2020	1.0	1	99	6.5	6.5	9.3	
5/22/2020	1.0	1	99.455	6.7	6.7	9.0	
5/23/2020	1.0						
5/24/2020	1.0						
5/25/2020	1.0	1	97.75	6.59	6.6	8.9	
5/26/2020		1	99.014	6.72	6.7	8.8	
5/27/2020		1	98.929	6.7	6.7	8.7	
5/28/2020		1	99.091	6.53	6.5	8.6	
5/29/2020		1	99.255	6.72	6.7	8.7	
5/30/2020							
5/31/2020							

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl) Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(report) lbs/day						
Stat. Base	Maximum Daily						
5/1/2020							
5/2/2020							
5/3/2020							
5/4/2020							
5/5/2020							
5/6/2020							
5/7/2020							
5/8/2020							
5/9/2020							
5/10/2020							
5/11/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2020	06	12
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 5/1/2020 - 5/31/2020
DMR Version: 1

5/12/2020							
5/13/2020							
5/14/2020	<0.0563481						
5/15/2020							
5/16/2020							
5/17/2020							
5/18/2020							
5/19/2020							
5/20/2020							
5/21/2020							
5/22/2020							
5/23/2020							
5/24/2020							
5/25/2020							
5/26/2020							
5/27/2020							
5/28/2020							
5/29/2020							
5/30/2020							
5/31/2020							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124	2020	06	12	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY