

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	10 mg/L	270 lbs/day	2 mg/L	53 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum 7-Day Average
8/1/2015	1.74						
8/2/2015	1.97						
8/3/2015	2.02	6.00	101.14	6.60	111.3	0.17	2.87
8/4/2015	2.30	4.00	76.85	5.20	99.9	0.24	4.61
8/5/2015	2.24	3.50	65.47	3.80	71.1	0.37	6.92
8/6/2015	2.21	4.40	81.21	3.90	72.0	0.24	4.43
8/7/2015	2.13	4.00	70.96	3.90	69.2	0.22	3.90
8/8/2015	1.88						
8/9/2015	1.97						
8/10/2015	2.32	4.00	77.25	5.20	100.4	0.12	2.32
8/11/2015	2.22	3.50	64.83	3.55	65.8	1.13	20.93
8/12/2015	2.23	4.50	83.75	2.90	54.0	0.53	9.86
8/13/2015	2.33	2.50	48.63	2.80	54.5	0.19	3.70
8/14/2015	2.20	1.60	29.35	4.20	77.0	0.84	15.41
8/15/2015	1.82						
8/16/2015	1.94						
8/17/2015	2.36	2.00	39.41	3.23	63.6	0.12	2.36
8/18/2015	2.30	1.60	30.70	2.20	42.2	0.13	2.49
8/19/2015	2.26	1.60	30.10	2.70	50.8	0.10	1.88
8/20/2015	2.11	2.00	35.19	3.30	58.1	0.22	3.87
8/21/2015	1.88	2.40	37.70	3.58	56.2	0.12	1.88
8/22/2015	1.75						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2015	09	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

8/23/2015	2.00						
8/24/2015	2.31	3.20	61.68	4.00	77.1	0.17	3.28
8/25/2015	2.06	2.40	41.19	2.70	46.3	0.24	4.12
8/26/2015	2.12	5.20	91.89	6.48	114.5	0.18	3.18
8/27/2015	2.11	2.00	35.19	3.55	62.5	0.13	2.29
8/28/2015	2.04	2.80	47.53	4.25	72.1	0.14	2.38
8/29/2015	1.74						
8/30/2015	1.83						
8/31/2015	2.24	0.80	14.94	6.03	112.63	0.11	2.05

Set: 2 of 4

Parameter	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Mercury QA-Effluent	Mercury QA-Effluent
Limit	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L	(report) ng/L	(report) ng/L	(report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
8/1/2015			<2	<50			
8/2/2015							
8/3/2015	0.17	2.87					
8/4/2015	0.19	3.65					
8/5/2015	0.21	3.93			<0.5	<0.2	<0.5
8/6/2015	0.21	3.88					
8/7/2015	0.21	3.73		<50			
8/8/2015							
8/9/2015							
8/10/2015	0.26	5.02					
8/11/2015	0.24	4.45					
8/12/2015	0.19	3.54					
8/13/2015	0.16	3.11					
8/14/2015	0.15	2.75					

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2015 09 18 YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

8/15/2015				<50			
8/16/2015							
8/17/2015	0.18	3.55					
8/18/2015	0.17	3.26					
8/19/2015	0.15	2.82					
8/20/2015	0.13	2.29					
8/21/2015	0.13	2.04					
8/22/2015							
8/23/2015				<50			
8/24/2015	0.16	3.08					
8/25/2015	0.15	2.57					
8/26/2015	0.14	2.47					
8/27/2015	0.13	2.29					
8/28/2015	0.06	1.02		<50			
8/29/2015							
8/30/2015							
8/31/2015	0.08	1.49					

Set: 3 of 4

Parameter	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)	Fecal Coliform	Fecal Coliform	pH
Mon. Loc.	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Fecal Daily	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC	400 #/100mL	(report) #/100mL	6.5 SU
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily
8/1/2015					25.5		
8/2/2015					25.5		
8/3/2015					25.5	17	7.28
8/4/2015					21.4	13	7.2

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2015	09	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

8/5/2015	<0.2	<0.2	0	0	23.7	12	7.43
8/6/2015					27.3	110	7.56
8/7/2015					21.7	37	7.52
8/8/2015					19.5		
8/9/2015					19.5		
8/10/2015					19.5	7	7.43
8/11/2015					21.8	22	7.35
8/12/2015					18.6	24	7.52
8/13/2015					13.6	35	7.48
8/14/2015					9.2	22	7.33
8/15/2015					6.8		
8/16/2015					6.8		
8/17/2015					6.8	12	7.07
8/18/2015					5.7	10	7.35
8/19/2015					5.2	5	7.35
8/20/2015					6.8	5	7.43
8/21/2015					5.7	5	7.42
8/22/2015					5.7		
8/23/2015					5.7		
8/24/2015					5.7	5	7.18
8/25/2015					5.1	6	7.22
8/26/2015						20	7.04
8/27/2015						2	7.43
8/28/2015						5	7.5
8/29/2015							
8/30/2015							
8/31/2015						3	7.41

Set: 4 of 4

Parameter	pH	Dissolved Oxygen					
Mon. Loc.	Final Effluent (1)	Final Effluent (1)					

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2015 09 18 YEAR MO DAY
--	---	--	--	---

Permit Number: MI0020257 v5.0

DMR Version: 1

Generated: 3/29/2021 8:48 PM

Page 4 of 5

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

Limit	6.5 SU	6.0 mg/L				
Stat. Base	Minimum Daily	Minimum Daily				
8/1/2015						
8/2/2015						
8/3/2015	7.3	8.0				
8/4/2015	7.2	8.1				
8/5/2015	7.4	8.1				
8/6/2015	7.6	8.1				
8/7/2015	7.5	7.9				
8/8/2015						
8/9/2015						
8/10/2015	7.4	7.9				
8/11/2015	7.4	7.8				
8/12/2015	7.5	7.9				
8/13/2015	7.5	7.9				
8/14/2015	7.3	7.6				
8/15/2015						
8/16/2015						
8/17/2015	7.1	7.6				
8/18/2015	7.4	7.6				
8/19/2015	7.4	7.5				
8/20/2015	7.4	8.3				
8/21/2015	7.4	7.6				
8/22/2015						
8/23/2015						
8/24/2015	7.2	7.6				
8/25/2015	7.2	7.9				
8/26/2015	7.0	7.8				
8/27/2015	7.4	7.7				
8/28/2015	7.5	7.6				
8/29/2015						
8/30/2015						
8/31/2015	7.4	7.6				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2015 09 18
--	---	---	---	---	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 8/1/2015 - 8/31/2015
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2015	09	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY