

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	(report) mg/L	(report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
11/1/2015	1.66			4.48	70.34		
11/2/2015	1.60	4.80	64.07	4.48	70.34	6.20	82.8
11/3/2015	1.97	4.40	72.20	4.24	67.15	4.20	68.9
11/4/2015	1.95	4.00	64.96	3.92	61.39	3.90	63.3
11/5/2015	1.97	4.80	78.67	3.60	55.85	3.40	55.7
11/6/2015	1.96	4.40	71.82	3.36	51.75	3.85	62.8
11/7/2015	1.84			3.28	50.66		
11/8/2015	1.50			3.28	50.66		
11/9/2015	1.60	3.60	48.10	3.28	50.66	3.20	42.8
11/10/2015	1.86	2.80	43.39	3.44	53.40	3.10	48.0
11/11/2015	1.86	2.40	37.27	3.76	59.38	3.10	48.1
11/12/2015	1.94	3.60	58.19	4.00	63.68	3.20	51.7
11/13/2015	1.99	4.00	66.38	4.16	66.52	4.00	66.4
11/14/2015	1.80			4.00	63.21		
11/15/2015	1.74			4.00	63.21		
11/16/2015	1.68	4.40	61.76	4.00	63.21	6.25	87.7
11/17/2015	2.00	4.40	73.30	5.12	79.07	4.35	72.5
11/18/2015	1.96	3.60	58.76	5.04	76.73	4.50	73.5
11/19/2015	1.97	4.40	72.40	5.12	77.59	3.70	60.9
11/20/2015	1.87	3.20	49.83	4.72	70.24	4.90	76.3
11/21/2015	1.80			4.96	74.64		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC	TELEPHONE		DATE		
			2317750181 124		2015	12	19
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

11/22/2015	1.69			4.96	74.64		
11/23/2015	1.69	10.00	141.04	4.96	74.64	9.58	135.1
11/24/2015	1.85	4.00	61.62	3.60	55.31	4.88	75.2
11/25/2015	1.89	4.00	63.07	3.50	53.73	4.70	74.1
11/26/2015	1.78	2.40	35.64	3.33	50.61	5.30	78.7
11/27/2015	1.96	4.40	71.83	3.80	58.10	5.30	86.5
11/28/2015	1.67			3.20	44.37		
11/29/2015	1.54			3.20	44.37		
11/30/2015	1.66	3.20	44.37	3.20	44.37	4.30	59.6

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2 mg/L	53 lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2015	66.7						
11/2/2015	66.7	0.05	0.67	0.25	3.34		
11/3/2015	58.7	0.03	0.49	0.20	3.28	<2.00	
11/4/2015	54.5	0.05	0.81	0.16	2.60		<50.000
11/5/2015	51.5	0.04	0.66	0.20	3.28		
11/6/2015	50.7	0.05	0.82	0.18	2.94		
11/7/2015	51.4						<50.000
11/8/2015	51.4						
11/9/2015	51.4	0.04	0.53	0.10	1.34		
11/10/2015	60.4	0.04	0.62	0.10	1.55		
11/11/2015	65.3	0.04	0.62	0.07	1.09		
11/12/2015	70.3	0.04	0.65	0.09	1.46		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2015 12 19 YEAR MO DAY
--	---	--	--	---

Permit Number: MI0020257 v5.0

DMR Version: 1

Generated: 3/29/2021 8:06 PM

Page 2 of 5

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

11/13/2015	72.2	0.12	1.99	0.15	2.49		<50.000
11/14/2015	74.2						
11/15/2015	74.2						
11/16/2015	74.2	0.05	0.70	0.18	2.53		
11/17/2015	83.6	0.10	1.67	0.14	2.33		
11/18/2015	84.2	0.06	0.98	0.16	2.61		<50.000
11/19/2015	84.3	0.10	1.65	0.18	2.96		
11/20/2015	87.9	0.06	0.93	0.16	2.49		
11/21/2015	89.9						
11/22/2015	89.9						
11/23/2015	89.9	0.07	0.99	0.15	2.12		
11/24/2015	74.8	0.06	0.92	0.13	2.00		<50.000
11/25/2015	74.7	0.09	1.42	0.20	3.15		
11/26/2015	74.9	0.06	0.89				
11/27/2015	72.1	0.04	0.65				
11/28/2015	88.3						
11/29/2015	88.3						
11/30/2015	88.3	0.04	0.56	0.18	2.50		

Set: 3 of 4

Parameter	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)
Mon. Loc.	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2015							
11/2/2015							
11/3/2015	1.10	<0.2	0.9	<0.2	<0.2		
11/4/2015						0	0
11/5/2015							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 	DATE 2015 12 19 YEAR MO DAY
--	---	---	---	----------------------------	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

11/6/2015							
11/7/2015							
11/8/2015							
11/9/2015							
11/10/2015							
11/11/2015							
11/12/2015							
11/13/2015							
11/14/2015							
11/15/2015							
11/16/2015							
11/17/2015							
11/18/2015							
11/19/2015							
11/20/2015							
11/21/2015							
11/22/2015							
11/23/2015							
11/24/2015							
11/25/2015							
11/26/2015							
11/27/2015							
11/28/2015							
11/29/2015							
11/30/2015							

Set: 4 of 4

Parameter	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen		
Mon. Loc.	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	400 #/100mL	(report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 12 YEAR	DATE 19 MO DAY
--	---	--	--	------------------------------	-------------------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily		
11/1/2015	0.0						
11/2/2015	12.6	35	7.38	7.4	8.9		
11/3/2015	7.1	6	7.29	7.3	8.9		
11/4/2015	6.8	5	6.99	7.0	8.8		
11/5/2015	6.8	5	7.38	7.4	8.7		
11/6/2015	8.4	60	7.44	7.4	8.5		
11/7/2015	5.1						
11/8/2015	5.1						
11/9/2015	5.1	2	7.36	7.4	9.2		
11/10/2015	5.9	5	7.35	7.4	9.2		
11/11/2015	1.7	5	7.38	7.4	9.1		
11/12/2015	1.4	14	7.36	7.4	8.9		
11/13/2015	1.1	5	7	7.0	8.8		
11/14/2015	0.8						
11/15/2015	0.8						
11/16/2015	0.8	4	7.16	7.2	9.1		
11/17/2015	0.6	0.01	7.27	7.3	9.0		
11/18/2015	0.6	2	7.17	7.2	8.8		
11/19/2015	0.8	5	7.11	7.1	8.6		
11/20/2015	0.6	1	7.21	7.2	9.0		
11/21/2015	0.7						
11/22/2015	0.7						
11/23/2015	0.7	1	7.08	7.1	9.4		
11/24/2015	1.5	0.01	7.05	7.1	9.3		
11/25/2015	5.3	6	7.04	7.0	9.2		
11/26/2015		1	7.1	7.1	9.2		
11/27/2015		2	7.2	7.2	9.4		
11/28/2015							
11/29/2015							
11/30/2015		68	6.91	6.9	9.9		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2015	12	19
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 11/1/2015 - 11/30/2015
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2015	12	19
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY