

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	30 mg/L	800 lbs/day	(report) mg/L	(report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
11/1/2017	2.06	8.00	137.33	9.75	163.69	3.30	56.6
11/2/2017	2.10	6.40	112.03	10.35	174.27	3.30	57.8
11/3/2017	2.14	12.00	213.87	11.47	191.39	6.30	112.3
11/4/2017	1.96			10.27	169.33		
11/5/2017	1.78			10.27	169.33		
11/6/2017	1.75	11.33	165.53	10.27	169.33	4.20	61.4
11/7/2017	2.07	11.00	189.68	10.20	167.20	3.00	51.7
11/8/2017	2.07	11.00	190.24	9.60	155.59	<3.000	51.9
11/9/2017	1.98	12.00	197.62	8.47	135.26	3.30	54.3
11/10/2017	2.07	6.00	103.61	7.53	122.41	3.90	67.3
11/11/2017	1.91			7.40	120.21		
11/12/2017	1.59			7.40	120.21		
11/13/2017	1.69	11.00	154.86	7.40	120.21	4.60	64.8
11/14/2017	1.97	8.00	131.64	6.53	108.83	3.60	59.2
11/15/2017	1.99	5.33	88.59	6.23	105.23	3.90	64.8
11/16/2017	2.18	7.33	133.33	6.57	110.21	4.20	76.4
11/17/2017	2.08	5.33	92.62	6.40	103.13	4.00	69.5
11/18/2017	2.05			6.33	98.19		
11/19/2017	1.76			6.33	98.19		
11/20/2017	1.76	6.67	97.96	6.33	98.19	4.93	72.4
11/21/2017	2.10	6.50	113.63	8.50	127.51	5.23	91.4

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2017 12 15 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

11/22/2017	1.94	7.00	113.50	8.10	119.43	6.30	102.2
11/23/2017	1.81	6.50	97.96	7.70	113.82	5.10	76.9
11/24/2017	1.63	5.00	67.90	7.40	110.96	3.20	43.5
11/25/2017	1.67			8.00	121.73		
11/26/2017	1.53			8.00	121.73		
11/27/2017	1.68	17.50	244.57	8.00	121.73	11.10	155.1
11/28/2017	1.95	4.50	73.21	4.83	80.78	7.45	121.2
11/29/2017	2.05	5.00	85.47	5.00	84.57	3.30	56.4
11/30/2017	2.01	5.00	83.68	5.00	83.68	3.30	55.2

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	2 mg/L	53 lbs/day	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2017	68.0	0.07	2.93	1.20	0.15	2.58	
11/2/2017	67.0	0.18	5.08	3.15	0.18	3.15	
11/3/2017	66.3	0.35	6.13	6.24	0.20	3.56	
11/4/2017	57.3		6.26				
11/5/2017	57.3		6.26				
11/6/2017	57.3	0.03	6.26	0.44	0.19	2.78	
11/7/2017	58.0	0.21	6.28	3.62	0.19	3.28	
11/8/2017	59.5	0.69	6.28	11.93	0.15	2.59	
11/9/2017	62.1	0.51	4.96	8.40	0.16	2.64	
11/10/2017	66.5	0.40	5.36	6.91	0.13	2.25	
11/11/2017	66.9		5.50				
11/12/2017	66.9		5.50				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2017 12 15 YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

11/13/2017	66.9	0.04	5.50	0.56	0.12	1.69	
11/14/2017	68.5	0.22	5.51	3.62	0.10	1.65	
11/15/2017	74.9	0.32	5.48	5.32	0.15	2.49	
11/16/2017	82.4	0.57	4.91	10.37	0.15	2.73	
11/17/2017	82.5	0.44	3.37	7.65	0.14	2.43	
11/18/2017	77.3		1.98				
11/19/2017	77.3		1.98				
11/20/2017	77.3	0.04	1.98	0.59	0.15	2.20	<2.00
11/21/2017	93.8	0.20	2.09	3.50	0.16	2.80	
11/22/2017	99.8	0.15	1.62	2.43	0.14	2.27	
11/23/2017	90.6	0.18	1.40	2.71	0.13	1.96	
11/24/2017	86.3	0.05	1.60	0.68	0.12	1.63	
11/25/2017	97.0		1.83				
11/26/2017	97.0		1.83				
11/27/2017	92.3	0.08	1.83	1.12	0.20	2.80	
11/28/2017	92.3	0.07	2.06	1.14	0.16	2.60	
11/29/2017	85.1	0.08	2.52	1.37	0.13	2.22	
11/30/2017	94.7	0.22		3.68	0.12	2.01	

Set: 3 of 4

Parameter	Total Copper	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)
Mon. Loc.	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)
Limit	(report) ug/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
11/1/2017							
11/2/2017	<50.000						
11/3/2017							
11/4/2017							
11/5/2017							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2017	12	15
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

11/6/2017	<50.000						
11/7/2017						0	0
11/8/2017							
11/9/2017							
11/10/2017							
11/11/2017							
11/12/2017							
11/13/2017							
11/14/2017							
11/15/2017	<50.000						
11/16/2017							
11/17/2017							
11/18/2017	<50.000						
11/19/2017							
11/20/2017		1.76	1.49	0.649	<0.50		
11/21/2017							
11/22/2017							
11/23/2017							
11/24/2017							
11/25/2017							
11/26/2017							
11/27/2017							
11/28/2017							
11/29/2017							
11/30/2017							

Set: 4 of 4

Parameter	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen		
Mon. Loc.	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	400 #/100mL	(report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 124 NUMBER	DATE 2017 12 15 YEAR MO DAY
--	---	--	--	---------------------------------	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily		
11/1/2017	0.0	10	7.13	7.1	8.6		
11/2/2017	19.3	27	7.03	7.0	8.2		
11/3/2017	17.2	31	6.86	6.9	8.1		
11/4/2017	13.1						
11/5/2017	13.1						
11/6/2017	13.1	10	7.24	7.2	8.9		
11/7/2017	11.8	19	7.15	7.2	8.8		
11/8/2017	11.4	17	7.26	7.3	8.8		
11/9/2017	11.8	15	7.28	7.3	8.5		
11/10/2017	10.9	8	7.27	7.3	9.0		
11/11/2017	13.3						
11/12/2017	13.3						
11/13/2017	13.3	6	7.16	7.2	9.2		
11/14/2017	11.6	16	7.15	7.2	8.8		
11/15/2017	12.1	20	7.26	7.3	8.6		
11/16/2017	13.9	10	7.13	7.1	8.6		
11/17/2017	20.2	22	7.15	7.2	8.8		
11/18/2017	18.2						
11/19/2017	18.2						
11/20/2017	18.2	3	7.16	7.2	9.3		
11/21/2017	19.3	20	7.12	7.1	8.8		
11/22/2017	17.4	40	7.15	7.2	9.0		
11/23/2017	12.6	64	7.15	7.15	8.9		
11/24/2017	10.1	13	7.03	7.03	9.2		
11/25/2017	9.5						
11/26/2017							
11/27/2017		4	6.98	7.0	9.6		
11/28/2017		12	7.06	7.1	9.3		
11/29/2017		8	7.3	7.3	9.3		
11/30/2017		21	6.94	6.9	9.0		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER 	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE 2317750181 124	DATE 2017 12 15			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 11/1/2017 - 11/30/2017
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

- **Set 1 DMR Value Comments:**
- Date: 11/27/2017 12:00:00 AM, Column 6 Comment: Final sample pump malfunction.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2017	12	15
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER		YEAR	MO