

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 4

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	34 mg/L	910 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
12/1/2017	1.90	3.00	47.43	5.16	81.96	3.70	58.5
12/2/2017	1.88			5.84	92.86		
12/3/2017	1.52			5.84	92.86		
12/4/2017	1.63	6.00	81.75	5.84	92.86	3.80	51.8
12/5/2017	2.10	5.20	91.15	5.76	91.22	3.80	66.6
12/6/2017	1.99	6.00	99.66	5.84	91.07	4.40	73.1
12/7/2017	1.92	5.60	89.83	5.68	87.69	4.65	74.6
12/8/2017	1.91	6.40	101.92	5.60	86.72	5.30	84.4
12/9/2017	1.92			5.44	84.69		
12/10/2017	1.59			5.44	84.69		
12/11/2017	1.57	5.60	73.53	5.44	84.69	4.30	56.5
12/12/2017	1.94	5.60	90.43	5.52	86.77	4.05	65.4
12/13/2017	1.91	5.20	82.76	5.20	81.47	5.55	88.3
12/14/2017	1.96	5.20	84.95	5.04	79.30	6.45	105.4
12/15/2017	1.97	5.60	91.76	4.80	74.23	7.40	121.3
12/16/2017	1.76			4.32	64.83		
12/17/2017	1.50			4.32	64.83		
12/18/2017	1.68	6.00	83.95	4.32	64.83	4.60	64.4
12/19/2017	1.92	4.00	63.92	3.60	53.60	4.78	76.4
12/20/2017	1.96	4.40	71.91	3.44	48.03	5.50	89.9
12/21/2017	1.79	4.00	59.59	3.18	41.65	6.00	89.4

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2018	01	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

12/22/2017	1.68	3.20	44.80	2.94	36.83	6.80	95.2
12/23/2017	1.56			2.86	35.13		
12/24/2017	1.43			2.86	35.13		
12/25/2017	1.39	2.40	27.76	2.86	35.13	2.70	31.2
12/26/2017	1.35	3.20	36.09	2.98	36.97	<3.000	<33.833
12/27/2017	1.54	3.12	40.02	2.91	37.27	<3.000	<38.482
12/28/2017	1.52	2.80	35.49	2.80	35.89	<3.000	<38.025
12/29/2017	1.55	2.80	36.29	2.80	36.29	<3.000	<38.880
12/30/2017	1.53						
12/31/2017	1.56						

Set: 2 of 4

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) ug/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2017	64.9	0.12	1.90	0.15	2.37		
12/2/2017	70.1						
12/3/2017	70.1						
12/4/2017	70.1	0.03	0.41	0.17	2.32		
12/5/2017	71.0	0.07	1.23	0.16	2.80		
12/6/2017	70.8	0.14	2.33	0.17	2.82		<50.000
12/7/2017	73.8	0.09	1.44	0.18	2.89		
12/8/2017	80.0	0.07	1.12	0.17	2.71		
12/9/2017	87.4						
12/10/2017	87.4						
12/11/2017	87.4	0.03	0.39	0.11	1.44		
12/12/2017	88.9	0.02	0.32	0.10	1.62		<50.000

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2018 01 18 YEAR MO DAY
--	---	--	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

12/13/2017	91.1	0.13	2.07	0.12	1.91		
12/14/2017	91.5	0.38	6.21	0.13	2.12		
12/15/2017	88.3	0.46	7.54	0.11	1.80		
12/16/2017	83.0						<50.000
12/17/2017	83.0						
12/18/2017	83.0	0.02	0.28	0.12	1.68		
12/19/2017	76.4	0.10	1.60	0.14	2.24	<2.00	
12/20/2017	76.4	0.30	4.90	0.13	2.13		
12/21/2017	71.9	0.13	1.94	0.13	1.94		<50.000
12/22/2017	63.2	0.15	2.10	0.13	1.82		
12/23/2017	31.2						
12/24/2017	31.2						
12/25/2017	31.2	0.06	0.69	0.12	1.39		
12/26/2017	37.3	0.02	0.23	0.11	1.24		
12/27/2017	37.3	0.07	0.90	0.13	1.67		
12/28/2017	37.3	0.13	1.65	0.14	1.78		
12/29/2017	37.3	0.12	1.56	0.15	1.94		
12/30/2017							
12/31/2017							

Set: 3 of 4

Parameter	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Acute Toxicity (ceriodaphnia dubia)	Chronic Toxicity (ceriodaphnia dubia)	Fecal Coliform
Mon. Loc.	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) TUA	(report) TUC	400 #/100mL
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean
12/1/2017	*G	*G	*G	*G	*G	*G	0.0
12/2/2017							11.9
12/3/2017							11.9

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWC Cadillac Financing Auth. GWC SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	DATE 2018 01 18 YEAR MO DAY
--	---	---	---	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

12/4/2017							11.9
12/5/2017							11.9
12/6/2017							9.8
12/7/2017							8.4
12/8/2017							7.5
12/9/2017							8.1
12/10/2017							8.1
12/11/2017							8.1
12/12/2017							9.0
12/13/2017							9.9
12/14/2017							8.0
12/15/2017							7.1
12/16/2017							6.0
12/17/2017							6.0
12/18/2017							6.0
12/19/2017							4.4
12/20/2017							0.4
12/21/2017							0.3
12/22/2017							0.3
12/23/2017							0.3
12/24/2017							0.3
12/25/2017							0.3
12/26/2017							
12/27/2017							
12/28/2017							
12/29/2017							
12/30/2017							
12/31/2017							

Set: 4 of 4

Parameter	Fecal Coliform	Total Suspended	pH	pH	Dissolved Oxygen		
-----------	----------------	-----------------	----	----	------------------	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2018	01	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

		Solids Minimum % Removal					
Mon. Loc.	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)		
Limit	(report) #/100mL	(report) %	6.5 SU	9.0 SU	5.0 mg/L		
Stat. Base	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily		
12/1/2017	14	98.37	7.07	7.1	9.2		
12/2/2017							
12/3/2017							
12/4/2017	3	96.809	7.02	7.0	9.5		
12/5/2017	16	96.486	6.94	6.9	9.0		
12/6/2017	26	96.667	7.03	7.0	9.2		
12/7/2017	16	97.705	7.12	7.1	9.4		
12/8/2017	12	97.714	7.16	7.2	9.3		
12/9/2017							
12/10/2017							
12/11/2017	3	97.308	7.05	7.1	9.8		
12/12/2017	6	96.744	7.13	7.1	9.8		
12/13/2017	12	96.579	7.14	7.1	9.6		
12/14/2017	9	97.451	7.13	7.1	9.4		
12/15/2017	18	97.255	7.15	7.2	9.2		
12/16/2017							
12/17/2017							
12/18/2017	5	97	6.76	6.8	9.9		
12/19/2017	10	97.436	6.99	7.0	9.4		
12/20/2017	4	97.925	7.11	7.1	9.4		
12/21/2017	5	98.438	6.83	6.8	9.6		
12/22/2017	8	98.545	7.36	7.4	9.4		
12/23/2017							
12/24/2017							
12/25/2017	1	98.824	7.02	7.0	10.2		
12/26/2017	0	98.462	7.54	7.5	10.7		
12/27/2017	1	98.34	7.04	7.0	10.8		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER 124 YEAR 2018	DATE 01 MO 18 DAY
--	---	---	---	---	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.1
DMR Period: 12/1/2017 - 12/31/2017
DMR Version: 1

12/28/2017	2	98.704	6.89	6.9	10.6		
12/29/2017	6.5	98.939	7.38	7.4	10.5		
12/30/2017							
12/31/2017							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124	2018	01	18	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY