

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(report) MGD	45 mg/L	1200 lbs/day	(report) mg/L	(report) lbs/day	34 mg/L	910 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
12/1/2020	1.74	9.00	130.70	9.40	133.71	5.65	82.1
12/2/2020	1.67	7.50	104.14	9.30	132.38	6.80	94.4
12/3/2020	1.79	9.00	134.15	10.00	143.38	7.70	114.8
12/4/2020	1.71	13.00	185.84	10.20	145.30	9.40	134.4
12/5/2020	1.63			9.30	131.76		
12/6/2020	1.52			9.30	131.76		
12/7/2020	1.60	8.50	113.72	9.30	131.76	14.35	192.0
12/8/2020	1.75	8.50	124.04	9.70	134.78	10.00	145.9
12/9/2020	1.74	11.00	159.16	9.70	134.94	12.90	186.7
12/10/2020	1.72	10.00	143.75	9.40	129.68	17.10	245.8
12/11/2020	1.67	8.50	118.14	8.90	122.59	15.20	211.3
12/12/2020	1.56			9.40	130.46		
12/13/2020	1.37			9.40	130.46		
12/14/2020	1.47	10.50	128.80	9.40	130.46	10.85	133.1
12/15/2020	1.76	8.50	124.85	9.10	126.76	9.10	133.7
12/16/2020	1.68	9.50	132.84	9.30	127.63	10.00	139.8
12/17/2020	1.73	7.50	108.32	8.90	120.68	11.40	164.6
12/18/2020	1.72	11.00	157.47	8.20	109.30	10.90	156.0
12/19/2020	1.60			7.10	89.14		
12/20/2020	1.50			7.10	89.14		
12/21/2020	1.47	9.00	110.33	7.10	89.14	10.40	127.5

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2021	01	14
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/22/2020	1.63	9.50	129.19	8.20	97.32	10.70	145.5
12/23/2020	1.57	7.50	98.10	9.37	105.93	9.40	123.0
12/24/2020	1.54	4.00	51.43	11.20	123.64	10.40	133.7
12/25/2020	1.24	5.50	56.67	14.00	153.44	9.10	93.8
12/26/2020	1.17			16.13	177.63		
12/27/2020	1.29			15.50	170.03		
12/28/2020	1.25	14.50	151.23	15.50	170.03	24.00	250.3
12/29/2020	1.35	15.33	172.24	16.00	179.43	10.30	115.7
12/30/2020	1.34	16.67	186.62	17.34	193.53	8.80	98.5
12/31/2020	1.34	18.00	200.45			15.10	168.15

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) mg/L	(report) lbs/day	(report) mg/L	(report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2020	123.5	0.30	4.36	0.28	4.07	8.1	0.118
12/2/2020	136.3	0.30	4.17	0.25	3.47		
12/3/2020	154.7	0.30	4.47	0.20	2.98		
12/4/2020	181.0	0.30	4.29	0.22	3.15		
12/5/2020	196.3						
12/6/2020	196.3						
12/7/2020	196.3	0.30	4.01	0.24	3.21	8.5	0.114
12/8/2020	184.6	0.30	4.38	0.19	2.77		
12/9/2020	182.1	0.30	4.34	0.20	2.89		
12/10/2020	172.7	0.43	6.18	0.16	2.30		
12/11/2020	156.5	0.30	4.17	0.16	2.22		
12/12/2020	145.5						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2021	01	14
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/13/2020	145.5						
12/14/2020	145.5	0.30	3.68	0.25	3.07		
12/15/2020	144.3	0.30	4.41	0.22	3.23		
12/16/2020	146.7	0.30	4.20	0.19	2.66		
12/17/2020	143.3	0.30	4.33	0.21	3.03		
12/18/2020	137.1	0.30	4.30	0.16	2.29	6.80	0.10
12/19/2020	124.7						
12/20/2020	124.7					6.7	0.084
12/21/2020	124.7	0.30	3.68	0.19	2.33		
12/22/2020	149.3	0.74	10.06	0.17	2.31		
12/23/2020	143.3	0.30	3.92	0.16	2.09	9.1	0.119
12/24/2020	138.4	0.30	3.86	0.14	1.80		
12/25/2020	145.3	0.30	3.09	0.14	1.44		
12/26/2020	158.2						
12/27/2020	156.0						
12/28/2020	171.7	0.59	6.15	0.29	3.03	17.5	0.183
12/29/2020	156.0	0.30	3.37	0.34	3.82		
12/30/2020	166.1	0.30	3.36	0.31	3.47		
12/31/2020		0.30	3.34	0.45	5.01		

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(report) ng/L	(report) lbs/day	(report) ng/L	(report) ng/L	(report) ng/L	(report) ng/L	(report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2020	*G	*G	*G	*G	*G	*G	<5.000
12/2/2020							
12/3/2020							
12/4/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2021 01 14 YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/5/2020							
12/6/2020							
12/7/2020							<5.000
12/8/2020							
12/9/2020							
12/10/2020							
12/11/2020							
12/12/2020							
12/13/2020							
12/14/2020							
12/15/2020							
12/16/2020							
12/17/2020							
12/18/2020							<5.000
12/19/2020							
12/20/2020							<5.000
12/21/2020							
12/22/2020							
12/23/2020							<5.000
12/24/2020							
12/25/2020							
12/26/2020							
12/27/2020							
12/28/2020							<5.000
12/29/2020							
12/30/2020							
12/31/2020							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2021	01	14
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(report) lbs/day	(report) ug/L	(report) lbs/day	(report) ng/L	(report) lbs/day	(report) ng/L	(report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2020	<0.073	<2.000	<0.029	*G	*G	*G	*G
12/2/2020							
12/3/2020							
12/4/2020							
12/5/2020							
12/6/2020							
12/7/2020	<0.067	<2.000	<0.027				
12/8/2020							
12/9/2020							
12/10/2020							
12/11/2020							
12/12/2020							
12/13/2020							
12/14/2020							
12/15/2020							
12/16/2020							
12/17/2020							
12/18/2020	<0.072	<2.000	<0.029				
12/19/2020							
12/20/2020	<0.063	<2.000	<0.025				
12/21/2020							
12/22/2020							
12/23/2020	<0.065	<2.000	<0.026				
12/24/2020							
12/25/2020							
12/26/2020							
12/27/2020							
12/28/2020	<0.052	<2.000	<0.021				
12/29/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE 2021 01 14
--	---	---	---	---------------------------------	------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/30/2020							
12/31/2020							

Set: 5 of 6

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis (2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL	(report) #/100mL	(report) %	6.5 SU	9.0 SU	5.0 mg/L	(report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
12/1/2020	1.2	3	95.313	7.19	7.2	9.5	
12/2/2020	1.0	1	95.739	7.09	7.1	9.4	
12/3/2020	1.0	1	95.673	7.38	7.4	9.4	
12/4/2020	1.3	1	94.298	7.13	7.1	9.1	
12/5/2020	1.3						
12/6/2020	1.3						
12/7/2020	1.3	1	95.833	7.13	7.1	9.3	
12/8/2020	1.3	1	97.204	7.05	7.1	8.9	
12/9/2020	1.6	1	96.839	7.42	7.4	8.9	
12/10/2020	1.6	3.1	95.902	7.15	7.2	8.8	<4.500
12/11/2020	1.3	1	96.731	7.19	7.2	8.6	
12/12/2020	1.6						
12/13/2020	1.6						
12/14/2020	1.6	1	96.14	6.86	6.9	9.5	
12/15/2020	1.6	3.1	96.458	6.92	6.9	9.5	
12/16/2020	1.3	1	95.602	7.1	7.1	9.3	
12/17/2020	1.3	1	96.25	7.22	7.2	9.2	
12/18/2020	1.3	3.1	95.565	7.31	7.3	9.2	
12/19/2020	1.0						

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE 2021 01 14 YEAR MO DAY
--	---	---	--	---

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 3/21/2021 3:55 PM

Page 6 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/20/2020	1.0						
12/21/2020	1.0	1	97.039	7.29	7.3	9.1	
12/22/2020	4.8	1	96.455	7.16	7.2	8.9	
12/23/2020	22.6	1	97.07	7.12	7.1	8.9	
12/24/2020	107.2	1	96.296	7.18	7.2	8.7	
12/25/2020	509.3	1	97.708	7.06	7.1	9.3	
12/26/2020							
12/27/2020							
12/28/2020		2,419.60	94.508	6.97	7.0	9.6	
12/29/2020		2,419.60	95.023	7	7.0	9.9	
12/30/2020		2,419.60	91.986	7.17	7.2	9.7	
12/31/2020		2,419.60	92.241	7.1	7.1	9.4	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(report) lbs/day						
Stat. Base	Maximum Daily						
12/1/2020							
12/2/2020							
12/3/2020							
12/4/2020							
12/5/2020							
12/6/2020							
12/7/2020							
12/8/2020							
12/9/2020							
12/10/2020	<0.0646895						
12/11/2020							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2021	01	14
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2020 - 12/31/2020
DMR Version: 1

12/12/2020							
12/13/2020							
12/14/2020							
12/15/2020							
12/16/2020							
12/17/2020							
12/18/2020							
12/19/2020							
12/20/2020							
12/21/2020							
12/22/2020							
12/23/2020							
12/24/2020							
12/25/2020							
12/26/2020							
12/27/2020							
12/28/2020							
12/29/2020							
12/30/2020							
12/31/2020							

DMR Instructions:

DMR Comments: (none)

Set 5 DMR Value Comments:

- Date: 12/25/2020 12:00:00 AM, Column 1 Comment: Low flow upset due to holiday industrial shutdown

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124		2021	01	14
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY