

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 1/1/2020 - 1/31/2020
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.69	2.01	MGD	*****	*****	*****			Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	52.12	71.98	lbs/day	*****	3.63	4.72	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	121.37	247.77	lbs/day	*****	8.38	25.8	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	670 Maximum Monthly Average	910 Maximum 7-Day Average		*****	25 Maximum Monthly Average	34 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	4.28	5.02	lbs/day	*****	0.3	0.3	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	99 Maximum Monthly Average	***** Maximum Daily		*****	3.7 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2020	02	18
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 1/1/2020 - 1/31/2020
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.07	4.19	lbs/day	*****	0.144	0.25	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	***** Maximum Daily		*****	0.5 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.131	0.167	lbs/day	*****	9.08	11.2	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<0.00000662	<0.00000662	lbs/day	*****	<0.50	<0.50	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	<0.0000147	*****	lbs/day	*****	<0.8975	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0716	<0.074	lbs/day	*****	<5.0	<5.0	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCUCadillac Financing Auth. GWCUSIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
TYPED OR PRINTED			2317750181 124	2020 02 18
			AREA CODE NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 1/1/2020 - 1/31/2020
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0283	<0.030	lbs/day	*****	<2.0	<2.0	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	***** Maximum Daily		*****	5.7 Maximum Monthly Average	***** Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*G	*G	lbs/day	*****	*G	*G	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	***** Maximum Monthly Average	***** Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****		*****	1.20	1.8	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****		89.88	*****	89.88	%		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124	2020	02	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 1/1/2020 - 1/31/2020
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	***** Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		6.61	*****	7.38	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		9.79	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		5.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<0.0675	<0.0675	lbs/day	*****	<4.5	<4.5	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	***** Maximum Daily		*****	31 Maximum Monthly Average	***** Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2020	02	18
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY