

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 5/1/2016 - 5/31/2016
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.89	2.19	MGD	*****	*****	*****			Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	***** Maximum Monthly Average	***** Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	56.95	81.96	lbs/day	*****	3.53	5.2	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	530 Maximum Monthly Average	800 Maximum 7-Day Average		*****	20 Maximum Monthly Average	30 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	90.47	135.49	lbs/day	*****	5.54	8.1	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	190 Maximum Monthly Average	270 Maximum 7-Day Average		*****	7 Maximum Monthly Average	10 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	6.84	31.61	lbs/day	*****	0.41	1.89	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	24 Maximum Monthly Average	53 Maximum 7-Day Average		*****	0.9 Maximum Monthly Average	2 Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCUCadillac Financing Auth. GWCUSIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
TYPED OR PRINTED			2317750181 124	2016 06 15
			AREA CODE NUMBER	YEAR MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 5/1/2016 - 5/31/2016
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1)	SAMPLE MEASUREMENT	2.66	3.82	lbs/day	*****	0.165	0.25	mg/L		5X Weekly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	13 Maximum Monthly Average	***** Maximum Daily		*****	0.5 Maximum Monthly Average	***** Maximum Daily			5X Weekly	24-Hr Composite
Available Cyanide (01257) Final Effluent (1)	SAMPLE MEASUREMENT	0.029	*****	lbs/day	<2.0	*****	<2.0	ug/L		Monthly	Grab
Lab ID:	PERMIT REQUIREMENT	0.16 Maximum Monthly	*****		5.9 Maximum Monthly Average	*****	***** Maximum Daily			Monthly	Grab
Total Copper (01042) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****		*****	*****	<50.0	ug/L		Quarterly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	*****	***** Maximum Daily			Quarterly	24-Hr Composite
Total Mercury (71900) Final Effluent (1)	SAMPLE MEASUREMENT	0.000010	*****	lbs/day	0.6	*****	0.6	ng/L		Quarterly	Calculation
Lab ID:	PERMIT REQUIREMENT	***** Maximum Monthly Average	*****		***** Maximum Monthly Average	*****	***** Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X)	SAMPLE MEASUREMENT	0.0000096	*****	lbs/day	*****	0.675	*****	ng/L		Quarterly	Grab
Lab ID:	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2016	06	15
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 5/1/2016 - 5/31/2016
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Acute Toxicity (ceriodaphnia dubia) (61425) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		*****	*****	0	TUA		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	***** Maximum Daily			Quarterly	24-Hr Composite
Chronic Toxicity (ceriodaphnia dubia) (03599) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		*****	0	0	TUC		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	1.1 Maximum Monthly Average	***** Maximum Daily			Quarterly	24-Hr Composite
Fecal Coliform (74055) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		*****	4.14	14	#/100mL		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		7.1	*****	7.69	SU		Daily	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			Daily	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****		7.33	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 Minimum Daily	*****	*****			5X Weekly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124		2016	06	15
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v5.0
DMR Period: 5/1/2016 - 5/31/2016
DMR Version: 1

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124	2016	06	15	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY