

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	45 mg/L	1200 lbs/day	(Report) mg/L	(Report) lbs/day	17 mg/L	480 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
10/1/2022	1.840						
10/2/2022	1.575						
10/3/2022	1.557			10.00	129.820	6.10	
10/4/2022	1.900			12.00	190.170	6.08	
10/5/2022	1.922			9.50	152.304	7.50	
10/6/2022	1.918			13.50	215.931	6.30	
10/7/2022	1.934	11.200	173.132	11.00	177.436	6.60	100.602
10/8/2022	1.811	11.200	173.132				100.602
10/9/2022	1.676	11.200	173.132				100.602
10/10/2022	1.638	12.300	189.525	15.50	211.785	4.68	97.553
10/11/2022	1.923	13.400	207.616	17.50	280.626	6.05	97.686
10/12/2022	1.971	15.100	236.340	18.00	295.920	7.40	97.969
10/13/2022	1.980	14.800	232.784	12.00	198.152	9.50	109.190
10/14/2022	1.873	16.800	262.895	21.00	327.993	11.20	122.884
10/15/2022	1.838	16.800	262.895				122.884
10/16/2022	1.620	16.800	262.895				122.884
10/17/2022	1.653	16.500	259.136	14.00	192.986	5.45	125.120
10/18/2022	1.879	15.400	240.619	12.00	188.042	6.35	125.618
10/19/2022	2.055	14.000	219.132	11.00	188.483	6.60	123.905
10/20/2022	1.992	14.200	222.686	13.00	215.924	5.60	111.133
10/21/2022	1.938	12.000	189.415	10.00	161.638	5.80	94.897

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/22/2022	1.848	12.000	189.415				94.897
10/23/2022	1.588	12.000	189.415				94.897
10/24/2022	1.698	11.200	179.148	10.00	141.654	4.30	92.054
10/25/2022	1.940	11.000	177.129	11.00	177.948	4.60	87.036
10/26/2022	1.906	10.400	164.869	8.00	127.182	6.30	84.449
10/27/2022	1.883	9.400	146.816	8.00	125.659	5.00	81.554
10/28/2022	1.725	9.200	140.381	9.00	129.460	5.90	79.777
10/29/2022	1.627	9.200	140.381				79.777
10/30/2022	1.450	9.200	140.381				79.777
10/31/2022	1.651	8.000	123.067	4.00	55.088	4.90	81.092

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	2.8 mg/L	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
10/1/2022							
10/2/2022							
10/3/2022	79.190	<0.30	<3.895	0.225	2.921	6.1	0.0792
10/4/2022	96.353	<0.30	<4.754	0.200	3.169		
10/5/2022	120.240	<0.30	<4.810	0.187	2.998		
10/6/2022	100.768	<0.30	<4.798	0.244	3.903		
10/7/2022	106.462	<0.30	<4.839	0.234	3.775		
10/8/2022							
10/9/2022							
10/10/2022	63.945	<0.30	<4.099	0.251	3.430		
10/11/2022	97.016	<0.30	<4.811	0.323	5.180	5.8	0.0930
10/12/2022	121.656	<0.30	<4.932	0.331	5.442		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE NUMBER	DATE YEAR MO DAY
--	---	--	--	-----------------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/13/2022	156.871	<0.30	<4.954	0.337	5.565		
10/14/2022	174.930	<0.30	<4.686	0.277	4.326		
10/15/2022							
10/16/2022						5.4	0.0730
10/17/2022	75.127	<0.30	<4.135	0.385	5.307		
10/18/2022	99.506	<0.30	<4.701	0.293	4.591		
10/19/2022	113.090	<0.30	<5.140	0.293	5.021	5	0.0857
10/20/2022	93.013	<0.30	<4.983	0.278	4.617		
10/21/2022	93.750	<0.30	<4.849	0.253	4.089		
10/22/2022							
10/23/2022							
10/24/2022	60.911	<0.30	<4.250	0.321	4.547		
10/25/2022	74.414	<0.30	<4.853	0.362	5.856		
10/26/2022	100.156	<0.30	<4.769	0.312	4.960		
10/27/2022	78.537	<0.30	<4.712	0.307	4.822	<5	<0.0785
10/28/2022	84.868	<0.30	<4.315	0.276	3.970		
10/29/2022							
10/30/2022							
10/31/2022	67.483	<0.30	<4.132	0.254	3.498		

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
10/1/2022							
10/2/2022							
10/3/2022							<5
10/4/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124	DATE <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> </tr> <tr> <td style="text-align: center; font-weight: bold;">YEAR</td> <td style="text-align: center; font-weight: bold;">MO</td> <td style="text-align: center; font-weight: bold;">DAY</td> </tr> </table>				YEAR	MO	DAY	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> <td style="border: 1px solid black; width: 20%; height: 30px;"></td> </tr> <tr> <td style="text-align: center; font-weight: bold;">AREA CODE</td> <td style="text-align: center; font-weight: bold;">NUMBER</td> <td></td> </tr> </table>				AREA CODE	NUMBER	
YEAR	MO	DAY															
AREA CODE	NUMBER																

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/5/2022							
10/6/2022							
10/7/2022							
10/8/2022							
10/9/2022							
10/10/2022							
10/11/2022	1.02	0.0000164	1.02	0.86	<0.25	<0.25	<5
10/12/2022							
10/13/2022							
10/14/2022							
10/15/2022							
10/16/2022							<5
10/17/2022							
10/18/2022							
10/19/2022							<5
10/20/2022							
10/21/2022							
10/22/2022							
10/23/2022							
10/24/2022							
10/25/2022							
10/26/2022							
10/27/2022							<5
10/28/2022							
10/29/2022							
10/30/2022							
10/31/2022							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
10/1/2022							
10/2/2022							
10/3/2022	<0.0649	<2	<0.0260				
10/4/2022							
10/5/2022							
10/6/2022							
10/7/2022							
10/8/2022							
10/9/2022							
10/10/2022							
10/11/2022	<0.0802	<2	<0.0321				
10/12/2022							
10/13/2022				1.4	0.0000231	1.6	0.0000264
10/14/2022							
10/15/2022							
10/16/2022	<0.0676	<2	<0.0270				
10/17/2022							
10/18/2022							
10/19/2022	<0.0857	<2	<0.0343				
10/20/2022							
10/21/2022							
10/22/2022							
10/23/2022							
10/24/2022							
10/25/2022							
10/26/2022							
10/27/2022	<0.0785	<2	<0.0314				
10/28/2022							
10/29/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER 	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE 2317750181 124	DATE 		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/30/2022							
10/31/2022							

Set: 5 of 6

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis (2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL	(Report) #/100mL	(Report) % (2)	6.5 SU	9.0 SU	6.0 mg/L	(Report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
10/1/2022							
10/2/2022							
10/3/2022		1.00	98.57	7.98	8.0	8.23	
10/4/2022		1.00	94.64	7.85	7.9	8.12	
10/5/2022		1.00	94.48	7.80	7.8	7.96	
10/6/2022	1.327	3.10	92.82	7.81	7.8	7.75	
10/7/2022	1.663	4.10	94.71	7.84	7.8	8.03	
10/8/2022	1.663						
10/9/2022	1.888						
10/10/2022	2.245	2.00	97.13	7.83	7.8	8.42	
10/11/2022	2.245	1.00	94.17	7.89	7.9	8.30	
10/12/2022	2.012	2.00	90.82	7.53	7.5	7.82	
10/13/2022	2.012	4.10	92.86	7.57	7.6	7.88	<4
10/14/2022	2.520	6.20	90.09	7.50	7.5	7.83	
10/15/2022	2.520						
10/16/2022	2.670						
10/17/2022	4.032	5.20	94.53	7.51	7.5	8.31	
10/18/2022	5.120	5.20	93.33	7.64	7.6	8.33	
10/19/2022	5.407	5.10	94.61	7.56	7.6	8.49	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/20/2022	4.547	3.10	91.88	7.49	7.5	8.39	
10/21/2022	3.359	1.00	94.44	7.60	7.6	8.31	
10/22/2022	3.359						
10/23/2022	3.011						
10/24/2022	3.631	11.00	95.90	7.56	7.6	8.24	
10/25/2022	2.874	2.00	95.63	7.76	7.8	8.17	
10/26/2022	3.270	5.20	96.15	7.67	7.7	8.12	
10/27/2022	5.181	6.30	94.74	7.75	7.8	8.38	
10/28/2022	4.283	2.00	95.98	7.79	7.8	8.41	
10/29/2022	4.283						
10/30/2022	3.383						
10/31/2022	4.048	4.10	97.30	7.52	7.5	8.56	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl)Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
10/1/2022							
10/2/2022							
10/3/2022							
10/4/2022							
10/5/2022							
10/6/2022							
10/7/2022							
10/8/2022							
10/9/2022							
10/10/2022							
10/11/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317750181 124 AREA CODE	NUMBER YEAR MO DAY	DATE
--	---	---	---	---	----------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

10/12/2022							
10/13/2022	<0.0661						
10/14/2022							
10/15/2022							
10/16/2022							
10/17/2022							
10/18/2022							
10/19/2022							
10/20/2022							
10/21/2022							
10/22/2022							
10/23/2022							
10/24/2022							
10/25/2022							
10/26/2022							
10/27/2022							
10/28/2022							
10/29/2022							
10/30/2022							
10/31/2022							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.805	2.055	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	191.456	262.895	lbs/day	*****	12.3	16.8	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	99.54	125.618	lbs/day	*****	6.37	11.2	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	290 Maximum Monthly Average	480 Maximum 7-Day Average		*****	11 Maximum Monthly Average	17 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<4.664	<5.140	lbs/day	*****	<0.3	<0.3	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	88 Maximum Monthly Average	REPORT Maximum Daily		*****	1.6 Maximum Monthly Average	2.8 Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCUCadillac Financing Auth. GWCUSIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	4.424	5.856	lbs/day	*****	0.284	0.385	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0819	0.0930	lbs/day	*****	5.460	6.1	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0000164	0.0000164	lbs/day	*****	1.02	1.02	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	0.00000984	*****	lbs/day	*****	1.068	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0754	<0.0857	lbs/day	*****	<5	<5	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317750181 124			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	<0.0301	<0.0343	lbs/day	*****	<2	<2	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	REPORT Maximum Daily		*****	5.7 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	0.0000231	0.0000231	lbs/day	*****	1.4	1.4	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	0.0000264	0.0000264	lbs/day	*****	1.6	1.6	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	3.58	5.407	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****	*****	94.51	*****	90.09	% (2)		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 10/1/2022 - 10/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.49	*****	7.98	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.75	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	<0.0661	<0.0661	lbs/day	*****	<4	<4	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	REPORT Maximum Daily		*****	31 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317750181 124				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

Submission Identifier: DMR-MI0020257-20221031-1

Submission Signature Hash: L4BnuV+zs1ceuz74zeEGfPK2ZYE/YB/3FwAPDQTSZEU=

Submitter Name: Jeffrey Dietlin Cadillac Financing Auth. GWCU

Submitter Email: utilities@cadillac-mi.net

Submitted Date/Time: 11/9/2022 11:26:48 AM