

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	45 mg/L	1200 lbs/day	(Report) mg/L	(Report) lbs/day	34 mg/L	910 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
12/1/2022	1.751			8.00	116.803	12.10	
12/2/2022	1.703			13.00	184.612	8.70	
12/3/2022	1.672						
12/4/2022	1.390						
12/5/2022	1.484			12.00	148.551	5.70	
12/6/2022	1.768			7.00	103.234	9.20	
12/7/2022	1.752	9.000	125.254	5.00	73.071	12.30	137.242
12/8/2022	1.758	8.600	119.486	6.00	87.963	7.50	123.899
12/9/2022	1.634	7.600	104.371	8.00	109.035	8.10	121.269
12/10/2022	1.620	7.600	104.371				121.269
12/11/2022	1.395	7.600	104.371				121.269
12/12/2022	1.549	6.600	92.752	7.00	90.455	10.80	135.069
12/13/2022	1.791	6.400	90.025	6.00	89.601	9.10	135.112
12/14/2022	1.788	6.340	89.428	4.70	70.088	10.20	129.582
12/15/2022	1.789	6.080	85.862	4.70	70.134	10.30	138.331
12/16/2022	1.668	5.280	75.185	4.00	55.646	10.50	145.465
12/17/2022	1.438	5.280	75.185				145.465
12/18/2022	1.351	5.280	75.185				145.465
12/19/2022	1.465	6.520	89.355	13.20	161.305	6.00	132.218
12/20/2022	1.786	6.040	82.158	3.60	53.619	3.60	115.763
12/21/2022	1.737	5.820	78.571	3.60	52.150	3.80	96.351

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/22/2022	1.700	5.440	72.483	2.80	39.695	4.40	78.087
12/23/2022	1.586	5.040	66.643	2.00	26.446	4.40	60.509
12/24/2022	1.340	5.040	66.643				60.509
12/25/2022	1.326	5.040	66.643				60.509
12/26/2022	1.220	2.800	38.453	2.00	20.355	7.30	60.705
12/27/2022	1.375	2.960	37.823	4.40	50.466	3.00	56.863
12/28/2022	1.428	2.720	33.108	2.40	28.579	3.00	52.998
12/29/2022	1.506	2.960	35.214	4.00	50.224	3.00	48.056
12/30/2022	1.502	3.200	37.940	3.20	40.075	3.00	43.933
12/31/2022	1.365	3.200	37.940				43.933

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L	0.82 lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2022	176.665	0.48	6.950	0.180	2.628		
12/2/2022	123.548	0.30	4.260	0.193	2.741		
12/3/2022							
12/4/2022							
12/5/2022	70.562	0.30	3.714	0.171	2.117		
12/6/2022	135.679	0.30	4.424	0.193	2.846		
12/7/2022	179.755	0.30	4.384	0.156	2.280		
12/8/2022	109.954	0.30	4.398	0.137	2.008	10	0.1466
12/9/2022	110.398	0.30	4.089	0.137	1.867		
12/10/2022							
12/11/2022						10	0.1164
12/12/2022	139.558	0.39	5.014	0.165	2.132		

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317797346 AREA CODE	NUMBER 	DATE 	YEAR 	MO 	DAY
--	---	---	--	----------------------------	--------------------------	--------------------------	------------------------	-------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/13/2022	135.895	0.31	4.689	0.168	2.509		
12/14/2022	152.105	0.30	4.474	0.136	2.028		
12/15/2022	153.698	0.30	4.477	0.123	1.835		
12/16/2022	146.071	0.30	4.173	0.115	1.600	10	0.1391
12/17/2022							
12/18/2022							
12/19/2022	73.320	0.77	9.385	0.163	1.992	10	0.1222
12/20/2022	53.619	0.30	4.468	0.158	2.353		
12/21/2022	55.048	0.30	4.346	0.146	2.115		
12/22/2022	62.378	0.30	4.253	0.138	1.956		
12/23/2022	58.182	0.81	10.698	0.133	1.759		
12/24/2022							
12/25/2022							
12/26/2022	74.297	0.30	3.053	0.154	1.567		
12/27/2022	34.409	0.30	3.441	0.151	1.732		
12/28/2022	35.723	0.51	6.013	0.155	1.846	10	0.1191
12/29/2022	37.668	0.30	3.767	0.180	2.260		
12/30/2022	37.570	0.30	3.757	0.166	2.079		
12/31/2022							

Set: 3 of 6

Parameter	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank	Total Nickel
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Final Effluent (1)
Limit	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2022	*g	*g	*g	*g	*g	*g	
12/2/2022							
12/3/2022							
12/4/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/5/2022							
12/6/2022							
12/7/2022							
12/8/2022							5
12/9/2022							
12/10/2022							
12/11/2022							5
12/12/2022							
12/13/2022							
12/14/2022							
12/15/2022							
12/16/2022							5
12/17/2022							
12/18/2022							
12/19/2022							5
12/20/2022							
12/21/2022							
12/22/2022							
12/23/2022							
12/24/2022							
12/25/2022							
12/26/2022							
12/27/2022							
12/28/2022							5
12/29/2022							
12/30/2022							
12/31/2022							

Set: 4 of 6

Parameter	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)	Perfluorooctanoic Acid (PFOA)
-----------	--------------	----------------	----------------	----------------------------------	----------------------------------	-------------------------------	-------------------------------

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
12/1/2022				*g	*g	*g	*g
12/2/2022							
12/3/2022							
12/4/2022							
12/5/2022							
12/6/2022							
12/7/2022							
12/8/2022	0.0733	2	0.0293				
12/9/2022							
12/10/2022							
12/11/2022	0.0582	2	0.0233				
12/12/2022							
12/13/2022							
12/14/2022							
12/15/2022							
12/16/2022	0.0696	2	0.0278				
12/17/2022							
12/18/2022							
12/19/2022	0.0611	2	0.0244				
12/20/2022							
12/21/2022							
12/22/2022							
12/23/2022							
12/24/2022							
12/25/2022							
12/26/2022							
12/27/2022							
12/28/2022	0.0595	2	0.0238				
12/29/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE 2317797346	DATE		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO
					DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/30/2022							
12/31/2022							

Set: 5 of 6

Parameter	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH	Dissolved Oxygen	Bis (2-Ethylhexyl) Pht halate
Mon. Loc.	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	400 #/100mL	(Report) #/100mL	(Report) % (2)	6.5 SU	9.0 SU	5.0 mg/L	(Report) ug/L
Stat. Base	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
12/1/2022		3.00	96.97	7.62	7.6	9.12	
12/2/2022		3.10	95.72	7.67	7.7	8.90	
12/3/2022							
12/4/2022							
12/5/2022		1.00	96.77	7.60	7.6	9.26	
12/6/2022	2.077	2.00	97.54	7.57	7.6	9.02	4.1
12/7/2022	1.578	1.00	97.73	7.64	7.6	8.88	
12/8/2022	1.189	1.00	97.95	7.42	7.4	8.81	
12/9/2022	1.149	1.00	98.47	7.44	7.4	8.92	
12/10/2022	1.149						
12/11/2022	1.189						
12/12/2022	1.000	1.00	97.89	7.29	7.3	9.10	
12/13/2022	1.000	1.00	97.86	7.50	7.5	9.23	
12/14/2022	1.000	1.00	98.19	7.50	7.5	9.37	
12/15/2022	1.000	1.00	96.87	7.50	7.5	9.18	
12/16/2022	1.000	1.00	98.10	7.54	7.5	8.89	
12/17/2022	1.000						
12/18/2022	1.000						
12/19/2022	1.000	1.00	93.77	7.25	7.3	10.05	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/20/2022	1.000	1.00	98.56	7.26	7.3	9.78	
12/21/2022	1.000	1.00	98.11	7.37	7.4	9.76	
12/22/2022	1.000	1.00	99.07	7.28	7.3	9.61	
12/23/2022	1.000	1.00	99.13	7.50	7.5	8.96	
12/24/2022	1.000						
12/25/2022	1.000						
12/26/2022	1.000	1.00	98.67	7.47	7.5	10.24	
12/27/2022	1.000	1.00	99.19	7.36	7.4	10.16	
12/28/2022	1.000	1.00	99.00	7.29	7.3	10.07	
12/29/2022	1.000	1.00	99.11	7.54	7.5	9.84	
12/30/2022	1.000	1.00	97.78	7.44	7.4	9.75	
12/31/2022	1.000						

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl) Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
12/1/2022							
12/2/2022							
12/3/2022							
12/4/2022							
12/5/2022							
12/6/2022	0.0605						
12/7/2022							
12/8/2022							
12/9/2022							
12/10/2022							
12/11/2022							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

12/12/2022							
12/13/2022							
12/14/2022							
12/15/2022							
12/16/2022							
12/17/2022							
12/18/2022							
12/19/2022							
12/20/2022							
12/21/2022							
12/22/2022							
12/23/2022							
12/24/2022							
12/25/2022							
12/26/2022							
12/27/2022							
12/28/2022							
12/29/2022							
12/30/2022							
12/31/2022							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.576	1.791	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	5.75	125.25	lbs/day	*****	5.75	9	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	98.01	145.47	lbs/day	*****	7.09	12.3	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	670 Maximum Monthly Average	910 Maximum 7-Day Average		*****	25 Maximum Monthly Average	34 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	4.92	10.7	lbs/day	*****	0.37	0.81	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	99 Maximum Monthly Average	REPORT Maximum Daily		*****	3.7 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	2.1	2.85	lbs/day	*****	0.16	0.19	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.1287	0.1466	lbs/day	*****	10	10	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	*g	*****	lbs/day	*****	*g	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	0.0643	0.0733	lbs/day	*****	5	5	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	0.0257	0.0293	lbs/day	*****	2	2	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	REPORT Maximum Daily		*****	5.7 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	3.1	2.077	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal	SAMPLE MEASUREMENT	*****	*****	*****	97.84	*****	93.77	% (2)		Monthly	Calculation

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 12/1/2022 - 12/31/2022
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(81011) Percent Removal (K) Lab ID:	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	7.25	*****	7.67	SU		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	8.81	*****	*****	mg/L		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		5.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0605	0.0605	lbs/day	*****	4.1	4.1	ug/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	REPORT Maximum Daily		*****	31 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

Submission Identifier: DMR-MI0020257-20221231-1

Submission Signature Hash: NsF5iVjF2oXj4umeV8ybVj1OGfoSwy14JDSuE65rJH0=

Submitter Name: Jeffrey Dietlin

Submitter Email: utilities@cadillac-mi.net

Submitted Date/Time: 1/19/2023 11:29:44 AM