

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 6

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Conventional Daily	Final Effluent (1)	Final Effluent (1)
Limit	(Report) MGD	30 mg/L	800 lbs/day	(Report) mg/L	(Report) lbs/day	10 mg/L	270 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
6/1/2023	1.890			8.00	126.075	8.20	
6/2/2023	1.880			7.00	109.759	8.70	
6/3/2023	1.690						
6/4/2023	1.588						
6/5/2023	1.613			4.00	53.801	3.60	
6/6/2023	1.800			3.30	49.539	5.00	
6/7/2023	1.737	5.260	79.426	4.00	57.955	7.30	98.978
6/8/2023	1.747	5.060	74.605	7.00	101.968	8.90	99.062
6/9/2023	1.749	4.760	68.696	5.50	80.218	8.30	95.990
6/10/2023	1.629	4.760	68.696				95.990
6/11/2023	1.538	4.760	68.696				95.990
6/12/2023	1.506	4.860	69.244	4.50	56.537	4.10	96.608
6/13/2023	1.711	5.100	72.175	4.50	64.198	4.80	95.292
6/14/2023	1.785	5.400	76.956	5.50	81.860	4.90	88.724
6/15/2023	1.753	4.700	66.798	3.50	51.175	5.90	80.048
6/16/2023	1.697	5.000	70.566	7.00	99.059	5.10	70.271
6/17/2023	1.730	5.000	70.566				70.271
6/18/2023	1.482	5.000	70.566				70.271
6/19/2023	1.523	5.100	71.958	5.00	63.498	3.00	67.589
6/20/2023	1.821	4.800	68.231	3.00	45.561	3.45	64.372
6/21/2023	1.857	4.800	68.895	5.50	85.181	4.40	63.415

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

6/22/2023	1.893	5.800	85.503	8.50	134.215	4.40	60.057
6/23/2023	1.922	5.800	88.137	7.00	112.229	4.80	61.014
6/24/2023	1.841	5.800	88.137				61.014
6/25/2023	1.593	5.800	88.137				61.014
6/26/2023	1.680	5.900	90.853	5.50	77.080	5.15	67.830
6/27/2023	1.668	6.100	92.871	4.00	55.649	3.30	66.533
6/28/2023	1.647	5.400	81.327	2.00	27.464	3.00	61.143
6/29/2023	1.697	4.300	62.977	3.00	42.465	3.00	55.740
6/30/2023	1.739	3.000	41.982	0.50	7.251	3.00	49.050

Set: 2 of 6

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Total Copper
Mon. Loc.	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Conventional Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	2.0 mg/L	53 lbs/day	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	31 ug/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
6/1/2023	129.227	0.30		4.728	0.213	3.357	15.40
6/2/2023	136.415	0.30		4.704	0.214	3.355	
6/3/2023							
6/4/2023							
6/5/2023	48.421	0.30		4.035	0.218	2.932	
6/6/2023	75.060	0.30		4.504	0.219	3.288	
6/7/2023	105.769	0.30	4.463	4.347	0.190	2.753	
6/8/2023	129.645	0.30	4.392	4.370	0.172	2.506	
6/9/2023	121.056	0.30	4.326	4.376	0.159	2.319	6.20
6/10/2023			4.326				
6/11/2023			4.326				
6/12/2023	51.511	0.30	4.273	3.769	0.245	3.078	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE			
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

6/13/2023	68.478	0.30	4.237	4.323	0.268	3.823	
6/14/2023	72.930	0.30	4.260	4.465	0.205	3.051	6.40
6/15/2023	86.266	0.30	4.264	4.386	0.171	2.500	
6/16/2023	72.172	0.36	4.396	5.038	0.210	2.972	
6/17/2023			4.396				
6/18/2023			4.396				6.30
6/19/2023	38.099	0.30	4.404	3.810	0.294	3.734	
6/20/2023	52.395	0.91	6.298	13.790	0.261	3.964	7.10
6/21/2023	68.145	0.39	6.597	5.963	0.242	3.748	
6/22/2023	69.476	0.30	6.667	4.737	0.227	3.584	
6/23/2023	76.957	0.30	6.622	4.810	0.222	3.559	
6/24/2023			6.622				
6/25/2023			6.622				
6/26/2023	72.175	0.30	6.701	4.204	0.237	3.321	7.20
6/27/2023	45.910	0.30	4.778	4.174	0.290	4.035	
6/28/2023	41.195	0.30	4.409	4.120	0.250	3.433	
6/29/2023	42.465	0.30	4.311	4.246	0.242	3.425	
6/30/2023	43.506	0.30	4.219	4.351	0.306	4.438	

Set: 3 of 6

Parameter	Total Copper	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Mercury QA-Effluent	Mercury QA-Effluent	Mercury QA-Effluent	Mercury QA-Effluent
Limit	0.82 lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
6/1/2023	0.2427	*g	*g	*g	*g	*g	*g
6/2/2023							
6/3/2023							
6/4/2023							
6/5/2023							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

6/6/2023							
6/7/2023							
6/8/2023							
6/9/2023	0.0904						
6/10/2023							
6/11/2023							
6/12/2023							
6/13/2023							
6/14/2023	0.0953						
6/15/2023							
6/16/2023							
6/17/2023							
6/18/2023	0.0779						
6/19/2023							
6/20/2023	0.1078						
6/21/2023							
6/22/2023							
6/23/2023							
6/24/2023							
6/25/2023							
6/26/2023	0.1009						
6/27/2023							
6/28/2023							
6/29/2023							
6/30/2023							

Set: 4 of 6

Parameter	Total Nickel	Total Nickel	Total Selenium	Total Selenium	Perfluorooctane Sulfonate (PFOS)	Perfluorooctane Sulfonate (PFOS)	Perfluorooctanoic Acid (PFOA)
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE			
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

Permit Number: MI0020257 v6.0

DMR Version: 1

Generated: 7/18/2023 5:03 PM

Page 4 of 7

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

Limit	(Report) ug/L	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	(Report) ng/L	(Report) lbs/day	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
6/1/2023	5.00	0.0788	2.00	0.0315	*g	*g	*g
6/2/2023							
6/3/2023							
6/4/2023							
6/5/2023							
6/6/2023							
6/7/2023							
6/8/2023							
6/9/2023	5.00	0.0729	2.00	0.0292			
6/10/2023							
6/11/2023							
6/12/2023							
6/13/2023							
6/14/2023	5.00	0.0744	2.00	0.0298			
6/15/2023							
6/16/2023							
6/17/2023							
6/18/2023	5.00	0.0618	2.00	0.0247			
6/19/2023							
6/20/2023	5.00	0.0759	2.00	0.0304			
6/21/2023							
6/22/2023							
6/23/2023							
6/24/2023							
6/25/2023							
6/26/2023	5.00	0.0701	2.00	0.0280			
6/27/2023							
6/28/2023							
6/29/2023							
6/30/2023							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2317797346 AREA CODE NUMBER	DATE YEAR MO DAY
--	---	---	--	---

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

Set: 5 of 6

Parameter	Perfluorooctanoic Acid (PFOA)	Fecal Coliform	Fecal Coliform	pH	pH	Dissolved Oxygen	Bis(2-Ethylhexyl) Pthalate
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Fecal Daily	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	400 #/100mL	(Report) #/100mL	6.5 SU	9.0 SU	6.0 mg/L	(Report) ug/L
Stat. Base	Maximum Daily	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily	Maximum Daily	Minimum Daily	Maximum Daily
6/1/2023	*g		1.00	8.10	8.10	8.05	
6/2/2023			1.00	8.10	8.10	7.98	
6/3/2023							
6/4/2023							
6/5/2023			1.00	8.02	8.02	8.19	
6/6/2023		1.00	1.00	7.86	7.86	7.99	
6/7/2023		1.00	1.00	7.87	7.87	8.03	4.00
6/8/2023		1.00	1.00	7.79	7.79	8.11	
6/9/2023		1.00	1.00	7.87	7.87	8.05	
6/10/2023		1.00					
6/11/2023		1.00					
6/12/2023		1.00	1.00	7.79	7.79	8.29	
6/13/2023		1.00	1.00	7.94	7.94	8.39	
6/14/2023		1.00	1.00	7.92	7.92	8.19	
6/15/2023		1.19	2.00	7.94	7.94	8.00	
6/16/2023		1.15	1.00	7.26	7.26	7.92	
6/17/2023		1.15					
6/18/2023		1.19					
6/19/2023		1.57	3.00	7.23	7.23	7.82	
6/20/2023		1.57	1.00	7.36	7.36	7.85	
6/21/2023		1.99	5.20	7.43	7.43	7.80	
6/22/2023		1.99	1.00	7.89	7.89	7.89	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

6/23/2023		1.73	1.00	8.00	8.00	7.88	
6/24/2023		1.73					
6/25/2023		1.51					
6/26/2023		2.49	7.40	8.25	8.25	7.87	
6/27/2023		1.65	1.00	7.88	7.88	7.92	
6/28/2023		1.65	1.00	7.85	7.85	8.10	
6/29/2023		1.65	1.00	7.27	7.27	8.01	
6/30/2023		1.86	3.00	7.45	7.45	8.06	

Set: 6 of 6

Parameter	Bis(2-Ethylhexyl) Pht halate						
Mon. Loc.	Final Effluent (1)						
Limit	(Report) lbs/day						
Stat. Base	Maximum Daily						
6/1/2023							
6/2/2023							
6/3/2023							
6/4/2023							
6/5/2023							
6/6/2023							
6/7/2023	0.0580						
6/8/2023							
6/9/2023							
6/10/2023							
6/11/2023							
6/12/2023							
6/13/2023							
6/14/2023							
6/15/2023							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

6/16/2023							
6/17/2023							
6/18/2023							
6/19/2023							
6/20/2023							
6/21/2023							
6/22/2023							
6/23/2023							
6/24/2023							
6/25/2023							
6/26/2023							
6/27/2023							
6/28/2023							
6/29/2023							
6/30/2023							

DMR Instructions:

DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE		DATE		
			2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.714	1.922	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	71.9	92.9	lbs/day	*****	4.9	6.1	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	530 Maximum Monthly Average	800 Maximum 7-Day Average		*****	20 Maximum Monthly Average	30 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	74.9	99.1	lbs/day	*****	5.1	8.9	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	190 Maximum Monthly Average	270 Maximum 7-Day Average		*****	7 Maximum Monthly Average	10 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	4.875	6.701	lbs/day	*****	0.33	0.91	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	24 Maximum Monthly Average	53 Maximum 7-Day Average		*****	0.9 Maximum Monthly Average	2.0 Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	3.326	4.438	lbs/day	*****	0.23	0.306	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Total Copper (01042) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.1192	0.2427	lbs/day	*****	8.1	15.4	ug/L		Weekly	24-Hr Composite
	PERMIT REQUIREMENT	0.3 Maximum Monthly Average	0.82 Maximum Daily		*****	11 Maximum Monthly Average	31 Maximum Daily			Weekly	24-Hr Composite
Total Mercury (71900) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculation
Total Mercury (71900) Hg Calculation (X) Lab ID:	SAMPLE MEASUREMENT	*g	*****	lbs/day	*****	*g	*****	ng/L		Quarterly	Calculation
	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculation
Total Nickel (01067) Final Effluent (1)	SAMPLE MEASUREMENT	0.0723	0.0788	lbs/day	*****	5	5	ug/L		Quarterly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU	TELEPHONE	DATE		
			2317797346			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	24-Hr Composite
Total Selenium (01147) Final Effluent (1)	SAMPLE MEASUREMENT	0.0289	0.0315	lbs/day	*****	2	2	ug/L		Monthly	24-Hr Composite
Lab ID:	PERMIT REQUIREMENT	0.15 Maximum Monthly Average	REPORT Maximum Daily		*****	5.7 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS) (51526) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Perfluorooctanoic Acid (PFOA) (51521) Final Effluent (1)	SAMPLE MEASUREMENT	*g	*g	lbs/day	*****	*g	*g	ng/L		2X Annually	Grab
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			2X Annually	Grab
Fecal Coliform (74055) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.71	2.49	#/100mL		5X Weekly	Grab
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
pH (00400) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	7.23	*****	8.25	SU		5X Weekly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
2317797346								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v6.0
DMR Period: 6/1/2023 - 6/30/2023
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	*****	*****	*****	7.8	*****	*****	mg/L		5X Weekly	Grab
Final Effluent (1)	PERMIT REQUIREMENT	*****	*****		6.0 Minimum Daily	*****	*****			5X Weekly	Grab
Bis(2-Ethylhexyl) Phthalate (39100)	SAMPLE MEASUREMENT	0.058	0.058	lbs/day	*****	4	4	ug/L		Monthly	24-Hr Composite
Final Effluent (1)	PERMIT REQUIREMENT	0.82 Maximum Monthly Average	REPORT Maximum Daily		*****	31 Maximum Monthly Average	REPORT Maximum Daily			Monthly	24-Hr Composite

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Jeffrey Dietlin Cadillac Financing Auth. GWCU		TELEPHONE		DATE		
				2317797346				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

Submission Identifier: DMR-MI0020257-20230630-1

Submission Signature Hash: WJ8gUkw0wnkxSukpQATKkv2Oq7fU22YM9FUZWYyOX5oY=

Submitter Name: Jeffrey Dietlin

Submitter Email: utilities@cadillac-mi.net

Submitted Date/Time: 7/18/2023 5:03:18 PM