

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

I Limit Set Name: 001A -
Set: 1 of 7

Parameter	Flow	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Total Suspended Solids	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Carbonaceous Biochemical Oxygen Demand (CBOD5)
Mon. Loc.	Final Effluent (1)	Prior to Disinfection (B)	Prior to Disinfection (B)	Conventional Daily	Conventional Daily	Prior to Disinfection (B)	Prior to Disinfection (B)
Limit	(Report) MGD	45 mg/L	1,200 lbs/day	(Report) mg/L	(Report) lbs/day	34 mg/L	910 lbs/day
Stat. Base	Maximum Daily	Maximum 7-Day Average	Maximum 7-Day Average	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average
1/1/2026	1.28			9.30	99.27	4.50	
1/2/2026	1.27			8.70	92.25	3.00	
1/3/2026	1.31			5.60	60.99		
1/4/2026	1.30			2.40	25.99		
1/5/2026	1.38			8.00	91.92	4.20	
1/6/2026	1.65			8.70	119.57	5.00	
1/7/2026	1.66	7.24	85.81	8.00	110.69	4.93	53.01
1/8/2026	1.65	6.96	86.00	7.30	100.62	4.50	55.80
1/9/2026	1.87	6.76	89.08	7.30	113.79	3.30	59.73
1/10/2026	1.72	6.91	94.01	6.67	95.46		59.73
1/11/2026	1.49	7.80	105.64	8.66	107.46		59.73
1/12/2026	1.58	7.42	102.50	5.30	69.92	3.30	58.79
1/13/2026	1.73	7.42	103.37	8.70	125.64	3.60	55.44
1/14/2026	1.74	6.95	97.31	4.70	68.31	3.00	50.52
1/15/2026	1.64	6.48	90.76	4.00	54.74	3.00	46.32
1/16/2026	1.64	6.39	87.59	6.70	91.64	3.30	45.06
1/17/2026	1.58	5.91	80.23	3.33	43.89		45.06
1/18/2026	1.41	4.96	68.23	2.00	23.47		45.06
1/19/2026	1.44	5.06	68.52	6.00	71.96	3.60	44.99
1/20/2026	1.68	4.49	60.00	4.70	66.02	3.20	43.58
1/21/2026	1.65	4.96	65.97	8.00	110.05	3.80	45.32

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2319126200 <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">AREA CODE</td> <td style="width: 40%;">NUMBER</td> </tr> </table>	AREA CODE	NUMBER	DATE <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">YEAR</td> <td style="width: 20%;">MO</td> <td style="width: 20%;">DAY</td> </tr> </table>	YEAR	MO	DAY
AREA CODE	NUMBER								
YEAR	MO	DAY							

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/22/2026	1.69	4.78	63.59	2.70	38.08	3.60	47.26
1/23/2026	1.68	4.49	59.90	4.70	65.85	3.80	48.88
1/24/2026	1.94	4.59	62.88	4.00	64.74		48.88
1/25/2026	1.68	4.81	66.73	3.60	50.42		48.88
1/26/2026	1.72	4.91	70.21	6.70	96.29	4.50	53.18
1/27/2026	1.86	5.00	72.51	5.30	82.12	4.20	57.21
1/28/2026	1.84	5.00	74.34	8.00	122.92	4.20	59.66
1/29/2026	1.75	5.19	77.26	4.00	58.47	4.10	61.49
1/30/2026	1.73	5.27	78.77	5.30	76.46	4.10	62.67
1/31/2026	1.74	5.74	84.67	7.30	106.03		62.67

Set: 2 of 7

Parameter	Carbonaceous Biochemical Oxygen Demand (CBOD5)	Ammonia Nitrogen (as N)	Ammonia Nitrogen (as N)	Total Phosphorus (as P)	Total Phosphorus (as P)	Available Cyanide	Available Cyanide
Mon. Loc.	Conventional Daily	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	(Report) mg/L	(Report) lbs/day	(Report) ug/L	(Report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
1/1/2026	48.03	0.22	2.34	0.61	6.52		
1/2/2026	31.81	0.20	2.07	0.68	7.22		
1/3/2026							
1/4/2026							
1/5/2026	48.26	0.05	0.57	0.59	6.77		
1/6/2026	68.72	0.32	4.38	0.72	9.84	3.00	0.0412
1/7/2026	68.21	0.27	3.72	0.56	7.71		
1/8/2026	62.03	0.18	2.49	0.39	5.39		
1/9/2026	51.44	0.23	3.63	0.37	5.77		
1/10/2026							
1/11/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE 2319126200 AREA CODE	NUMBER 	DATE YEAR MO DAY
--	---	--	--	--------------------	-----------------------------

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/12/2026	43.54	0.13	1.77	0.31	4.02		
1/13/2026	51.99	0.22	3.13	0.42	6.01		
1/14/2026	43.60	0.27	3.92	0.45	6.54		
1/15/2026	41.06	0.24	3.34	0.37	5.01		
1/16/2026	45.14	0.10	1.42	0.36	4.98		
1/17/2026							
1/18/2026							
1/19/2026	43.17	0.08	0.98	0.23	2.72		
1/20/2026	44.95	0.31	4.37	0.35	4.92		
1/21/2026	52.27	0.25	3.43	0.37	5.05		
1/22/2026	50.77	0.23	3.29	0.36	5.12		
1/23/2026	53.24	0.27	3.78	0.35	4.89		
1/24/2026							
1/25/2026							
1/26/2026	64.67	0.29	4.15	0.27	3.89		
1/27/2026	65.07	0.52	8.04	0.41	6.41		
1/28/2026	64.53	0.65	10.02	0.47	7.21		
1/29/2026	59.93	0.35	5.15	0.39	5.67		
1/30/2026	59.14	0.26	3.68	0.41	5.94		
1/31/2026							

Set: 3 of 7

Parameter	Total Arsenic	Total Arsenic	Total Beryllium	Total Beryllium	Total Cadmium	Total Cadmium	Total Cadmium
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Conventional Daily
Limit	(Report) ug/L	(Report) lbs/day	(Report) ug/L	(Report) lbs/day	12 ug/L	0.32 lbs/day	(Report) lbs/day
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum 7-Day Average	Maximum Daily
1/1/2026							
1/2/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE 2319126200	DATE <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; height: 30px;"></td> <td style="width: 33%; height: 30px;"></td> <td style="width: 33%; height: 30px;"></td> </tr> <tr> <td>YEAR</td> <td>MO</td> <td>DAY</td> </tr> </table>						YEAR	MO	DAY
YEAR	MO	DAY										
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER								

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/3/2026	1.00	0.0109	1.00	0.0109	0.20		0.00218
1/4/2026							
1/5/2026							
1/6/2026	1.00	0.0137	1.00	0.0137	0.20		0.00275
1/7/2026						0.00246	
1/8/2026						0.00246	
1/9/2026						0.00246	
1/10/2026						0.00275	
1/11/2026						0.00275	
1/12/2026						0.00275	
1/13/2026						0.00275	
1/14/2026	1.00	0.0145	1.00	0.0145	0.20	0.00291	0.00291
1/15/2026						0.00291	
1/16/2026						0.00291	
1/17/2026						0.00291	
1/18/2026						0.00291	
1/19/2026						0.00291	
1/20/2026						0.00291	
1/21/2026						0.00291	
1/22/2026	1.00	0.0141	1.00	0.0141	0.20	0.00282	0.00282
1/23/2026						0.00282	
1/24/2026						0.00282	
1/25/2026						0.00282	
1/26/2026						0.00282	
1/27/2026						0.00282	
1/28/2026						0.00282	
1/29/2026						0.00282	
1/30/2026	1.00	0.0144	1.00	0.0144	0.20	0.00289	0.00289
1/31/2026						0.00289	

Set: 4 of 7

--	--	--	--	--	--	--	--

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

Parameter	Total Copper	Total Mercury	Total Mercury	Total Mercury - uncorrected	Total Mercury - field duplicate	Total Mercury - field blank	Total Mercury - laboratory method blank
Mon. Loc.	Prior to Disinfection (B)	Final Effluent (1)	Final Effluent (1)	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent	Mercury QA- Effluent
Limit	(Report) ug/L	(Report) ng/L	(Report) lbs/day	(Report) ng/L	(Report) ng/L	(Report) ng/L	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily
1/1/2026							
1/2/2026							
1/3/2026	13.00						
1/4/2026							
1/5/2026							
1/6/2026	14.00						
1/7/2026		0.60	0.00000830	0.60	0.56	0.20	0.20
1/8/2026							
1/9/2026							
1/10/2026							
1/11/2026							
1/12/2026							
1/13/2026							
1/14/2026	9.60						
1/15/2026							
1/16/2026							
1/17/2026							
1/18/2026							
1/19/2026							
1/20/2026							
1/21/2026							
1/22/2026	9.00						
1/23/2026							
1/24/2026							
1/25/2026							
1/26/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

TYPED OR PRINTED

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/27/2026							
1/28/2026							
1/29/2026							
1/30/2026	9.30						
1/31/2026							

Set: 5 of 7

Parameter	Total Silver	Total Silver	Acute Toxicity (Ceriodaphnia dubia)	Acute Toxicity (fathead minnow)	Chronic Toxicity (fathead minnow)	Chronic Toxicity (Ceriodaphnia dubia)	Perfluorooctane Sulfonate (PFOS)
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)
Limit	(Report) ug/L	(Report) lbs/day	(Report) TUA	(Report) TUA	(Report) TUC	(Report) TUC	(Report) ng/L
Stat. Base	Maximum Daily	Maximum Daily	Maximum Daily	Maximum Daily	Individual Chronic Value	Individual Chronic Value	Maximum Daily
1/1/2026							
1/2/2026							
1/3/2026	0.50	0.00545					
1/4/2026							
1/5/2026							
1/6/2026	0.50	0.00687					
1/7/2026							
1/8/2026							
1/9/2026							
1/10/2026							
1/11/2026							
1/12/2026			<0	<0	<0	<0	
1/13/2026							
1/14/2026	0.50	0.00727	<0	<0	<0	<0	
1/15/2026			<0	<0	<0	<0	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE			
			2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/16/2026							
1/17/2026							
1/18/2026							
1/19/2026							
1/20/2026							
1/21/2026							1.10
1/22/2026	0.50	0.00705					
1/23/2026							
1/24/2026							
1/25/2026							
1/26/2026							
1/27/2026							
1/28/2026							
1/29/2026							
1/30/2026	0.50	0.00721					
1/31/2026							

Set: 6 of 7

Parameter	Chloride	Sulfate	Fecal Coliform	Fecal Coliform	Total Suspended Solids Minimum % Removal	pH	pH
Mon. Loc.	Prior to Disinfection (B)	Prior to Disinfection (B)	Final Effluent (1)	Fecal Daily	Percent Removal (K)	Final Effluent (1)	Final Effluent (1)
Limit	(Report) mg/L	(Report) mg/L	400 #/100mL	(Report) #/100mL	(Report) %	6.5 SU	9.0 SU
Stat. Base	Maximum Daily	Maximum Daily	Max 7-Day Geometric Mean	Maximum Daily	Minimum Daily % Removal	Minimum Daily	Maximum Daily
1/1/2026				1.00	95.99	6.93	6.93
1/2/2026				1.00	96.98	7.11	7.11
1/3/2026							
1/4/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

TYPED OR PRINTED

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

1/5/2026				4.10	96.83	7.50	7.50
1/6/2026			1.69	2.00	96.55	7.22	7.22
1/7/2026			2.56	5.20	97.30	7.49	7.49
1/8/2026			3.64	4.10	92.70	7.44	7.44
1/9/2026			2.81	1.00	97.43	7.39	7.39
1/10/2026			2.81				
1/11/2026			2.56				
1/12/2026			2.56	2.00	93.69	7.35	7.35
1/13/2026			1.69	1.00	96.05	7.39	7.39
1/14/2026			1.80	5.20	97.78	7.47	7.47
1/15/2026			2.14	2.00	94.74	7.53	7.53
1/16/2026			1.83	1.00	96.44	7.72	7.72
1/17/2026			1.83				
1/18/2026			1.80				
1/19/2026			1.80	1.00	90.63	7.56	7.56
1/20/2026			1.19	1.00	95.48	7.48	7.48
1/21/2026	180.00	54.00	1.19	2.00	97.14	7.58	7.58
1/22/2026			1.19	1.00	99.25	7.57	7.57
1/23/2026			1.44	3.10	97.78	7.54	7.54
1/24/2026			1.44				
1/25/2026			1.58				
1/26/2026			2.08	3.00	97.34	7.37	7.37
1/27/2026			2.48	4.10	98.08	7.31	7.31
1/28/2026			5.07	17.30	97.10	7.41	7.41
1/29/2026			7.27	13.10	97.63	7.48	7.48
1/30/2026			11.45	70.60	98.46	7.37	7.37
1/31/2026			11.45				

Set: 7 of 7

Parameter	Dissolved Oxygen	Benzidine	Benzidine	Bromomethane			
Mon. Loc.	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)	Final Effluent (1)			

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
				2319126200				
		TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

Limit	5.0 mg/L	(Report) ug/L	(Report) lbs/day	(Report) ug/L			
Stat. Base	Minimum Daily	Maximum Daily	Maximum Daily	Maximum Daily			
1/1/2026	9.99						
1/2/2026	9.96						
1/3/2026							
1/4/2026							
1/5/2026	10.11						
1/6/2026	9.46						
1/7/2026	9.43	0.100	0.00138	<5.0			
1/8/2026	9.56						
1/9/2026	9.17						
1/10/2026							
1/11/2026							
1/12/2026	9.93						
1/13/2026	9.54						
1/14/2026	9.36						
1/15/2026	9.87						
1/16/2026	9.99						
1/17/2026							
1/18/2026							
1/19/2026	10.05						
1/20/2026	10.08						
1/21/2026	10.04	0.099	0.00136				
1/22/2026	9.85						
1/23/2026	9.93						
1/24/2026							
1/25/2026							
1/26/2026	10.03						
1/27/2026	9.65						
1/28/2026	9.74						
1/29/2026	10.01						
1/30/2026	9.63						
1/31/2026							

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE 2319126200	DATE			
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR) - DAILY

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

DMR Instructions:
DMR Comments: (none)

•

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE		DATE		
			2319126200				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

Limit Set: 001A

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow (50050) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	1.62	1.94	MGD	*****	*****	*****	*****		Daily	Report Total Daily Flow
	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	*****	*****			Daily	Report Total Daily Flow
Total Suspended Solids (00530) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	79.97	105.64	lbs/day	*****	5.95	7.80	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	800 Maximum Monthly Average	1,200 Maximum 7-Day Average		*****	30 Maximum Monthly Average	45 Maximum 7-Day Average			5X Weekly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	52.80	62.67	lbs/day	*****	3.85	5.00	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	610 Maximum Monthly Average	910 Maximum 7-Day Average		*****	23 Maximum Monthly Average	34 Maximum Daily			5X Weekly	24-Hr Composite
Ammonia Nitrogen (as N) (00610) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	3.62	10.02	lbs/day	*****	0.26	0.65	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	99 Maximum Monthly Average	REPORT Maximum Daily		*****	3.7 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
2319126200								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Total Phosphorus (as P) (00665) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	5.80	9.84	lbs/day	*****	0.43	0.72	mg/L		5X Weekly	24-Hr Composite
	PERMIT REQUIREMENT	13 Maximum Monthly Average	REPORT Maximum Daily		*****	0.5 Maximum Monthly Average	REPORT Maximum Daily			5X Weekly	24-Hr Composite
Available Cyanide (01257) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	0.0412	0.0412	lbs/day	*****	3	3	ug/L		Monthly	Grab
	PERMIT REQUIREMENT	0.16 Maximum Monthly Average	REPORT Maximum Daily		*****	5.9 Maximum Monthly Average	REPORT Maximum Daily			Monthly	Grab
Total Arsenic (01002) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	0.0135	0.0145	lbs/day	*****	1	1	ug/L		2X Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.43 Maximum Monthly Average	REPORT Maximum Daily		*****	16 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composite
Total Beryllium (01012) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	0.0135	0.0145	lbs/day	*****	1	1	ug/L		2X Monthly	24-Hr Composite
	PERMIT REQUIREMENT	0.11 Maximum Monthly Average	REPORT Maximum Daily		*****	4.1 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composite
Total Cadmium (01027) Prior to Disinfection (B)	SAMPLE MEASUREMENT	0.00271	0.00291	lbs/day	*****	0.2	0.2	ug/L		2X Monthly	24-Hr Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
			2319126200			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	0.11 Maximum Monthly Average	0.32 Maximum 7-Day Average		*****	4.1 Maximum Monthly Average	12 Maximum Daily			2X Monthly	24-Hr Composit e
Total Copper (01042) Prior to Disinfection (B)	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	14	ug/L		2X Monthly	24-Hr Composit e
Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			2X Monthly	24-Hr Composit e
Total Mercury (71900) Final Effluent (1)	SAMPLE MEASUREMENT	0.00000830	0.00000830	lbs/day	*****	0.60	0.60	ng/L		Quarterly	Calculat ion
Lab ID:	PERMIT REQUIREMENT	REPORT Maximum Monthly Average	REPORT Maximum Daily		*****	REPORT Maximum Monthly Average	REPORT Maximum Daily			Quarterly	Calculat ion
Total Mercury (71900) Hg Calculation (X)	SAMPLE MEASUREMENT	0.00000736	*****	lbs/day	*****	0.568	*****	ng/L		Quarterly	Calculat ion
Lab ID:	PERMIT REQUIREMENT	0.000053 12-Month Rolling Average	*****		*****	2.0 12-Month Rolling Average	*****			Quarterly	Calculat ion
Total Silver (01077) Prior to Disinfection (B)	SAMPLE MEASUREMENT	0.00677	0.00727	lbs/day	*****	0.5	0.5	ug/L		2X Monthly	24-Hr Composit e
Lab ID:	PERMIT REQUIREMENT	0.037 Maximum Monthly Average	REPORT Maximum Daily		*****	1.4 Maximum Monthly Average	REPORT Maximum Daily			2X Monthly	24-Hr Composit e

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
2319126200								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Acute Toxicity (Ceriodaphnia dubia) (61425) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	<0.0	TUA		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Quarterly	24-Hr Composite
Acute Toxicity (fathead minnow) (TSI6C) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	<0.0	TUA		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Quarterly	24-Hr Composite
Chronic Toxicity (fathead minnow) (TTK6C) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.0	<0.0	TUC		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	1.1 Maximum Monthly Average	REPORT Individual Chronic Value			Quarterly	24-Hr Composite
Chronic Toxicity (Ceriodaphnia dubia) (03599) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.0	<0.0	TUC		Quarterly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	1.1 Maximum Monthly Average	REPORT Individual Chronic Value			Quarterly	24-Hr Composite
Perfluorooctane Sulfonate (PFOS)	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1.1	ng/L		3X Annually	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac	TELEPHONE	DATE		
			2319126200			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO DAY

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
(51526) Final Effluent (1) Lab ID:	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			3X Annually	Grab
Chloride (00940) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	180	mg/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Monthly	24-Hr Composite
Sulfate (00945) Prior to Disinfection (B) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	54	mg/L		Monthly	24-Hr Composite
	PERMIT REQUIREMENT	*****	*****		*****	*****	REPORT Maximum Daily			Monthly	24-Hr Composite
Fecal Coliform (74055) Final Effluent (1) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	*****	6.63	11.45	#/100mL		5X Weekly	Grab
	PERMIT REQUIREMENT	*****	*****		*****	200 Max Monthly Geometric Mean	400 Max 7-Day Geometric Mean			5X Weekly	Grab
Total Suspended Solids Minimum % Removal (81011) Percent Removal (K) Lab ID:	SAMPLE MEASUREMENT	*****	*****	*****	96.43	*****	90.63	%		Monthly	Calculation
	PERMIT REQUIREMENT	*****	*****		85 Minimum Monthly % Removal	*****	REPORT Minimum Daily % Removal			Monthly	Calculation
pH (00400) Final Effluent (1)	SAMPLE MEASUREMENT	*****	*****	*****	6.93	*****	7.72	SU		5X Weekly	Grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
2319126200								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

DISCHARGE MONITORING REPORT (DMR)

Facility Name: Cadillac WWTP
Permittee Name: City of Cadillac

Permit Number: MI0020257 v7.0
DMR Period: 1/1/2026 - 1/31/2026
DMR Version: 1

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Lab ID:	PERMIT REQUIREMENT	*****	*****		6.5 Minimum Daily	*****	9.0 Maximum Daily			5X Weekly	Grab
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	*****	*****		9.17	*****	*****			5X Weekly	Grab
Final Effluent (1)											
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	5.0 Minimum Daily	*****	*****	mg/L		5X Weekly	Grab
Benzidine (39120)	SAMPLE MEASUREMENT	0.00137	0.00138		*****	0.1	0.1			2X Monthly	Grab
Final Effluent (1)											
Lab ID:	PERMIT REQUIREMENT	0.0032 Maximum Monthly Average	REPORT Maximum Daily	lbs/day	*****	0.12 Maximum Monthly Average	REPORT Maximum Daily	ug/L		2X Monthly	Grab
Bromomethane (38677)	SAMPLE MEASUREMENT	*****	*****		*****	*****	<5			Quarterly	Grab
Final Effluent (1)											
Lab ID:	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	REPORT Maximum Daily	ug/L		Quarterly	Grab

DMR Instructions:

DMR Comments: (none)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Patrick Miller City of Cadillac		TELEPHONE		DATE		
2319126200								
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY	

Submission Identifier: DMR-MI0020257-20260131-1

Submission Signature Hash: EfJFh4lgSoNVno4mpOrrnAbZsprLdRSoyQlGFNBzkbQ=

Submitter Name: Patrick Miller

Submitter Email: pmiller@cadillac-mi.net

Submitted Date/Time: 2/13/2026 9:53:30 AM