

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 10/25/2017 11:52:38 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: RE: BOD Violation (Permit# MI0020257)

Don,

Yes, I will let you know when we are back in compliance. We were experimenting with some high strength waste (apple peels) at the head works to increase our digester gas production. I think this is what caused our filamentous problem to spike. We treated it with a low level of chlorine solution to reduce filamentous in the aeration basins. Also RAS, WAS adjustments and more adequate use of our equalization basin to lower day time peak flows.

Yes, I would still like to look at the options for the seasonal permitting.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor
City of Cadillac
231-775-2841

From: Brady, Donal (DEQ) [mailto:BradyD6@michigan.gov]
Sent: Wednesday, October 25, 2017 10:34 AM
To: Doug Langworthy
Cc: Jeff Dietlin
Subject: RE: BOD Violation (Permit# MI0020257)

Thanks for the notice Doug. Can you pls. let me know when the BOD is back within limits? Also, can you provide a brief explanation of what you did to control the filamentous and any theories you have on why they showed up?

I understand that fall and spring can be challenging times at WWTPs. Did you decide if you wanted the seasons broken up differently on your NPDES permit?



Don Brady, P.E.
Michigan Department of Environmental Quality
Water Resources Division
Cadillac District Office
120 West Chapin Street
Cadillac, MI 49601
(231) 876-4478
BradyD6@michigan.gov

From: Doug Langworthy [<mailto:dlangworthy@Cadillac-MI.net>]
Sent: Wednesday, October 25, 2017 9:52 AM
To: Brady, Donal (DEQ) <BradyD6@michigan.gov>
Cc: Jeff Dietlin <utilities@Cadillac-MI.net>
Subject: BOD Violation (Permit# MI0020257)

Don,

Today we had a BOD violation of 11.3 mg/L for the day of Friday 10-20-2017. The violation comes after a spike of filamentous bacteria in our activated sludge process. I believe we have the filamentous under control now. If you have any questions feel free to contact me.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor
City of Cadillac
231-775-2841