

Bitondo, Mike (DEQ)

From: Bitondo, Mike (DEQ)
Sent: Friday, August 09, 2013 10:46 AM
To: 'Jeff Dietlin'
Cc: Barbieri, Charles (CBarbieri@fosterswift.com); Hamid Rahbarnoohi
Subject: RE: City of Cadillac NPDES draft permit
Attachments: Cadillac WWTP Response to Comments.pdf

Attached is the response to your comments from our biologist, Glen Schmitt.

He recommends that Available Cyanide limits & monitoring remain unchanged; Total Copper is reduced to quarterly monitoring only; and, Mercury remains unchanged. See his memo for details.

Note that Total Copper may not have been properly reviewed for the 2008 permit and Total Copper monitoring (and possibly limits) maybe should have been included in the 2008 permit.

Mercury limits are calculated using past data at each site. If the Mercury Pollutant Minimization Program is properly implemented yet the new limit cannot be met, then that would be evidence that the limit may need to be recalculated. We have found that our current Mercury strategy works well and most permittees are able to meet their limits.

If you wish to discuss this further with Glenn, he is out until August 19, 2013 conducting field work. I am available anytime except I will be out this Monday August 12, maybe August 19, and the morning of August 20.

We need to get the permit on public notice soon to meet our commitments to US EPA but negotiations can continue during the public notice period.

Thank you.

Mike Bitondo, 517-335-3303, bitondom@michigan.gov
Lakes Michigan and Superior Permits Unit
Water Resources Division-DEQ, PO Box 30458, Lansing, MI 48909-7958

From: Jeff Dietlin [<mailto:utilities@Cadillac-MI.net>]
Sent: Thursday, August 01, 2013 3:29 PM
To: Bitondo, Mike (DEQ)
Cc: Barbieri, Charles (CBarbieri@fosterswift.com); Hamid Rahbarnoohi
Subject: City of Cadillac NPDES draft permit

Mr. Mike Bitondo,

Attached please find the letter City of Cadillac response to the draft NPDES. Also attached is a pdf signed copy. Would you like a hard copy mailed to you for your files.

Please contact me at your earliest convenience so we can discuss the concerns we have over the draft permit.

Thank you,

JEFFREY M. DIETLIN

City of Cadillac
Director of Utilities
(231) 779-7346(Direct)
(231)775-0906 (Fax)

