

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/17/2017 9:05:16 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jankowski, Brian (DEQ)" <JANKOWSKIB@michigan.gov>; "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: RE: BOD Violations (NPDES MI0020257)

Don,
Just to let you know, our BOD have been within the compliance limits all week.
Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor
City of Cadillac
231-775-2841

From: Brady, Donal (DEQ) [mailto:BradyD6@michigan.gov]
Sent: Friday, May 12, 2017 9:51 AM
To: Doug Langworthy
Cc: Jeff Dietlin; Jankowski, Brian (DEQ)
Subject: RE: BOD Violations (NPDES MI0020257)

Hi Doug,

Thank you for this written report (e-mail) and also for the phone calls and other e-mails earlier this week.



Don Brady, P.E.
Michigan Department of Environmental Quality
Water Resources Division
Cadillac District Office
120 West Chapin Street
Cadillac, MI 49601
(231) 876-4478
BradyD6@michigan.gov

From: Doug Langworthy [mailto:dlangworthy@Cadillac-MI.net]
Sent: Friday, May 12, 2017 9:46 AM
To: Brady, Donal (DEQ) <BradyD6@michigan.gov>
Cc: Jeff Dietlin <utilities@Cadillac-MI.net>; Jankowski, Brian (DEQ) <JANKOWSKIB@michigan.gov>
Subject: BOD Violations (NPDES MI0020257)

Mr. Brady,

As per our permit required by Part II, Sections C.6 and C.8. I am submitting a written report of our recent BOD violations. Our daily limit of 10mg/L was exceeded on 5/3 with an effluent reading of 11.2mg/L, on 5/4 with an effluent reading of 10.7mg/L and 5/5 with an effluent reading of 13.8mg/L. I believe the underlying cause of the is the colder weather we've had with the plants seasonal turn over. The weather has been more cooperative in recent days and a minor increase in waste activated sludge has shown overall improvement in the plants efficiency. I anticipate we will be back in compliance in the coming days.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841