

**From:** Ottjepka, Jenny (EGLE)  
**Sent:** 2/19/2026 4:05:40 PM  
**To:** "cgee@glfenv.com" <cgee@glfenv.com>  
**Cc:** "Nixon, Shane (EGLE)" <NIXONS@michigan.gov>; "Wells, Lindsey (EGLE)" <WellsL8@michigan.gov>; "anthony.testa@gflenv.com" <anthony.testa@gflenv.com>; "bkotrba@eillc.com" <bkotrba@eillc.com>  
**Subject:** Flare Performance Test Plan Letter  
**Attachments:** N3862\_Flare Performance Test Plan\_ 2-27-26 (2).pdf

Good Afternoon,

Attached is the letter regarding the Flare Performance Test Plan from Lindsey Wells of the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division.

If you have any questions, please contact Lindsey Wells at [WellsL8@michigan.gov](mailto:WellsL8@michigan.gov) or by phone at 517-282-2345.

Thank you,  
Jenny Ottjepka  
Cadillac District Secretary  
Air Quality Division  
Michigan Department of Environment,  
Great Lakes and Energy  
231-942-3820 / [OttjepkaJ@michigan.gov](mailto:OttjepkaJ@michigan.gov)

ATTACHMENT NAME:

N3862\_Flare Performance Test Plan\_ 2-27-26 (2).pdf

ATTACHMENT TYPE:

Adobe Portable Document Format (PDF) compound image



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
AIR QUALITY DIVISION



PHILLIP D. ROOS  
DIRECTOR

February 19, 2026

Christopher Gee  
Wexford County Landfill  
990 N Mackinaw Trail  
Manton, Michigan 49663

SRN: N3862; Wexford County

Dear Christopher Gee:

SUBJECT: Wexford – GFL Flare Performance Test Plan 2026  
ROP0000566 v4.0 (MI-ROP-N3862-2022)

The Michigan Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) has reviewed the Air Quality Test Plan Submittal received on January 22, 2026 (Reference 0AAE-7N4K-ZMP6) for testing at the Wexford County Landfill facility in Manton, Michigan. The EUFLARE will be tested for flare exhaust gas velocity, flare inlet gas net heating value, and visible emissions. Performance testing of the EUFLARE is required by ROP0000566 v4.0 (MI-ROP-N3862-2022). Testing is scheduled for February 27, 2026.

Testing will be performed in accordance with Title 40 of the Code of Federal Regulations (40 CFR) Part 60, Appendix A:

- Methods 1A and 2C will be used to determine the flare gas exit velocity for the unobstructed cross-sectional area of the flare tip in accordance with 40 CFR 60.18(f)(4) and 40 CFR 63.11(b)(7)(i).
- Method 3C will be used to determine the concentration of methane for the net heating value determination.
- Method 22 will be used to determine visible emissions via a single 120-minute Method 22 reading.

All requirements and specifications of the above methods apply; and the AQD recommends submission of an alternative method request to Environmental Protection Agency's (EPA) Office of Air Quality Planning and Standards Measurement Group and EPA Region V for any modifications to the applicable portions of 40 CFR Part 62, Subpart OOO and/or 40 CFR Part 63, Subpart AAAA.

During the test, the EUFLARE will operate at normal routine landfill gas flow. During each test run, the following information will be recorded:

- Landfill gas flow to flare in CFM
- Flare temperature
- Sufficient process information to demonstrate normal routine landfill conditions

The test report will include:

- all analyzer QA/QC data, and all test run data, all in tabular format
- field data sheets
- all laboratory data and results which will be presented with units of measurement
- the process data listed above
- the information listed in 40 CFR 63.1981(i):

- a diagram of the collection system showing all wells, gas extraction devices including collectors, and areas excluded or proposed to be in future expansion
- the data upon which density of wells, collectors, and gas mover sizing are based
- for areas excluded based on asbestos and/or non-degradable materials, supporting waste-in-place documentation detailing the presence of asbestos or non-degradable material
- for areas excluded based on nonproductivity, the sum of gas generation flow rates from all areas and the supporting calculations for each excluded area
- the provisions for increasing gas mover equipment capability if the present gas mover equipment is inadequate to move the maximum flow rate expected over the life of the landfill
- the provisions for the control of off-site migration.
- landfill gas flare flowrate data 60 days prior to and the day of the performance test. Monthly well monitoring data for December 2025, January 2026, and (if available) February 2026 in spreadsheet format with numerical data,

All aborted, repeated, and/or invalidated runs must be included in the report.

The AQD recommends submission of a complete copy of the test report using the Air Quality Test Report schedule within the MiEnviro portal for air site N3862 – Wexford County Landfill.

If you have questions regarding this letter, or if there is a change in test date, please contact me at the number listed below or at WellsL8@Michigan.gov.

Sincerely,



Lindsey Wells  
Environmental Quality Analyst  
Air Quality Division  
517-282-2345

cc: Anthony Testa, Wexford County Landfill,  
Ben Kotrba, Environmental Information Logistics, LLC  
Shane Nixon, EGLE