



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

Section I: INTERVIEW

Control Authority: Cadillac WWTP

NPDES Permit #

Inspection Date(s): 5/14/15

Period Covered by Inspection: 5/14/14 → 5/15/15

Inspector(s): Jill Edelbrock, Julie Lowe

Name	Title	Phone/e-mail
Jill Edelbrock	EQA	989-894-6266
Julie Lowe	EQA	989-705-3446 Lowej2@Michigan.gov

Facility Representative(s):

Name	Title	Phone/e-mail
Hamid Rahbarnoochi	Water Resources Sup.	231-775-2841 hrahbarnoochi@cadillac-mi.net



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

IPP Implementation: ERP

1. Are you having problems with any industrial users?



Yes



No

If yes, complete the following:

Facility Name(s)	Nature of Problem and CA Response
Arvco	use ink for cardboard and having color problems
cci cadillac casting inc	historical Zn problem H ₂ O towers - reduced H ₂ O now hit metals
michigan rubber	plant problems w/ Nitrification FOG & 29 - primaries had scum layer - short circuited - just took another sample will follow up



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

2. a) Did the POTW experience any of the following since the last inspection? [R 323.2303] Please check all that apply and the cause.

Did the POTW experience any of the following?	Yes	No	Industrial Cause	Non-Industrial Cause	Cause Unknown
Interference	☒	☐	☐ <i>mich rubber</i>	☐	☐
Pass through	☒	☐	☐ <i>Rubber</i>	☐	☐
Fire or explosion	☐	☒	☐	☐	☐
Corrosive structural damage	☐	☒	☐	☐	☐
Flow obstruction	☐	☒	☐	☐	☐
Excessive flow rates	☐	☒	☐	☐	☐
Excessive pollutant contributions	☒	☐	☐ <i>mich rubber</i>	☐	☐
Heat problems	☐	☒	☐	☐	☐
Interference due to oil & grease	☒	☐	☐ <i>mich rubber</i>	☐	☐
Toxic fumes	☐	☒	☐	☐	☐
Illicit dumping of hauled wastes	☐	☒	☐	☐	☐
Worker health & safety issues	☐	☒	☐	☐	☐
NPDES Violations (specify)	☒	☐	☐ <i>mich rubber</i>	☐	☐

Ammonia

- b) For each instance of industrial cause checked above provide information in table below.

IU Name	Action Taken
<i>see above</i> <i>Michigan Rubber</i>	<i>email sent - will follow up</i>



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

IPP Implementation: Procedures

Regulation of IUs

3. a. Any new SIUs since the last IPP Annual Report was submitted? [R323.2306 (c) (i)]

☐ Yes ☒ No

If yes, please list

*Spencer plastics + BnP were new
the year before.*

b. How do you find out about new industrial users and ensure that they are properly regulated?

city hall notifies plant.

4. Are all of your SIU's currently covered by an enforceable permit or equivalent control document? [R 323.2306 (a) (iii)]

☒ Yes ☐ No

If no, list and explain:

5. How many permits were reissued more than 180 days after the expiration date of the previous permit? [40 CFR 123.45 (EPA 1990 QNCR Guidance)]

None

Explain:

Inspections and Sampling

6. In the past 12 months, were all your SIU's [R 323.2306(c)(v)]:

a) Sampled for all regulated parameters at least once by the CA?

☒ Yes ☐ No

b) Formally inspected at least once by the CA?

☒ Yes ☐ No



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

Continued Inspections and Sampling

- c) If (a) and/or (b) is no, please list facilities that were not inspected or adequately sampled and an explanation.

Facility	Explanation

Adequate Resources

7. Describe the training provided for IPP staff since the last inspection. [R 323.2306 (e)]

joint biosolids/MWEA 2 years ago

8. Are you planning to propose any program modifications within the next year? [R 323.2309]

☐ Yes ☒ No

If yes, describe:

Section II: FILE REVIEW

9. Are there any specific IU's that you would like us to review during our inspection?

☐ Yes ☒ No

If yes, please list, and state reason.

10. IU's selected for review:

Industry Name	File No.



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER RESOURCES DIVISION
PRETREATMENT COMPLIANCE INSPECTION

Section III: SUMMARY & EVALUATION

1. Violations, deficiencies and required corrective actions:

2. SNC Evaluation: Facilities that meet any Level I criteria or two or more Level II criteria are considered to be in SNC [USEPA QNCR Guidance]

a. Level I Criteria:

i. Failure to enforce against Pass-through and Interference ☐

b. Level II Criteria:

i. Failure to issue/reissue >10% of SIU permits within 180 days. ☐

ii. Failure to inspect or sample at least 80% of SIUs in the past year. ☐

iii. Failure to enforce pretreatment standards and reporting requirements ☐

iv. Any other violation of concern to the Approval Authority. ☐

c. Facility does not meet SNC Criteria ☐

3. NMS Data:

Areas Evaluated	Comment (S, M, U, NE)	Comment Detail
Enforcement Response	S	
IU Reporting	S	
IU Permits	M	See Comments
Procedures Implementation	S	
Inspections/Sampling	M	Inspect Form needs updating
Adequate resources	S	
Legal Authority	S	
Local Limits	S	
Enforcement Response Plan	S	
Procedures	S	

S=Satisfactory, M=Marginal, U=Unsatisfactory, NE= Not Evaluated