

Section I: INTERVIEW

PRETREATMENT COMPLIANCE INSPECTION

Control Authority: Cadillac WWTP

NPDES Permit # MI 0020257

Inspection Date(s): 5/14/15

Period Covered by Inspection: Permit cycle Nov 2013 - Present

Inspector(s): Jill Edelbrock / Julie Lowe

Name	Title	Phone/e-mail
Jill Edelbrock	EQA	989-894-6266
Julie Lowe	EQA	989-705-3446

Facility Representative(s):

Name	Title	Phone/e-mail
Hamid Rahbarnoo	Water Resource ^{Super User}	231-775-2841
	Hamid hrahbarnoo	hrahbarnoo@
		Cadillac - MI.net

IPP Implementation: ERP

1. Are you having problems with any industrial users?

☒ Yes ☐ No

If yes, complete the following:

Facility Name(s)	Nature of Problem and CA Response
ARVLO	They make cardboard boxes - ink causing color changes. Low flow
CCI Cadillac Casting Inc.	Lately things are good. They are recycling water. Metals & mass bal. is ok. Less water = not much dilution. Moly, copper etc. hits in the past
Michigan Rubber Fats/oils - causing problems w/ nitrification No limit in permit - NOT taking enforcement yet Just verifying sampling.	Nitrification / Ammonia limits exceeded - they don't have nitrification. Creates bumps & makes primary tanks to malfunction. Freezing in winter. ERP: WWTP is sampling / following up. ^{Harmful is} ^{they knew about it} ^{new} toxicity of ammonia
* This is why they are	having Ammonia issues
AVON automotive	EPA contacted about toluene dumping down drain. Talk to Brian Sheen at plant. ^{older - prior to Aug 2015}

Follow-up w/ Brian Matzen - Cadillac District office ✓
Brian Jankowski or Ryan Blazic chief follow-up

2. a) Did the POTW experience any of the following since the last inspection? [R 323.2303] Please check all that apply and the cause.

Did the POTW experience any of the following?	Yes	No	Industrial Cause	Non-Industrial Cause	Cause Unknown
Interference	☒	☐	☒	☐	☒
Pass through	☒	☐	☒	☐	☒
Fire or explosion	☐	☒	☐	☐	☐
Corrosive structural damage	☐	☒	☐	☐	☐
Flow obstruction	☐	☒	☐	☐	☐
Excessive flow rates	☐	☒	☐	☐	☐
Excessive pollutant contributions	☒	☐	☐	☐	☐
Heat problems	☐	☒	☐	☐	☐
Interference due to oil & grease	☒	☐	☐	☐	☐
Toxic fumes	☐	☒	☐	☐	☐
Illicit dumping of hauled wastes	☒	☒	☐	☐	☐
Worker health & safety issues	☐	☒	☐	☐	☐
NPDES Violations (specify) Ammonia recently	☒	☐	☐	☐	☐

Michigan Rubber & Nitrification Bacteria - they can't survive the winter - each spring / early spring ammonia on the rise

- b) For each instance of industrial cause checked above provide information in table below.

IU Name	Action Taken
Michigan Rubber	sampled FAT/oil Limit - Added sent email to permit? waiting results + follow-up

Fat / oil / Grease - what does the SNO say → not in SNO in Resolution >

IPP Implementation: Procedures

Regulation of IUs

3. a. Any new SIUs since the last IPP Annual Report was submitted? [R323.2306 (c) (i)]

☐ Yes ☒ No

If yes, please list

- b. How do you find out about new industrial users and ensure that they are properly regulated?

They have to go to City Hall for water usage. City hall contacts WWTP. WWTP - site visit to new facilities.

4. Are all of your SIU's currently covered by an enforceable permit or equivalent control document? [R 323.2306 (a) (iii)]

☒ Yes ☐ No

If no, list and explain:

5. How many permits were reissued more than 180 days after the expiration date of the previous permit? [40 CFR 123.45 (EPA 1990 QNCR Guidance)]

None

Explain:

Inspections and Sampling

6. In the past 12 months, were all your SIU's [R 323.2306(c)(v)]:

- a) Sampled for all regulated parameters at least once by the CA?

☒ Yes ☐ No

- b) Formally inspected at least once by the CA?

☒ Yes ☐ No

(Inspections and Sampling, continued)

- c) If (a) and/or (b) is no, please list facilities that were not inspected or adequately sampled and an explanation.

Facility	Explanation

Adequate Resources

7. Describe the training provided for IPP staff since the last inspection. [R 323.2306 (e)]

Joint IPP/ Biosolids - 2 yrs ago

8. Are you planning to propose any program modifications within the next year?
[R 323.2309]

☐ Yes ☒ No

If yes, describe:

Section II: FILE REVIEW

9. Are there any specific IU's that you would like us to review during our inspection?

☒ Yes ☐ No

If yes, please list, and state reason.

Michigan Rubber
ARVCO

10. IU's selected for review:

Industry Name	File No.
ARVCO	590-20
Michigan Rubber	not recorded

Section III: SUMMARY & EVALUATION

1. Violations, deficiencies and required corrective actions:

ND

2. SNC Evaluation: Facilities that meet any Level I criteria or two or more Level II criteria are considered to be in SNC [USEPA QNCR Guidance]

a. Level I Criteria:

i. Failure to enforce against Pass-through and Interference ☒

b. Level II Criteria:

i. Failure to issue/reissue >10% of SIU permits within 180 days. ☒

ii. Failure to inspect or sample at least 80% of SIUs in the past year. ☒

iii. Failure to enforce pretreatment standards and reporting requirements ☒

iv. Any other violation of concern to the Approval Authority. ☒

c. Facility does not meet SNC Criteria ☒

3. NMS Data:

Areas Evaluated	Comment (S, M, U, NE)	Comment Detail
Enforcement Response	S	
IU Reporting	S	
IU Permits	S	
Procedures Implementation	M, S	Follow-up - ERP
Inspections/Sampling	S	
Adequate resources	S	
Legal Authority	S	
Local Limits	S	
Enforcement Response Plan	S, M	Follow-up
Procedures	S	

S=Satisfactory, M=Marginal, U=Unsatisfactory, NE= Not Evaluated

Come back to

File No. _____

[illegible]

File No. _____

[illegible]