



200 North Lake Street • Cadillac, Michigan 49601
231.775.0181 • fax 231.775.8755
www.cadillac-mi.net

IN THE MATTER OF

USER NAME: Cadillac Casting Inc.
ADDRESS: 1500 Fourth Avenue
Cadillac, MI 49601
PERMIT NO: 590-11

NOTICE OF VIOLATION
FOR PERMITTED USER

LEGAL AUTHORITY

The following findings are made and order issued pursuant to the authority vested in the Wastewater Treatment Plant Superintendent under Chapter 42 Sewers of City Ordinance 2000-09. This Notice represents an enforcement action of the Cadillac Industrial Pretreatment Program (IPP), which is required by the City's discharge permit under the National Pollutant Discharge Elimination System (NPDES).

FINDINGS

WHEREAS:

1. Cadillac Casting Inc. (the DISCHARGER) discharges nondomestic wastewater containing pollutants into the sanitary sewer system and treatment works of the City of Cadillac (the CITY).
2. The SEWER USE ORDINANCE contains general discharge prohibitions for pollutants or wastewater of which no user shall contribute or cause to be contributed, as well as notification responsibilities and other requirements for nondomestic users.
3. The SEWER USE ORDINANCE Sec. 42-337 (a) prohibits the discharge of any pollutant or wastewater which will interfere with the operation or performance of the POTW. The Cadillac POTW experienced pass through of available cyanide during the months of April and May. Specifically, the POTW violated its monthly average available cyanide NPDES permit limit of 5.9 µg/L during the month of April, when the POTW monthly average available cyanide was 125 µg/L. The City completed sampling of all permitted industrial users to determine the source of elevated cyanide in June 2026. Results of this sampling indicated the source of elevated available cyanide was CCI.
4. As indicated: (x) On June 10, 2026, pollutant analysis revealed that the DISCHARGER exceeded the following specific discharge prohibitions:
Available cyanide concentration on 6/10/26 was 670 µg/L, which exceeds the City's maximum daily local limit of 4 µg/L.

() As of 20 , the DISCHARGER failed to meet the following notification responsibilities pursuant to the SEWER USE ORDINANCE:

() As of 20 the DISCHARGER failed to achieve the following other specific requirements of the SEWER USE ORDINANCE and/or the Order of the City:



200 North Lake Street • Cadillac, Michigan 49601
231.775.0181 • fax 231.775.8755
www.cadillac-mi.net

NOTICE

THEREFORE, BASED ON THE ABOVE FINDINGS, THE DISCHARGER IS HEREBY NOTIFIED THAT:

1. *It is in violation of the SEWER USE ORDINANCE.*
2. *In accordance with the SEWER USE ORDINANCE, within thirty (30) days of the date of receipt of this notice, the DISCHARGER shall respond personally or in writing to the Wastewater Treatment Superintendent advising of its position with respect to this violation.*
3. *Failure to correct this violation shall constitute a further violation of the SEWER USE ORDINANCE and may subject the DISCHARGER to escalated enforcement response. This could include civil prosecution with a maximum penalty of \$500 for each violation, or criminal prosecution with a maximum penalty of \$500 and/or three months imprisonment, as authorized by the SEWER USE ORDINANCE.*
4. *This notice, entered this 30th day of June, 2026, shall be effective upon receipt by the DISCHARGER.*

Signed: _____

Patrick Miller, WWTP Superintendent