

**Wade, Jamie (DEQ)**

---

**From:** Jeff Dietlin <utilities@Cadillac-MI.net>  
**Sent:** Monday, May 16, 2016 8:46 AM  
**To:** Wade, Jamie (DEQ)  
**Cc:** Doug Langworthy  
**Subject:** Violation

Mr. Wade,

I'm writing this to inform you on 4-19-2016 we had a pH violation of 6.34. I do not believe this was an accurate measurement. There was no rerun performed to insure this value was true or not but as Doug told you on the phone the meter will occasionally lock in before the full value is achieved. Please let us know if there will be any further action that needs to be taken.

***JEFFREY M. DIETLIN***

City of Cadillac  
Director of Utilities  
(231) 779-7346(Direct)  
(231)775-0906 (Fax)