

SITE NAME	PRMT NUM	VIOL DATE	VIOL TYPE	DMR PARAM/ SOC	MON LOC	STAT BASE	LIMIT VALUE	SAMPLE VALUE	UNIT CODE
Cadillac WWTP	MI0020257	3/1/2023	DMR value exceeds Limit value	Total Copper	Final Effluent (1)	Maximum Monthly Average	11	11.5	ug/L
Cadillac WWTP	MI0020257	3/6/2023	Compliance Schedule Not Received by Due Date	MAHL Report and Proposed Local Limits	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	4/1/2023	Compliance Schedule Not Received by Due Date	Michigan IPP Annual Report	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	7/31/2023	Compliance Schedule Not Received by Due Date	Asset Management Annual Report	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	1/26/2024	Compliance Schedule Not Received by Due Date	MAHL Report and Proposed Local Limits	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	1/26/2024	Compliance Schedule Not Received by Due Date	Draft IU Permits	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	1/26/2024	Compliance Schedule Not Received by Due Date	Updated IPP Program Procedures	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	2/21/2024	DMR not submitted by due date	N/A	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	8/1/2024	DMR value exceeds Limit value	Total Phosphorus	Prior to Disinfection	Maximum Monthly Average	0.5	0.528	mg/L
Cadillac WWTP	MI0020257	8/30/2024	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	10	14.3	mg/L
Cadillac WWTP	MI0020257	11/20/2024	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	17	23.4	mg/L
Cadillac WWTP	MI0020257	11/21/2024	DMR value does not achieve Limit value	Dissolved Oxygen	Final Effluent (1)	Minimum Daily	6	5.93	mg/L

Cadillac WWTP	MI0020257	11/21/2024	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	17	22.8	mg/L
Cadillac WWTP	MI0020257	11/25/2024	DMR value exceeds Limit value	Ammonia Nitrogen	Prior to Disinfection	Maximum Daily	2.8	3.43	mg/L
Cadillac WWTP	MI0020257	11/26/2025	DMR value exceeds Limit value	Ammonia Nitrogen	Prior to Disinfection	Maximum Daily	2.8	4.51	mg/L
Cadillac WWTP	MI0020257	1/10/2025	Compliance Schedule Not Received by Due Date	Local Limits Evaluation	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	4/17/2025	Additional Monitoring by Permittee	DMRQA Study 44	N/A	N/A	N/A	N/A	N/A
Cadillac WWTP	MI0020257	6/2/2025	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	10	11.2	mg/L
Cadillac WWTP	MI0020257	6/4/2025	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	10	10.2	mg/L
Cadillac WWTP	MI0020257	6/5/2025	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	10	11.2	mg/L
Cadillac WWTP	MI0020257	6/6/2025	DMR value exceeds Limit value	Carbonaceous Biochemical Oxygen Demand	Prior to Disinfection	Maximum Daily	10	13.2	mg/L
Cadillac WWTP	MI0020257	6/10/2025	Improper/Inadequate Sample Preservation	Ammonia Nitrogen	N/A	N/A	N/A	N/A	N/A