



Westland County
Cadillac W.W.T.P.
1-12-16

Cadillac Utilities Department

January 12, 2016

Dear Mr. Jamie Wade,

Per part 2 Section C paragraph 7 spill notification of our NPDES permit I'm writing this letter to inform you of a spill. On the morning of January 12, 2016 at 9:22 am I received a call from Larry Springberg, the leachate driver for American Waste. He informed me that there had been a leachate spill while offloading. While heading out to survey the situation I promptly contacted the Director of Utilities Jeff Dietlin to report the spill to him. Upon arrival of the incident I noticed the discharge from the truck had ended. I witnessed the tail end of the leachate running along the edge of the asphalt and ponding at a lower elevation around the bend from the truck.

At that time we took immediate actions to contain the spill. Snow berms were plowed up to help contain the ponding leachate from running toward the river. While containing the ponding I looked over the three storm drains in the area. Two of them were out of harm's way due to elevation. The third was in the direct path of the leachate. Three sand bags were placed on the storm drain in the drive and snow was pack around it to ensure no leachate enter the storm drain structure and thus eventually into the river. The leachate truck can contain up to ten thousand gallons, it was determined less than this amount was spilled. We continued to monitor the leachate at the spill. Upon the arrival of the Director of Utilities we contacted you Mr. Wade and asked you to take a look at the spill site. Together we surveyed the spill site and you gave us your recommendation for cleanup.

The frozen slush was pushed off the asphalt via a plow truck to the ponded area. All the contaminated snow was taken off the spill site, edges of the road and around the area that the leachate ponded. The dirt was scrapped down to the frost level in all the affected areas via a backhoe and loader. All contaminated material was removed and hauled to the waste water treatment plants drying beds where it can filter through and be treated by the process. All excavated areas were back filled with fresh top soil.

At this time it was believed that a leachate truck driver pulled the hose almost all the way out of the waste stream to prevent freezing. The weight and heat of the next morning's leachate delivery made the hose pliable and heavy pulling it out of the hole that secures the hose to the waste stream. To prevent this from happening in the future we will have the leachate truck drivers check the hose depth and remain in their trucks while offloading. I believe this will help reduce the risk of a spill this size from happening again. Thank you for taking time out of your day to help us with this matter.

Respectfully,

A handwritten signature in black ink, appearing to read "DL", is written over a horizontal line.

Douglas Langworthy
Assistant Water Resources Supervisor
City of Cadillac W.W.T.P.
231-775-2841

JAN 16 2016