

From: Jeffrey Fischer
To: Jeff Dietlin
Date: 5/27/2008 1:48:52 PM
Subject: Re: NPDES draft Permit

Jeff,

I apologize for the delay in getting back with you, but I have been waiting to receive a response to your comments about the whole effluent toxicity requirements of your draft permit. Unfortunately, I still have not received anything...however, I can respond to your other comments.

Regarding the monthly average limitations for CBOD5 (4 mg/l), and Ammonia Nitrogen (0.5 mg/l). Based on an review of the information provided by our assessment section, these are advanced wastewater treatment limits that are included with daily maximum limitations which are based on Dissolved Oxygen Standards and the results of computer modeling of the potential discharge impacts on the receiving water body. It is standard practice to include these monthly average limits with daily maximum limits of 10 mg/l (CBOD) and 2.0 (Ammonia), respectively. However, it is the daily maximum value that is of most importance in protecting the receiving stream in this case and; therefore, it has been determined that the permittee's current monthly average limits of 7 mg/l (CBOD) and 0.9 mg/l (Ammonia), may be retained in the reissued permit without any adverse impact.

I will follow-up with a response to your other comments as soon as possible. Your patience in this matter is greatly appreciated.

Jeff Fischer
Environmental Quality Analyst
Lakes Michigan & Superior Permits Unit
Permits Section - Water Bureau - MDEQ
Phone: (517) 335-4188
Fax: (517) 241-8133
fischerj1@michigan.gov

>>> "Jeff Dietlin" <wwtpr@Cadillac-MI.net> 5/5/2008 1:30 PM >>>

Jeff,

Did you get my e-mail?

One of the people I cc e-mailed me that they didn't get the whole thing.

I am attaching it to this just to be safe.

Jeff Dietlin