

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/9/2017 9:28:22 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jankowski, Brian (DEQ)" <JANKOWSKIB@michigan.gov>; "Jeff Dietlin" <utilities@Cadillac-MI.net>
Subject: RE: Phone Call Received Today at 9:26 AM Regarding CBOD5 Exceedance - City of Cadillac WWTP - NPDES Permit Number MI0020257

Don,
Thank you for getting back to me. I just missed your call today when I got back in the office. I wanted to let you know that I had another BOD hit today. We had a 10.7 mg/L result on our effluent sample from 10/4. Do you want me to do a written report for each incident or a report when are back in compliance? 231-510-0238 is my cell. This is the best way to reach me.
Thanks Doug

Douglas Langworthy
Assistant Water Resources Supervisor
City of Cadillac
231-775-2841

From: Brady, Donal (DEQ) [mailto:BradyD6@michigan.gov]
Sent: Monday, May 08, 2017 6:44 PM
To: Doug Langworthy
Cc: Jankowski, Brian (DEQ)
Subject: Phone Call Received Today at 9:26 AM Regarding CBOD5 Exceedance - City of Cadillac WWTP - NPDES Permit Number MI0020257

Hi Doug,

Sorry I was not available to take your call today. I was out of the office and will be out for the next 2 days. Please consider this e-mail acknowledgement of your verbal notification to the DEQ that the CBOD5 of 11.2 mg/L in the plant effluent sample from last Wednesday (5/3) exceeded the permit limit of 10 mg/L. Please submit a written report within 5 days of when you became aware of the exceedance that includes the information required by Part II, Sections C.6 and/or C.8 of the permit. The written report can be submitted to me and to Brian via e-mail. I will call you tomorrow at (231) 775-2841 to discuss.



Don Brady, P.E.
Michigan Department of Environmental Quality
Water Resources Division
Cadillac District Office
120 West Chapin Street

Cadillac, MI 49601

(231) 876-4478

BradyD6@michigan.gov