

From: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Sent: 5/12/2017 9:46:25 AM
To: "Brady, Donal (DEQ)" <BradyD6@michigan.gov>
Cc: "Jeff Dietlin" <utilities@Cadillac-MI.net>; "Jankowski, Brian (DEQ)" <JANKOWSKIB@michigan.gov>
Subject: BOD Violations (NPDES MI0020257)

Mr. Brady,

As per our permit required by Part II, Sections C.6 and C.8. I am submitting a written report of our recent BOD violations. Our daily limit of 10mg/L was exceeded on 5/3 with an effluent reading of 11.2mg/L, on 5/4 with an effluent reading of 10.7mg/L and 5/5 with an effluent reading of 13.8mg/L. I believe the underlying cause of the is the colder weather we've had with the plants seasonal turn over. The weather has been more cooperative in recent days and a minor increase in waste activated sludge has shown overall improvement in the plants efficiency. I anticipate we will be back in compliance in the coming days.

Thanks Doug

Douglas Langworthy

Assistant Water Resources Supervisor

City of Cadillac

231-775-2841