

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: 12/19/2018 3:33:04 PM
To: "Berdinski, Thomas (DEQ)" <BERDINSKIT@michigan.gov>
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Tom –

Thanks for the reply. If there are no different requirements for biosolids, I think we'll just stay with Test America and the Modified Method 537 (isotope dilution). We will have them run a % solids.

Thanks,

Cindy A. Tomaszewski
Lab Supervisor

From: Berdinski, Thomas (DEQ) [mailto:BERDINSKIT@michigan.gov]
Sent: Wednesday, December 19, 2018 2:57 PM
To: Cindy Tomaszewski
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Hello Cindy,

My understanding is either method can be used, but I have only personally seen ASTM 7979 used on wastewater samples. I have seen 537 Modified (isotope dilution methods) on wastewater and biosolids samples. I have seen biosolids data from numerous labs – Test America, Eurofins, Trident, I can recall off the top of my head. The important thing is to also get a % solids result so the data can be reported as ug/kg.

I hope this helps? Thanks for your ongoing efforts under the IPP PFAS initiative.

Tom

Thomas P. Berdinski
Senior Environmental Quality Analyst
DEQ-Water Resources Division
Grand Rapids District Office
616-356-0212
berdinskit@michigan.gov

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: Wednesday, December 19, 2018 9:18 AM
To: Berdinski, Thomas (DEQ) <BERDINSKIT@michigan.gov>
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes
Importance: High

Tom –

Our Director, Jeff Dietlin, has informed me that you would like us to test our biosolids for PFAS. Is there a required or preferred method to be used for the biosolids matrix? Any lab(s) you already have a positive track-record with for this matrix? Jeff would like to collect the sample before the top of the year, so any guidance you can give me (quickly) is appreciated. Thank you,

Cindy A. Tomaszewski

Lab Supervisor

From: Berdinski, Thomas (DEQ) [<mailto:BERDINSKIT@michigan.gov>]
Sent: Wednesday, August 1, 2018 1:24 PM
To: Cindy Tomaszewski
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Cindy,

The little bit of methodological comparison that we've either conducted or seen data on show very comparable results using a "modified" Method 537 with isotope dilution and ASTM 7979. The ASTM method has higher reporting limits (on the order of 10 ppt vs. 2 ppt for the "modified" 537). WMRPD's position is that they accept data from either method (same as WRD's) for landfills but we will want to see the QA/QC package as well.

I hope this is helpful.

Tom

Thomas P. Berdinski
Senior Environmental Quality Analyst
DEQ-Water Resources Division
Grand Rapids District Office
616-356-0212
berdinskit@michigan.gov

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: Tuesday, July 31, 2018 1:04 PM
To: Berdinski, Thomas (DEQ) <BERDINSKIT@michigan.gov>
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Tom –

Thank you for the reply and information.

Is there a preference (recommended or required) regarding the analytical method used? I am hearing differing opinions regarding Mtd. 537 Mod vs. ASTM D7979 (from commercial labs and our IPP

peers). Do you know which method the WMRPD is planning to use when testing landfills (later this Fall)? Our only IPP Probable Source is landfill leachate.

Any guidance is appreciated. Thank you,

Cindy A. Tomaszewski

Lab Supervisor

From: Berdinski, Thomas (DEQ) [<mailto:BERDINSKIT@michigan.gov>]
Sent: Wednesday, June 27, 2018 10:42 AM
To: Cindy Tomaszewski; Jeff Dietlin
Cc: Doug Langworthy
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Cindy,

Sorry for the delay. I have been told that the "General PFAS Sampling Guidance" is still not available. However, the "Wastewater PFAS Sampling Guidance", although it refers to "General" guidance, contains what is needed. We would like to see the "General" guidance released because it will have the list of acceptable sunscreens, but beyond that we are not aware of anything that isn't covered in the "Wastewater" guidance. Many POTWs have successfully completed their PFAS sampling since the "Wastewater" guidance was released (and many did so even before it was released, following their contract laboratory's guidelines) so I don't think you need to delay until the "General" guidance is released. That said, if you have any specific questions about something in the "Wastewater" guidance, please feel free to call or email me and I will do my best to get answers.

Only PFOS and PFOA are required for Probable Source monitoring, but as we indicated during the IPP-PFAS Regional Meetings, the "Suggested PFAS Laboratory Analytes" (a draft during the meetings, but now a finalized list) are recommended. This list remains a recommendation, so a shorter list is acceptable. We feel the full list will be the most helpful, but it is not required. Also, remember to confirm with your contract lab that these are wastewater samples to ensure will be analyzed under appropriate (modified) method.

I hope this helps. Again, I apologize for the delays.

Tom

Thomas P. Berdinski
Senior Environmental Quality Analyst
DEQ-Water Resources Division
Grand Rapids District Office
616-356-0212
berdinskit@michigan.gov

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: Tuesday, June 26, 2018 10:54 AM

To: Berdinski, Thomas (DEQ) <BERDINSKIT@michigan.gov>; Jeff Dietlin <utilities@Cadillac-MI.net>
Cc: Doug Langworthy <dlangworthy@Cadillac-MI.net>
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Tom –

Any word on finding this document?

We would like to move forward with sampling our IPP Probable Source(s). However, without this reference document (General PFAS Sampling Guidance), I am concerned about being able to properly comply with the WW PFAS Sampling Guidance.

Additionally, is it required (or recommended) that we analyze any IPP Probable Source samples for the (recently amended) full “Suggested PFAS Laboratory Analytes” list? Or a partial list? Or just PFOS and PFOA? We are considering using PACE Labs (MN) for our analysis, because we have a favorable lab history/relationship with that company. However, they are currently only offering “21 PFAS compounds” by Method 357 (rev 1.1) modified.

Please advise on how we should proceed. Thank you,

Cindy A. Tomaszewski

Lab Supervisor

From: Berdinski, Thomas (DEQ) [<mailto:BERDINSKIT@michigan.gov>]
Sent: Thursday, June 07, 2018 2:25 PM
To: Cindy Tomaszewski; Jeff Dietlin
Cc: Doug Langworthy
Subject: Re: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Cindy,

I am trying to track it down. I had seen drafts of it but I am uncertain if or where it is published. I'll get back to you as soon as I have information.

Thanks,
Tom

Thomas Berdinski
DEQ-WRD
Berdinskit@michigan.gov
616-356-0212

From: Cindy Tomaszewski <ctomaszewski@Cadillac-MI.net>
Sent: Thursday, June 7, 2018 10:15:20 AM
To: Jeff Dietlin; Berdinski, Thomas (DEQ)
Cc: Doug Langworthy
Subject: RE: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Tom –

In The DEQ “Wastewater PFAS Sampling Guidance” there are several references to the “General PFAS Sampling Guidance”. Where can we find that document?

Thanks,

Cindy A. Tomaszewski

Lab Supervisor

From: Jeff Dietlin
Sent: Thursday, June 07, 2018 8:00 AM
To: Cindy Tomaszewski
Cc: Doug Langworthy
Subject: FW: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Jeffrey M. Dietlin

City of Cadillac
Director of Utilities
(231) 779-7346(Direct)
(231)775-0906 (Fax)

From: Berdinski, Thomas (DEQ) [<mailto:BERDINSKIT@michigan.gov>]
Sent: Friday, June 01, 2018 1:31 PM
To: Mike Barricklow; Marc Middlestadt; Dave Cushway (dcushway@ci.big-rapids.mi.us); John Barthels (jbarthels@infralt.com); Ryan Vredevelde; Anderson, Kurt (kanderso@grand-rapids.mi.us); 'swheat@greenvillemi.org'; George B. Holzworth (gholzworth@hastingsmi.org) (gholzworth@hastingsmi.org); Bunschoten, Gary; Chris Kenyon; Imbault, Eric; James Schoolcraft; Oostindie, Dave (DOostindie@wyomingmi.gov); Doug Engelsman; Mic Joynt; John Fibley; Dave Krohn; Johnson, Dave; Rob Edgar; Brian.VanderMeulen@suez-na.com; Mark Fowler; Jeff Dietlin; sbrown@infralt.com; ccossette@ci.ludington.mi.us; curtbrackenrich@gmail.com; elizabeth.hart@ch2m.com; Bscull@cityofsaline.org; dsweeiris@cityofallegan.org; rebeardslee@battlecreekmi.gov; bbelfy@qtm.net; bonsonh20@hotmail.com; jwilliams@cityofbuchanan.com; kdey@coldwater.org; ecclerk@sbcglobal.net; bzgrsd@sbcglobal.net; cohwwtp@frontier.com; rochows@kalamazoocity.org; bpond@plainwell.org; utility.manager@quincy-mi.org; dmulac@south-haven.com; Tsikorski@sturgismi.gov; dhumbert@threeriversmi.org; vllgwwtp@elkrapids.org; lkeyzer@cityofotsego.org; Jouzts@fv-operations.com
Cc: Veldkamp, Christine (DEQ); Bauer, Christina (DEQ); Hollenbach, Heidi (DEQ); Taylor Morgan, Joy (DEQ); Worm, Michael (DEQ); McElmurry, Ashley (DEQ); Shattuck, Terri (DEQ)
Subject: IPP PFAS Initiative Sampling Guidance, Suggested Analytes

Hello all,

The DEQ “Wastewater PFAS Sampling Guidance” has been published and is available online. This guidance aligns with the sampling information that was presented at the IPP PFAS Regional Meetings. In

addition, the list of "Suggested PFAS Laboratory Analytes" has been finalized. Both documents have been posted to the IPP website. Links to both these items are www.mi.gov/ipp.

Please let me know if you have any questions.

Thanks,
Tom

Thomas P. Berdinski
Senior Environmental Quality Analyst
DEQ-Water Resources Division
Grand Rapids District Office
616-356-0212
berdinski@michigan.gov