

MILL TEST CERTIFICATE

THE INSPECTION CERTIFICATE AS PER EN 10204 CLAUSE 3.1 CONFORMING TO THE DEFINITION IN EN 10168

12.02.2026

CERTIFICATE NO	218-2026
COMMODITY	
STANDARD OF GRADE OF PRODUCT	EN 10025-1-2 / 2019
SIZE AND SHAPE TOLERANCES STANDARDS	EN 10279 FOR U, EN 10024 FOR I, 10034 FOR I-H, EN 10058 FOR FLAT, 10059 FOR SQUARE, 10060 FOR ROUND STANDARDS APPLY
TEST STANDARDS	EN ISO 6892 -1/ EN ISO 148-1
DELIVERY REQUIREMENTS STANDART FOR SURFA	EN 10163-3

SHIPPER	MESCIER D.Ç. SAN. TIC. AŞ. ŞTİ.		
CUSTOMER	YAKUP YILMAZ BORU PROFİL YAPI MALZEMELERİ İNŞAAT MAKİNA DİŞ TİCARET SANAYİ VE TİCARET ANONİM ŞİRKETİ TURGUT ÖZAL 2 BLV. 06080 GÜLTEPE MAH. ALTINDAĞ/ ANKARA		
VESSEL			
İRSALİYE NO:			
ORDER NO		PAGE	

							MECHANICAL PROPERTIES					CHEMICAL COMPOSITION																		
TEST PIECES NO	HEAT NO	SIZE (mm)	QUALITY	PCS (BN DL)	LENG HT (m)	WORK ORDER	TENSION TEST				CHARPY TEST			PRODUCT ANALYSIS																
							YIELD S. (Re)	TENSILE S. (Rm)	Rm / Re	ELONGATION	TEST PIECES WIDTH (mm)	AVERA VALUE (Joule)	TEST TEMPERATURE(°C)	C	Si	Mn	P	S	Ti	Cu	Ni	Cr	Mo	V	Al	W	Nb	N	CARBON EQUIVALENT	
N/mm2		%					%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	%	(CEV)						
	25M113274	50X50X5	S235JR					330,2	475,9	1,44	33,0				0,14	0,23	0,6065	0,013	0,036	0,004	0,27	0,11	0,07	0,007	0,0001	0,004	0,0247	0,004	0,007	0,28
	25M123742	60X60X6	S235JR					313,4	450,5	1,44	30,0	5	94	23	0,10	0,23	0,548	0,010	0,006	0,001	0,15	0,19	0,18	0,021	0,012	0,022	0,014	0,003	0,000	0,26
	25M123660	80 NPI	S235JR					329,4	466,1	1,41	31,7				0,11	0,16	0,567	0,015	0,018	0,001	0,19	0,11	0,16	0,000	0,011	0,007	0,016	0,003	0,000	0,26

SURVEYOR TO	NOTES:	WE HEREBY CERTIFY THAT THE MATERIAL HEREIN HAS BEEN MADE AND TESTED IN ACCORDANCE WITH ABOVE SPECIFICATION AND THE RESULTS OF ALL TEST ARE ACCEPTANCE	QUALITY CONTROL DEPARTMENT
  		(1) VALUES ARE FOR KV300 (2) BEND AND REBEND TESTS ARE FOR ONLY RIBBED REINFORCING STEELS (3) "L" MEANS "LOGITUDINAL" "T" MEANS "TRANSVERSE" (4) (NUMBER OF CYCLES X 1000000)	

QUALITY CONTROL DEPARTMENT

MESCIER®
KARABÜK Ü.D. 019 052 9911