

Report Control Number: \_\_\_

#### **ENVIRONMENTAL MANAGEMENT BUREAU REGION 8**



# COMPLIANCE INSPECTION FOR AIR QUALITY MANAGEMENT

IRONMENTAL	MONITORING	AND ENFORCEMENT	DIVISION-WATER	AIR QUALITY	MONITORING SECTION

Date of Inspection: 18 January 2022 Mission Order No.: Desk Monitoring (SMR Evaluation) 1. GENERAL INFORMATION Name of Establishment: Esperas Crushing Plant (Proponent: Christopher Randy Esperas) Address: Brgy. Basper Tacloban City Geo Coordinates: 11.1458°N, 124.5734°E Nature of Business: Refueling Station PSIC Code: 0810 Year Established: 2019 Product: Gravel aggregates Operating hours/day: 8 hours Operating days/week: 6 days Operating days/year: **Product Lines** Production Rate as Declared in Actual Production Rate (unit/day) the ECC (unit/day) Crushed stones 26 tons/hour Name of Managing Head: **Christopher Randy Esperas** Name of PCO: Claro Francisco 2019-RVIII-0163 Date of Effectivity: PCO Accreditation No.: 11/22/2019 - 11/22/2022 Phone/Fax: 0917 568 8200 / 0966 365 9945 Email: clarofrancisco40@gmail.com 2. PURPOSE OF INSPECTION ☐ Verify accuracy of information submitted by the establishment pertaining to new permit applications, renewals, or modification New Renewal New Renewal PMPIN Application П Hazardous Waste ID Registration Hazardous Waste Transporter Registration Hazardous waste TSD Registration Permit to Operate Air Pollution Control Installation Discharge Permit Others Determine compliance status with the environmental regulations, permit conditions, and other requirements ☐ Investigate community complaints ☐ Check status of voluntary commitment Industrial Ecowatch Philippine Environmental Partnership Program (PEPP) Pollution Adjudication Board (PAB) Others ☐ Others Name of Contact Person Position / Designation

# 3. COMPLIANCE STATUS

3.1 DENR Permits/Licenses/Clearance

<b>Environmental Law</b>		Permits	Date of Issue	Expiry Date	
	ECC1	ECC-OL-R08-2019-0086	05/24/2019	N/A	
PD 1586	ECC2				
	ECC3	-			
	DENR Registry ID	-			
RA 6969	PCL Compliance Certificate	-			
	CCO Registry	-			
	Permit to Transport	-			
RA 8749	POA No.	PTO-OL-R08-2021-02578	04/29/2021	04/29/2026	
RA 9003	ECC for Sanitary Landfill	-			
RA 9275	DP No.	DP-R08-20-06615	12/28/2020	12/28/2021	

# MODULE AQM01: PRE-INSPECTION INFORMATION SHEETFOR EMISSION SOURCES

Emission Source No.	1
Type (Brand/Model)	Jaw Crusher
Rated Capacity	26 tons/hour
Fuel Type & Quantity	Electric-powered
Operating Capacity	
Control Facility	Water sprinkler

Emission Source No.	2
Type (Brand/Model)	Powercity generator set
Rated Capacity	75 KVA
Fuel Type & Quantity	Diesel
Operating Capacity	
Control Facility	Muffler

Legal Provision	Regulatory Requirements Complia			iant	Notes
		Y	N	N/A	
DAO 2004-26	A sharp resident				
Rule 19 Section 1	All emission sources have a valid Permit to Operate	/			
Rule 19 Section 3	As built design of the installation conforms with submitted engineering plans and specifications	/			
	Declared control facilities are installed and operational	/			
	Installation is located as proposed in the vicinity map (plant and machinery layout)	1			
	Facility design capacity is within the capacity declared in the application for permit to operate	1			
Rule 19 Section 5	Temporary Permit is still valid			/	
Rule 19 Section 6	Application for renewal has been filed for expiring Permit to Operate 30 days before permit expiration date			1	
Rule 19 Section 9	Permit to Operate displayed conspicuously upon the installation or in an accessible / visible place near the installation	1			
	Conditions of the Permit to Operate are complied with	/			

Rulle 19 Section 11 Plant operational problems notification submitted to EMB within 24 hours of occurrence			/			
Rule 19 Section 12	Quarterly submission of self- monitoring report	1		Q <sub>1</sub> 05/20/2021 Q <sub>2</sub> Q <sub>3</sub> Q <sub>4</sub>		
DAO 2000-81						
Part 7 Rule 25 Section 5 a#	Person in charge of the plant /	T	1			
1	equipment has sufficient measure to ensure that no dark smoke is discharging from any stack in the					
	establishment. E.g.: window view of stack, mirror to reflect top of stack, smoke density indicator, CCTV, etc.					
Part 7 Rule 25 Section 5 a# 2	All oil-burning equipment have heaters capable of heating oil to a temperature appropriate for the oil and burner		/			
Part 7 Rule 25 Section 5 a# 3	Establishment is fossil fuel-fired power plant over 10MW rating installed with CEMS for particulates, sulfur oxide, and NOx		/			
	Establishment is petroleum refinery / petrochemical industry installed with CEMS for particulates, sulfur oxide, and NOx		/			
	Establishment is primary copper smelter installed with CEMS for particulates, sulfur oxide, and NOx		/			
	Establishment is steel plant installed with CEMS for particulates and sulfur oxide		/			
	Establishment is ferro-alloy production facility installed with CEMS for particulates		/			
	Establishment is cement plant installed with CEMS for particulates		/			
Part 7 Rule 25 Section 5 b	Miscellaneous equipment like reheating furnace, smoke oven, bake oven, coffee heaters, varnish kettles, etc. are installed with pollution control facilities		/			
Part 7 Rule 25 Section 13 a	Establishment has precautionary controls for dusts generated during vehicular movement, transportation of materials, construction, etc. (List controls identified)		/			
Part 7 Rule 25 Section 13 b	Establishment has precautionary controls for volatile organic compounds or organic solvent emissions generated during storing, pumping, handling, processing, etc. (List controls identified)		/			
Part 7 Rule 25 Section 13 d	No open burning activity in the establishment	1				

MC 2009-04	Standby Gensets with capacity		/	
	greater than or equal to 1,250 KW			
	undergo annual emission testing			
	(with 3 test runs). These gesets			
	should not have the potential to emit			
	more than 100tons/year of regulated			
	pollutant.			
MC 2007-003 (2)	Boiler rated at greater than or equal		1	
	to 251HP undergo bi-annual			
	emission testing (with 3 test runs)			
	Other sources that have potential to		/	
	emit equal to or greater than			
	100tons/year of regulated pollutant			
	undergo bi-annual emission testing			
	(with 3 test runs)			
	Boiler rated between 100 to 250 HP	-	,	
	undergo annual emission testing		/	
	(with 3 test runs)			
	Diesel generator rated at 600 to		,	
	1,249KW undergo annual testing	'	/	
	(with 3 test runs)			
	Other sources that have potential to	-	/	
	emit greater than 30 but less than	1 1 3	/	
	100tons/year of regulated pollutant			
	undergo annual emission testing			
	(with 3 test runs)			
	Sources of emissions of hazardous		/	
	air pollutants included in PCL (DAO			
	1998 -58) undergo bi-annual			
	emission testing (with 3 test runs)			
	Emission sources of petroleum	+ +	/	
	refinery undergo bi-annual emission	'		
	testing (with 3 test runs)			
	Emission sources of petrochemical		/	
	works undergo bi-annual emission			
	testing (with 3 test runs)			
	Emission sources of smelters	-	,	
	undergo bi-annual emission testing		/	
	(with 3 test runs)			
	(,			
	1.7			
	Emission sources of cement kilns		/	
	undergo bi-annual emission testing			
	`with 3 test runs)			
	Emission sources of stack walking	+	,	
	Emission sources of steel -making plants undergo bi-annual emission	/		
	testing (with 3 test runs)			
	Emission sources of ferro-alloy-		/	
	making plants undergo bi-annual			
	emission testing (with 3 test runs)			
			1	

	Emission sources of glass-making plants undergo bi-annual emission testing (with 3 test runs)	1	
	Boiler rated at 99HP or less undergo biennial emission testing (with 3 test runs)	/	
	Diesel generator rated at 599KW or less undergo biennial emission testing (with 3 test runs)	/	
	Other sources that have potential to emit at least 10tons/year but less than 30tons/year of regulated pollutant undergo biennial emission testing (with 3 test runs)	1	
	Source using Bunker Fuel Oil, blended fuels involving Bunker Fuel Oil, or sulfur content of 1% or more undergo bi-annual emission testing	/	
Appendix F (Quality A	Assurance Procedures)		
Section 6 (8)	Notification has been sent to EMB for any changes made in the CEMS installation	/	
	Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control plan	/	
Section 6 (5)	Each CEMS is audited and conducted in accordance to CFR 40 part 60 Appendix F.	/	
Section 6 (6)	Relative Accuracy Test Audit (RATA) is performed annually by industries in the presence of EMB personnel.	/	
	Establishment has sent thirty (30) day notice to EMB prior to the RATA testing schedule	/	
0	Calibration gases are subject to audit	/	
Section 6 (7)	or relative accuracy audit test every quarter		

Section 6 (9)	EMB Director and Regional Director have been notified of CEMS malfunction that lasted longer than seven (7) consecutive days.	/	
Section 7 (1)	Records of occurrence and duration of any start-up, shut-down or malfunction in the operation of any source or control facility is available in the establishment.	1	
Section 7 (2)	Records of audits, performance testing, evaluations, calibration checks, adjustments and maintenance of any continuous emission monitors that have been installed pursuant to Rule IX Section 5 of DAO 2000-81 are available in the establishment.	/	
Section 8 (1)	SMR includes data on the time intervals, date and magnitude of excess emissions, nature and cause of excess, corrective actions taken, and preventive measures adopted.	/	
Section 8 (2)	SMR includes information on the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question.	/	
Section 8 (3)	SMR includes information on time and date for each period during which the continuous monitoring system was inoperative and the nature of system repairs and adjustments made in the CEMS/COMS	1	
Section 8 (4)	SMR data measurements are within 75% data capture?	1	
For Facilities Engaged with	h Consent Agreement		
EMS established within 18 months upon entering Consent Agreement with EMB	EMS established within 18 months upon entering Consent Agreement with EMB	1	
DAO 2000-81 Part 7 Rule 25 Section 9b	Environmental Management Plan derived from EMS process submitted within 6 months after entering Consent Agreement with EMB	1	

## Other Observations:

- · Esperas Crushing Plant is operational.
- As per valid Permit to Operate (PTO), the Firm has a one (1) unit Jaw Crusher with a crushing capacity of 26 tons/
  hour and a one (1) unit 75 KVA Powercity generator set as standby power source. The PTO is valid until April 29,
  2026. As per SMR submitted, the Jaw Crusher has only produced 2,250 MT for a quarter, equating to an average of
  10,000 MT produced crushed stones for 2021 which is within the required annual production capacity of 65,000 MT
  per valid PTO. Likewise, generator set had only been operated for an average of 2 hours for a quarter.
- Only one (1) SMR had been submitted online.
- PCO for the gas station is accredited until November 22, 2019.
- As per Records, Discharge Permit issued to the Firm had already expired.

All Modules of the submitted SMR online has been properly supplied with the necessary data and information. Module
 4 has been supplied with data as to operation and fuel consumption of the present air pollution source equipment.
 SMR was received as sufficient.

### Remarks and Recommendation:

- The Permittee is to strictly comply with the frequency on the submission of the SMR including submission of the Compliance Monitoring Report online.
- · The Permittee is to renew its Discharge Permit online.
- For issuance of Notice/Letter to comply with the abovementioned recommendations.

## List of Documents Reviewed:

Copy of ECC, SMR online, PTO, DP,

Submitted by:

LEDANE JON LAURENTE

Approved by:

FOR. MANUEL J. SACEDA, JR OIC Chief, ENED Recommending Approval:

Engr. CARLOS A. CAYANONG Chief, WAQMS

Noted by:

OIC Regional

FM-EMED-55 00 08-01-19



## Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City



#### DISPOSITION FORM

Doc. Date: January 19, 2022

Company Name: ENVIRONMENTAL MANAGEMENT BUREAU -

IIS No. : R8-2022-004086 REGION VIII (EASTERN VISAYAS)

Subject / Title: Inspection Report AIR (Desk Monitoring/SMR Evaluation) - Esperas Crushing Plant

#### TO: All Officials/Personnel Concerned:

Please accomplish and route this properly with the corresponding attached communication/documents. The Official or employee in-charge to whom this document is routed shall act promptly and expeditiously without discrimination as prescribed in the SECSIME or within fifteen (15) working days from receipt thereof, failure to do is punishable by LAW under RA 6713 and negligence to Memorandum Circular No. 44 issued by the Office of the President of the Philippines "Directing all Government Agencies and Instrumentalities, including government-owned or controlled corporations to respond to all public requests and concerns within 15 days (15 from the receipt thereof)

For strict compliance.

		I	ROUTED	
BY (Official Code/ Sender Initial)	DATE (mm/dd/yy)	TO (Official Code/ Receiver Initial)	TIME (AM/PM)	ACTION   REMARKS   STATUS
Ledane Joy Y. Laurente	01/19/2022	Carlos A. Cayanong	04:16 PM	For initial/signature.
On	1-19	MS	805	H
C.EMED	01/20/22	0.0	•	4. 282
J. INOPIA	2 1 JAN 2022	HEA	8:35m	J
RD	IAN 2 1 2022	EMED/	9:44~	Noted Birrel
	UAII E I COCC	Nin		1127

#### Use code for comment/instruction and desired action:

A - For information / guidance / reference

B - For comments / recommendations

C - Pls. take up with me

D - Pls. draft answer memo

E - Pls. appropriatte action

F - Pls. immediate investigation

G - Pls. Attach supporting papers

H - Pls. for approval

I - For initial/signature

J - For study/evaluation

K - Pls. release/file

L - Update stat of case

#### Important Reminder!

Do not tamper. Continue on separate sheet if necessary. Attach this always with the document to be routed as this shall form an integral part of the document process.