



Republic of the Philippines
Department of Environmental and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-10-88

Date: Oct 06, 2021

Permit No.: DP-R08-21-06478
New

WASTEWATER DISCHARGE PERMIT

Pursuant to Section 14, Article 2, of the RA 9275 otherwise known as the "Philippine Clean Water Act of 2004", this permit is hereby granted to **Lgu Tacloban City** with office address at Kanhuraw Hill, Cenro Office (Igu Tacloban City), Barangay 25, Tacloban City (Capital), Leyte for its establishment:

Two (2) Units Two-storey Public Market Building	Barangay 37 TACLOBAN CITY (Capital)
(Igu Tacloban City)	
TIN No. 000-608-920-000	

To discharge **Commercial Wastewater** into **Anibong Bay (Class SC)** subject to the following conditions:

1. The discharge rate of the effluent shall not exceed **2.932 m3/day** after treatment at the **Wastewater Treatment Facility (WTF)** and shall comply with the following standard:

Parameter	Standard	Parameter	Standard
Color	150 TCU	TSS	100 mg/L
Temperature	3 °Change	Ammonia	4 mg/L
pH	6.0-9.0	Nitrate	20 mg/L
BOD	100 mg/L	Oil & Grease	10 mg/L

** Reference for effluent parameters: DAO 2016-08; PSIC Code - OC1*

2. Consider the installation of a **Sewerage Treatment Plant (STP)** for a complete treatment of the generated wastewater prior discharging.
3. Institute measures on the operation of your **WTF** so as to have effluent conforming with the prescribed standard.
4. The maximum wastewater generation of **2.866 m3/day** shall be from the washing/cleaning activities.
5. The maximum wastewater generation of **0.066 m3/day** shall be from the domestic wastes.
6. Submit Self-Monitoring (SMR) based on the following schedule: *(Online submission at <https://client.emb.gov.ph/smr>)*

Quarter	Coverage	Submission	Quarter	Coverage	Submission
First	Jan-Mar	1-15 Apr.	Third	Jul-Sep.	1-15 Oct.
Second	Apr-Jun.	1-15 Jul.	Fourth	Oct-Dec.	1-15 Jan.

7. Include effluent analysis on the **BOD, pH, Temperature, Nitrate, & TSS** parameters, conducted by EMB RVIII Laboratory, at least **two (2) months** prior to the expiration of this permit.
8. Include effluent analysis on the other remaining parameters, conducted by Third Party Laboratory duly recognized by EMB, at least **two (2) months** prior to the expiration of this permit.
9. Submit **BOD & TSS** analysis of the abstracted water or source of your water supply. (e.g. deep well water, tap water, water distributed by peddlers, etc.) conducted by EMB RVIII Laboratory, at least **two (2) months** prior to the expiration of this permit.



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.


- 10. Provide accessible sampling port at the effluent side of your **WTF** at all times.
- 11. Channel your wastewater generation (washing/cleaning & domestic) into your **WTF - Septic Tank**.
- 12. Submit Certificate of desludging/siphoning of the **Septic Tank** and treatment of the same by an accredited service provider.
- 13. Renew the Certificate of PCO Accreditation not later than **July 6, 2024**.
- 14. Allow the entry of our duly authorized representative(s) to conduct inspection within your premises.
- 15. This permit, together with the corresponding Official Receipts of Payment, shall be adequately framed and posted in a conspicuous place at the plant/establishment.
- 16. This permit shall be renewed not less than **thirty (30) days** prior to its expiration.

This permit is valid up to Oct 06, 2022, unless revoked or suspended by this Office in writing.

Non-compliance with the above conditions and/or any pertinent provisions of RA 9275 otherwise known as "Philippine Clean Water Act of 2004", a corresponding penalty in the amount of P10,000-P200,000 per violation shall be imposed.

Recommended by:

Approved by:


MARIBEL B. MUNSAYAC
Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
OIC-Regional Director

Permit Fee	: Php 2000.00	O.R. No. : 4739634	Date : 29 Sept. 2021
Filing Fee	: Php 55.00	O.R. No. : 4737205, 4736929, 4739634	Date : 29 Sept. 2021
PD1856	: Php 10.00	O.R. No. : 4737205, 4736929, 4739634	Date : 29 Sept. 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4737205, 4736929, 4739634	Date : 29 Sept. 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.