



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-10-88

Permit No: PTO-OL-R08-2021-06584-R
Application Type: Renewal

Date Issued: 23 Aug 2021
Date Expiration: 23 Jul 2024

PERMIT TO OPERATE
Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

**OSPA - FARMERS' MEDICAL CENTER (OSPA -
FARMERS' MEDICAL CENTER)**

Carlota Hills, Can-Adieng, Ormoc City, Leyte

subject to the following terms and conditions:


TERMS AND CONDITIONS

AMENDED

1. This Permit is issued for the permittee to operate **one (1) unit "JOHN DEERE" Diesel Generator Set** rated at **300 KW**, **one (1) unit "JOHN DEERE" Diesel Generator Set** rated at **100 KW**, and **one (1) unit "PERKINS" Diesel Generator Set** rated at **115 KW**, for the purpose of **Standby Power**, respectively at the permittee's establishment identified on this Permit. **(Refer to attached Annex at page 2)**
2. Any application for renewal of this Permit shall be filed **not less than thirty (30) days** before the expiry date indicated on this Permit.
3. This Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
 - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749; and
 - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
5. The permittee shall submit Self-Monitoring Reports to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the **first Report** on or before **October 15, 2021**. Online submission at <https://client.emb.gov.ph/smr>
6. The permittee shall at all times have an appointed or designated Pollution Control Officer (PCO) pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall burn only **Diesel Fuel Oil** in the **one (1) unit 300 KW "JOHN DEERE" Standby Diesel Generator Set** for not more than **500 annual operating hours** for the whole duration of the permit validity.
10. The permittee shall burn only **Diesel Fuel Oil** in the **one (1) unit 100 KW "JOHN DEERE" Standby Diesel Generator Set** for not more than **500 annual operating hours** for the whole duration of the permit validity.
11. The permittee shall burn only **Diesel Fuel Oil** in the **one (1) unit 115 KW "PERKINS" Standby Diesel Generator Set** for not more than **500 annual operating hours** for the whole duration of the permit validity.
12. The permittee paid the permit fee (2,500.00) under OR no. 7154545 dated June 27, 2019.

Recommended by:

Approved by:


MARIBEL B. MUNSAAYAC
Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
OIC-Regional Director

Filing Fee : Php 600.00
Permit Fee : Php 3000.00
PD1856 : Php 10.00
Documentary Stamp Tax : Php 30.00

O.R. No. : 7154545, 4736301 D, 4737036 D
O.R. No. : 7154545, 4736301 D, 4737036 D
O.R. No. : 7154545, 4736301 D, 4737036 D
O.R. No. : 7154545, 4736301 D, 4737036 D

Date : July 26, 2021
Date : July 26, 2021
Date : July 26, 2021
Date : July 26, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
91015	POWER GENERATOR	300.0 KILOWATTS	JOHN DEERE	DIESEL	---
91020	POWER GENERATOR	100.0 KILOWATTS	JOHN DEERE	DIESEL	---
91021	POWER GENERATOR	115.0 KILOWATTS	PERKINS	DIESEL	---

Filing Fee	: Php 600.00	O.R. No. : 7154545, 4736301 D, 4737036 D	Date : July 26, 2021
Permit Fee	: Php 3000.00	O.R. No. : 7154545, 4736301 D, 4737036 D	Date : July 26, 2021
PD1856	: Php 10.00	O.R. No. : 7154545, 4736301 D, 4737036 D	Date : July 26, 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 7154545, 4736301 D, 4737036 D	Date : July 26, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.