



Republic of the Philippines  
Department of Environmental and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
**Region VIII**  
DENR Compound, Jones Street, Barangay 2, Tacloban City  
Tel No: (053) 832-10-88

Date: Dec 15, 2021

Permit No.: DP-R08-21-08336  
**Renewal**

**WASTEWATER DISCHARGE PERMIT**

Pursuant to Section 14, Article 2, of the RA 9275 otherwise known as the "Philippine Clean Water Act of 2004", this permit is hereby granted to **Religious Sisters Of Mercy** with office address at Benigno Aquino Avenue, Barangay 50-B, Tacloban City (Capital), Leyte for its establishment:

<b>Mother Of Mercy Hospital Tacloban Inc.</b>	Benigno Aquino Avenue Barangay 50-B TACLOBAN CITY (Capital)
TIN No. 288-339-65-000	

To discharge **Commercial Wastewater** into **Mangonbangon River (Class C)** subject to the following conditions:

1. The discharge rate of the effluent shall not exceed **18.234 m3/day** after treatment at the **Wastewater Treatment Facility (WTF)** and that its shall comply with the following standard:

Parameter	Standard	Parameter	Standard
BOD	50 mg/L	Ammonia	4 mg/L
TSS	100 mg/L	Oil & Grease	10 mg/L
Temperature	3°C Change	Nitrate	20 mg/L
pH	6.0-9.5	Surfactants	15 mg/L
Phosphate	4 mg/L	Fecal Coliform	400 MPN/100mL
Color	150 TCU		

\* Reference for effluent parameters: DAO 2016-08; PSIC Code - 86, 87

2. Institute measures on the operation of your **WTF** so as to have effluent conforming with the prescribed standard.
3. The maximum wastewater generation of **14.04018 m3/day** shall be from the washing/cleaning activities.
4. The maximum wastewater generation of **3.09978 m3/day** shall be from the washing/cleaning activities.
5. The maximum wastewater generation of **0.9117 m3/day** shall be from the domestic wastes.
6. The maximum wastewater generation of **0.18234 m3/day** shall be from the other activities (e.g. evaporation, etc.).
7. Submit Self-Monitoring (SMR) based on the following schedule: (Online submission at <https://iis.emb.gov.ph/smr>)

Quarter	Coverage	Submission	Quarter	Coverage	Submission
First	Jan-Mar	1-15 Apr.	Third	Jul-Sep.	1-15 Oct.
Second	Apr-Jun.	1-15 Jul.	Fourth	Oct-Dec.	1-15 Jan.

8. Include effluent analysis of the **BOD, TSS, Fecal Coliform, Nitrate, & Phosphate** parameters, conducted by the **EMB VIII Laboratory**, at least **two (2) months** prior to the expiration of this permit.
9. Include effluent analysis on the other remaining parameters, conducted by Third Party Laboratory duly recognized by EMB, at least **two (2) months** prior to the expiration of this permit.
10. Submit **BOD & TSS** analysis of the abstracted water or source of your water supply. (e.g. deep well water, tap water, water distributed by peddlers, etc.) conducted by the **EMB VIII Laboratory**, at least



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

**two (2) months** prior to the expiration of this permit.


- 11. Provide accessible sampling port at the effluent side of your **WTF** at all times.
- 12. Channel your domestic wastewater generation (washing/cleaning and domestic) into your **Wastewater Treatment Facility**.
- 13. Renew the Certificate of PCO Accreditation not later than **June 3, 2022**.
- 14. Allow the entry of our duly authorized representative(s) to conduct inspection within your premises.
- 15. This permit, together with the corresponding Official Receipts of Payment, shall be adequately framed and posted in a conspicuous place at the plant/establishment.
- 16. This permit shall be renewed not less than **thirty (30) days** prior to its expiration.

**This permit is valid up to Oct 15, 2022, unless revoked or suspended by this Office in writing.**

*Non-compliance with the above conditions and/or any pertinent provisions of RA 9275 otherwise known as "Philippine Clean Water Act of 2004", a corresponding penalty in the amount of P10,000-P200,000 per violation shall be imposed.*

Recommended by:

Approved by:

  
**ENGR. HENNENCY G. HAYAG**  
OIC-Chief, Clearance and Permitting Division

  
**ENGR. REYNALDO B. BARRA**  
OIC-Regional Director

Filing Fee	: Php 55.00	O.R. No. : 1944369 / 1947840 / 1945913	Date : Dec. 2, 2021
PD1856	: Php 10.00	O.R. No. : 1944369 / 1947840 / 1945913	Date : Dec. 2, 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 1944369 / 1947840 / 1945913	Date : Dec. 2, 2021
Permit Fee	: Php 2200.00	O.R. No. : 4739774/1947840	Date : Dec. 2, 2021
Water Discharge Fee	: Php 377.44	O.R. No. : 4739774/1947840	Date : Dec. 2, 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.