

ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-WATER AIR QUALITY MONITORING SECTION

Report Control Number: \_\_\_\_\_  
Date of Inspection: **February 4, 2021**  
Mission Order No.: **EMBR8-2022-005175**

<b>1. GENERAL INFORMATION</b>		
Name of Establishment: <b>St. Peterlife Memorial Homes - Maasin</b>		
Address: <b>Brgy. Pasay, Maasin City, Southern Leyte</b>		Geo Coordinates: <b>10.117598° N, 124.893485° E</b>
Nature of Business: <b>Funeral Home</b>		
PSIC Code: <b>96300</b>	Product:	Year Established: <b>2000</b>
Operating hours/day: <b>24</b>	Operating days/week: <b>7</b>	Operating days/year: <b>365</b>

Product Lines	Production Rate as Declared in the ECC (unit/day)	Actual Production Rate (unit/day)
Name of Managing Head:	<b>Maribeth M. Kangleon</b>	
Name of PCO:	<b>Nerissa C. Serdan</b>	
PCO Accreditation No.:	<b>2018-RVIII-0103</b>	Date of Effectivity: <b>08/15/2018-2021</b>
Phone/Fax:	<b>0905-203-4756</b>	Email: <b>maasinchapel@stpeter.com.ph</b>

<b>2. PURPOSE OF INSPECTION</b>		
<input type="checkbox"/> Verify accuracy of information submitted by the establishment pertaining to new permit applications, renewals, or modification		
_____ New Renewal	<b>New</b>	<b>Renewal</b>
_____ PMPIN Application	<input type="checkbox"/>	<input type="checkbox"/>
_____ Hazardous Waste ID Registration	<input type="checkbox"/>	<input type="checkbox"/>
_____ Hazardous Waste Transporter Registration	<input type="checkbox"/>	<input type="checkbox"/>
_____ Hazardous waste TSD Registration	<input type="checkbox"/>	<input type="checkbox"/>
_____ Permit to Operate Air Pollution Control Installation	<input type="checkbox"/>	<input type="checkbox"/>
_____ Discharge Permit	<input type="checkbox"/>	<input type="checkbox"/>
_____ Others _____	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/> Determine compliance status with the environmental regulations, permit conditions, and other Reauirements		
<input type="checkbox"/> Investigate community complaints		
<input type="checkbox"/> Check status of voluntary commitment		
_____ Industrial Ecowatch		
_____ Philippine Environmental Partnership Program (PEPP)		
_____ Pollution Adjudication Board (PAB)		
_____ Others _____		
<input type="checkbox"/> Others _____		
Name of Contact Person	<b>Nerissa C. Serdan</b>	
Position / Designation	Pollution Control Officer	

3. COMPLIANCE STATUS

3.1 DENR Permits/Licenses/Clearance

Environmental Law	Permits		Date of Issue	Expiry Date
PD 1586	ECC1			
	ECC2			
	ECC3			
RA 6969	DENR Registry ID	OL-GR-R8-64-008919	11/19/2020	
	PCL Compliance Certificate			
	CCO Registry			
	Permit to Transport			
RA 8749	POA No.	17-POA-E-0864-0249	05/22/2017	05/22/2022
RA 9003	ECC for Sanitary Landfill			
RA 9275	DP No.	DP-R08-21-04704	07/29/2021	07/29/2022

4. Water Supply and Wastewater Generation						
A. Water Sources						
Sources of Water Supply	Daily (m³/day)		Annual (m³/year)		Specify if Others	
Surface water (river, lakes, etc.)						
Groundwater	0.42		152			
Water utilities						
Others (specify)						
B. Wastewater Sources						
Water Use / Sources of Wastewater	Consumed (m³/day)		Generated (m³/day)		Specify if Others	
Process Water						
Domestic Water			0.2			
Cooling Water						
Maintenance						
Storm drain						
Others (specify)			0.2			
C. Quality of Abstracted Water						
Sources of Water Supply	pH	Temp	TSS	Heavy Metals		Specify if Others

5. Information on Wastewater Pollution	
A. Does the Establishment have a Wastewater Treatment Plant?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
B. What type of WWTP?	<input type="checkbox"/> Physical <input checked="" type="checkbox"/> Biological

	<input type="checkbox"/> Chemical <input type="checkbox"/> Others		
C. WWTP Detail			
1. Date Installed	January 2006		
2. Design Capacity	10 m³/day		
3. Cost of WWTP	Php 50,000		
4. Annual Maintenance Cost (Php/year)			
5. Location of Discharge Point(s)	Receiving Water Body	Classification of Water Body	
None	None		
	<input type="checkbox"/> V-weir	Other (specify)	
6. Flow Metering Device Use	<input type="checkbox"/> Flow Meter		
7. Flow Rate	Influent	Effluent	Others (specify)
A. Components of WWTP			
Primary	Biological	Chemical	Others
<input type="checkbox"/> Screening	<input type="checkbox"/> Activated Sludge	<input type="checkbox"/> pH Adjustment	
<input type="checkbox"/> Primary Treatment	<input checked="" type="checkbox"/> Anaerobic Digestion	<input type="checkbox"/> Disinfection	
<input type="checkbox"/> Grit Removal	<input type="checkbox"/> Trickling Filter	<input type="checkbox"/> Oxidation/Reduction	
<input type="checkbox"/> Oil/Water Separator	<input type="checkbox"/> Oxidation/Stabilization Pond	<input type="checkbox"/> Flocculation/Coagulation	
<input type="checkbox"/> Equalization Tank	<input type="checkbox"/> Sequencing Batch Reactor	<input type="checkbox"/> Others (specify)	
<input type="checkbox"/> Others (specify)	<input type="checkbox"/> Others (specify)		
B. Condition of the WWTP			
1. What is the general condition of the WWTP during sampling?	<input checked="" type="checkbox"/> Properly Maintained <input type="checkbox"/> Inadequately maintained <input type="checkbox"/> Poor Maintenance <input type="checkbox"/> Others		
2. Is the WWTP under construction or undergoing rehabilitation?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
3. If the answer is No. 2 is YES, has this been reported to EMB/LLDA?			
4. Which System or units are under construction or being modified?			
5. Estimated date of completion			
6. Treatment units utilized to treat wastewater			

Water Quality Field Date						
Sampling Point No. 1						
Sampling Station	None		Sampling Time:			
Type of Sample						
Result Analysis						
Parameter	Value	Unit	DENR Effluent Standards	Compliant		Remarks
				Yes	No	

Information/Summary of the previous or recent inspection/sampling:						
Date of Sampling:						
Sampling Station	None			Sampling Time:		
Type of Sample						
Result Analysis						
Parameter	Value	Unit	DENR Effluent Standards	Compliant		Remarks
				Yes	No	

III. SUMMARY OF FINDINGS					
Legal Reference	Compliance Requirements	Compliant			Remarks
		Y	N	N/A	
DAO 2005-10 Rule 13.1	1. Does the establishment pay the required wastewater charge?	✓			
DAO 2005-10 Rule 14.1	2. Does the establishment have a Discharge Permit?	✓			
DAO 2005-10 Rule 14.5	3. Does the establishment pay the required discharge permit fee?	✓			
DAO 2005-10 Rule 14.9	4. Is the permit available and valid?	✓			
DAO 2005-10 Rule 14.11	5. Do the discharge points correspond to those declared in the discharge permit?			✓	
	6. Is the volume discharged within the allowable volume declared in the discharge permit?	✓			
	7. Is the permit posted in a proper area?	✓			
DAO 2005-10 Rule 14.16	8. Are the SMRs submitted quarterly and on time?	✓			4Q 2021 SMR# 297699 submitted 1/12/2022
DAO 1990-35 Section 4-6	9. Are the effluent parameters compliant with the standards in DENR existing effluent standards?			✓	
DAO 1990-35 Section 8	10. Does the establishment comply with the additional requirements stated in DAO 1990-35?			✓	
DAO 1990-35 Section 9	11. Are the pollution control facilities properly and continuously operated?	✓			
DAO 1990-35 Section 10	12. Are the methods of analysis used for effluent samples in accordance with the prescribed methods of the Department?			✓	
Other Requirements	13. Are the copies of water analysis reports available?			✓	

14. Are the correspondence between the establishment and EMB documented?	✓			
15. Are the establishment's compliance violations and exceedances documented?	✓			
16. Are there any pending litigation/PAB cases?		✓		
17. Are there spill prevention contingency plans?	✓			
18. Are there spill containment facilities available?	✓			

**Other Observations:**

- The funeral establishment was operational during the inspection. Some parts were under repair due to damage brought by typhoon.
- Septic tanks is large enough to accommodate volume of waste water over a period of time.
- Last desludging activity was conducted in 2018.

**Remarks and Recommendation:**


- Secure renewal of PCO Accreditation
- Constant monitoring shall be sustained on order to ensure environmental and public health safety.


**List of Documents Reviewed:**

DP-R08-21-04704, 4Q 2021 SMR




Submitted by:

  
**ZEUS BRYAN B. LORETO**  
EMS II

  
**For. ALEJANDROQUE G. MACATIGUE**  
Head, PEMU Southern Leyte

Recommending Approval:

  
**Engr. CARLOS A. CAYANONG**  
Chief, WAQMS

Approval:  
  
**For. MANUEL J. SACEDA, Jr.**  
OIC-Chief, EMED

Noted:

  
**Engr. REYNALDO B. BARRA**  
OIC-Regional Director

