

Report Control Number: __

ENVIRONMENTAL MANAGEMENT BUREAU REGION 8



COMPLIANCE INSPECTION FOR AIR QUALITY MANAGEMENT

ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-WATER AIR QUALITY MONITORING SECTION

Date of Inspection: 18 Januar		
Mission Order No.: <u>Desk Mor</u>	nitoring (SMR Evaluation)	
1. GENERAL INFORMATION		
Name of Establishment: EP Fue	ls Gasoline Station	
	nent: Emmelie Pfleider Silao)	
Address: Maharlika Highway, B	rgy. 95 Caibaan Tacloban City	Geo Coordinates: 11.20644°N, 124.99123°E
Nature of Business: Refueling St	ation	
PSIC Code: 4661	Product: Gasoline & Diesel	Year Established: 2013
Operating hours/day: 24 hours	Operating days/week: 7	Operating days/year: 365 days
Product Lines	Production Rate as Declared in the ECC (unit/day)	Actual Production Rate (unit/day)
N/A	N/A	N/A
Name of Managing Head:	Emmelie Pfleider Silao	
Name of PCO:	Joel Silao	
PCO Accreditation No.:	2021-RVIII-0023	Date of Effectivity:
Phone/Fax: 0917 707 5482		03/10/2021 - 03/10/2024 Email: epfuels123456789@gmail.com
11011C/14A. EITIAII. epiueis 123430/08		
2. PURPOSE OF INSPECTION		
	on submitted by the establishment perta	ining to new permit applications
renewals, or modification		ining to new permit applications,
New Renewal	1 21.86	New Renewal
PMPIN Application		
Hazardous Waste ID Re	egistration	
Hazardous Waste Tran		
Hazardous waste TSD F		
	Pollution Control Installation	
Discharge Permit		
☑ Determine compliance stat	us with the environmental regulations, p	permit conditions, and other
requirements		
☐ Investigate community com	nplaints	
☐ Check status of voluntary of		
Industrial Ecowatch		
	tal Partnership Program (PEPP)	
Pollution Adjudication		
	board (1 Ab)	
_ Others		
Name of Contact Person	Joel Silao	
Position / Designation	PCO	

3. COMPLIANCE STATUS

3.1 DENR Permits/Licenses/Clearance

Environmental Law		Permits	Date of Issue	Expiry Date
	ECC1	ECC-R08-1308-0093	08/07/2013	N/A
PD 1586	ECC2	-		
	ECC3	-		
	DENR Registry ID	-		
RA 6969	PCL Compliance Certificate	-		
	CCO Registry	-		
	Permit to Transport	-		
RA 8749	POA No.	18-POA-C-0837-0051	03/20/2018	03/20/2023
RA 9003	ECC for Sanitary Landfill	-		
RA 9275	DP No.	DP-R08-21-02858	05/14/2021	02/14/2022

MODULE AQM01: PRE-INSPECTION INFORMATION SHEETFOR EMISSION SOURCES

Emission Sou	rce Data Information
Emission Source No.	1
Type (Brand/Model)	UGTs
	1 UGT of 25 kL capacities
	1 UGT of 14 kL capacities
Rated Capacity	1 UGT of 10 kL capacities
Fuel Type & Quantity	Diesel & Gasoline
Operating Capacity	
Control Facility	
Notes: Fuel Storage Ta	nks

Rated Capacity 25 KW Fuel Type & Quantity Diesel Operating Capacity	Emission Source No. 2				
Fuel Type & Quantity Diesel Operating Capacity	Type (Brand/Model)	Shinsetsu generator set			
Operating Capacity	Rated Capacity	25 KW			
	Fuel Type & Quantity	Diesel			
	Operating Capacity				
Control Facility Muffler	Control Facility	Muffler			

Legal Provision	Regulatory Requirements		ompl	iant	Notes
		Υ	N	N/A	
DAO 2004-26					
Rule 19 Section 1	All emission sources have a valid Permit to Operate	1			
Rule 19 Section 3	As built design of the installation conforms with submitted engineering plans and specifications			1	
	Declared control facilities are installed and operational	1			
	Installation is located as proposed in the vicinity map (plant and machinery layout)			1	
	Facility design capacity is within the capacity declared in the application for permit to operate	1			
Rule 19 Section 5	Temporary Permit is still valid			1	
Rule 19 Section 6	Application for renewal has been filed for expiring Permit to Operate 30 days before permit expiration date			1	
Rule 19 Section 9	Permit to Operate displayed conspicuously upon the installation or in an accessible / visible place near the installation	1			
	Conditions of the Permit to Operate are complied with	1			

Rulle 19 Section 11	Plant operational problems notification submitted to EMB within 24 hours of occurrence		/	
Rule 19 Section 12	Quarterly submission of self- monitoring report	1		Q ₁ 04/15/2021 Q ₂ 06/30/2021 Q ₃ 10/11/2021 Q ₄ 01/07/2022
DAO 2000-81				
Part 7 Rule 25 Section 5 a# 1	Person in charge of the plant / equipment has sufficient measure to ensure that no dark smoke is discharging from any stack in the establishment. E.g.: window view of stack, mirror to reflect top of stack, smoke density indicator, CCTV, etc.		/	
Part 7 Rule 25 Section 5 a# 2	All oil-burning equipment have heaters capable of heating oil to a temperature appropriate for the oil and burner		1	
Part 7 Rule 25 Section 5 a# 3	Establishment is fossil fuel-fired power plant over 10MW rating installed with CEMS for particulates, sulfur oxide, and NOx		/	
	Establishment is petroleum refinery / petrochemical industry installed with CEMS for particulates, sulfur oxide, and NOx		/	
	Establishment is primary copper smelter installed with CEMS for particulates, sulfur oxide, and NOx		1	
	Establishment is steel plant installed with CEMS for particulates and sulfur oxide		/	
	Establishment is ferro-alloy production facility installed with CEMS for particulates		/	
	Establishment is cement plant installed with CEMS for particulates		/	
Part 7 Rule 25 Section 5 b	Miscellaneous equipment like reheating furnace, smoke oven, bake oven, coffee heaters, varnish kettles, etc. are installed with pollution control facilities		1	
Part 7 Rule 25 Section 13 a	Establishment has precautionary controls for dusts generated during vehicular movement, transportation of materials, construction, etc. (List controls identified)		/	
Part 7 Rule 25 Section 13 b	Establishment has precautionary controls for volatile organic compounds or organic solvent emissions generated during storing, pumping, handling, processing, etc. (List controls identified)		/	
Part 7 Rule 25 Section 13 d	No open burning activity in the establishment	1		

MC 2009-04	Standby Gensets with capacity	/	
	greater than or equal to 1,250 KW		
	undergo annual emission testing		
	(with 3 test runs). These gesets		
	should not have the potential to emit		
	more than 100tons/year of regulated		
140,0007,000 (0)	pollutant.		
MC 2007-003 (2)	Boiler rated at greater than or equal	/	
	to 251HP undergo bi-annual		
	emission testing (with 3 test runs)		
	Other sources that have potential to	/	
	emit equal to or greater than		
	100tons/year of regulated pollutant		
	undergo bi-annual emission testing		
	(with 3 test runs)		
	Boiler rated between 100 to 250 HP	1	
	undergo annual emission testing		
	(with 3 test runs)		
	Diesel generator rated at 600 to	1	
	1,249KW undergo annual testing		
	(with 3 test runs)		
	Other sources that have potential to	1	
	emit greater than 30 but less than		
	100tons/year of regulated pollutant		
	undergo annual emission testing		
	(with 3 test runs)		
	Sources of emissions of hazardous	/	
	air pollutants included in PCL (DAO		
	1998 -58) undergo bi-annual		
	emission testing (with 3 test runs)		
	Emission sources of petroleum	/	
	refinery undergo bi-annual emission testing (with 3 test runs)		
	testing (with 5 test runs)		
	Emission sources of petrochemical	1	
	works undergo bi-annual emission	'	
	testing (with 3 test runs)		
	Emission sources of smelters	/	
	undergo bi-annual emission testing		
	(with 3 test runs)		
	Emission sources of cement kilns	/	
	undergo bi-annual emission testing	/	
	`with 3 test runs)		
	Emission sources of steel -making	/	
	plants undergo bi-annual emission		
	testing (with 3 test runs)		
		1 1	
	Emission sources of force all and		
	Emission sources of ferro-alloy-	/	
	making plants undergo bi-annual	/	
		/	

Emission sources of glass-making plants undergo bi-annual emission testing (with 3 test runs) Boiler rated at 99HP or less undergo 1 biennial emission testing (with 3 test runs) Diesel generator rated at 599KW 1 or less undergo biennial emission testing (with 3 test runs) Other sources that have potential to emit at least 10tons/year but less than 30tons/year of regulated pollutant undergo biennial emission testing (with 3 test runs) Source using Bunker Fuel Oil, blended fuels involving Bunker Fuel Oil, or sulfur content of 1% or more undergo bi-annual emission testing Appendix F (Quality Assurance Procedures) Notification has been sent to EMB for Section 6 (8) any changes made in the CEMS installation Notification has been sent to EMB for 1 any changes made in the CEMS quality assurance and quality control Section 6 (5) Each CEMS is audited and / conducted in accordance to CFR 40 part 60 Appendix F. Section 6 (6) Relative Accuracy Test Audit (RATA) 1 is performed annually by industries in the presence of EMB personnel. Establishment has sent thirty (30) 1 day notice to EMB prior to the RATA testing schedule Section 6 (7) Calibration gases are subject to audit 1 or relative accuracy audit test every quarter Other alternative quarterly audits 1 employed by the establishment are approved by EMB.

Section 6 (9)	EMB Director and Regional Director have been notified of CEMS malfunction that lasted longer than seven (7) consecutive days.	/	
Section 7 (1)	Records of occurrence and duration of any start-up, shut-down or malfunction in the operation of any source or control facility is available in the establishment.	1	
Section 7 (2)	Records of audits, performance testing, evaluations, calibration checks, adjustments and maintenance of any continuous emission monitors that have been installed pursuant to Rule IX Section 5 of DAO 2000-81 are available in the establishment.	/	
Section 8 (1)	SMR includes data on the time intervals, date and magnitude of excess emissions, nature and cause of excess, corrective actions taken, and preventive measures adopted.	/	
Section 8 (2)	SMR includes information on the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question.	/	
Section 8 (3)	SMR includes information on time and date for each period during which the continuous monitoring system was inoperative and the nature of system repairs and adjustments made in the CEMS/COMS	/	
Section 8 (4)	SMR data measurements are within 75% data capture?	/	
For Facilities Engaged with	n Consent Agreement		
EMS established within 18 months upon entering Consent Agreement with EMB	EMS established within 18 months upon entering Consent Agreement with EMB	/	
DAO 2000-81 Part 7 Rule 25 Section 9b	Environmental Management Plan derived from EMS process submitted within 6 months after entering Consent Agreement with EMB	/	

Other Observations:

- · The gas station is operational.
- Air pollution source equipment provided in the gas station are three (3) UGTs each having 25kL, 14 kL and 10 kL capacities (for diesel and gasoline) as indicated per valid Permit to Operate which is valid until March 20, 2023.
- Submission of Self-Monitoring Report (SMR) online is regular.
- · PCO for the gas station is accredited until March 10, 2024.
- All Modules of the submitted SMR online has been properly supplied with the necessary data and information.
 However, Module 5 is for improvement especially on providing compliances for ECC conditions. SMRs were received as sufficient.

Remarks and Recommendation:

• The gas station complies with the permitting and compliance requirements of R.A. 8749, P.D. 1586, and R.A. 9275.

List of Documents Reviewed:

Copy of ECC, SMR online, PTO, DP,

Submitted by:

LEDANE JOY LAURENTE

Approved by:

FOR MANUEL J. SACEDA, JR.

Recommending Approval:

Engr. CARLOS A. CAYANONO Chief, WAQMS

Noted by:

REYNANDO B BARRA, PME OIC Regional Director



Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City



DISPOSITION FORM

Doc. Date: January 19, 2022

: R8-2022-004082

Company Name: ENVIRONMENTAL MANAGEMENT BUREAU -

REGION VIII (EASTERN VISAYAS)



Subject / Title: Inspection Report AIR (Desk Monitoring/SMR Evaluation) - EP Fuels Gasoline Station

TO: All Officials/Personnel Concerned:

Please accomplish and route this properly with the corresponding attached communication/documents. The Official or employee in-charge to whom this document is routed shall act promptly and expeditiously without discrimination as prescribed in the SECSIME or within fifteen (15) working days from receipt thereof, failure to do is punishable by LAW under RA 6713 and negligence to Memorandum Circular No. 44 issued by the Office of the President of the Philippines "Directing all Government Agencies and Instrumentalities, including government-owned or controlled corporations to respond to all public requests and concerns within 15 days (15 from the receipt thereof)

For strict compliance.

IIS No.

ROUTED						
BY (Official Code/ Sender Initial)	Official Code/ (mm/dd/sy) (Official Code/ (AM/PM)		ACTION REMARKS STATUS			
Ledane Joy Y. Laurente	01/19/2022	Carlos A. Cayanong	04:14 PM	For initial/signature.		
A	1-19	MS	825	H		
C.EMED	01120122	UI INDPYA		1		
J.INOPIA	2 1 JAN 2022	HEA	8:33mm	J		
RD	JAN 2 1 202	D FMED/	9:490	Nated Signed		
		Nin	•	,,,,,		
			ē.			

Use code for comment/instruction and desired action:

A - For information / guidance / reference

B - For comments / recommendations

C - Pls. take up with me

D - Pls. draft answer memo

E - Pls. appropriatte action

F - Pls. immediate investigation

G - Pls. Attach supporting papers

H - Pls. for approval

I - For initial/signature

J - For study/evaluation

K - Pls. release/file

L - Update stat of case

Important Reminder!

Do not tamper. Continue on separate sheet if necessary. Attach this always with the document to be routed as this shall form an integral part of the document process.