



Republic of the Philippines  
Department of Environment and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
Region VIII  
DENR Compound, Jones Street, Barangay 2, Tacloban City  
Tel No: (053) 832-1088 / (053) 832-2319  
embr8\_records@emb.gov.ph

Permit No: PTO-OL-R08-2022-02443-R  
Application Type: Renewal

Date Issued: 25 Mar 2022  
Date Expiration: 25 Mar 2027

**PERMIT TO OPERATE**  
**Air Pollution Source and Control Installations**

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

**GLOBE TELECOMMUNICATIONS, INC. (CABUCG)** **Libertad, Cabucgayan, Biliran**


subject to the following terms and conditions:

**TERMS AND CONDITIONS**

1. This Permit is issued for the permittee to operate **one (1) unit 25 KVA (20KW) "ASCOT" Diesel Generator Set**, for the purpose of **Standby Power** at the permittee's establishment identified on this Permit. (Refer to attached Annex at page 2)
2. Any application for renewal of this Permit shall be filed not less than **thirty (30) days** before the expiry date indicated on the previous page of the Permit.
3. The previous page of this Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
  - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749;
  - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
5. The permittee shall submit **Self-Monitoring Reports (SMR)** to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the Report on or before **April 15, 2022**. (Online submission at <https://client.emb.gov.ph/smr>)
6. The permittee shall at all times have an appointed or designated **Pollution Control Officer (PCO)** pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall burn only **Diesel Fuel** in the **one (1) unit 25 KVA (20KW) "ASCOT" Standby Diesel Generator Set** for not more than **500 annual operating hours** for the whole duration of the permit validity.

Recommended by:

Approved by:

  
**ENGR. HENNENCY G. HAYAG**  
OIC-Chief, Clearance and Permitting Division

  
**ENGR. REYNALDO B. BARRA**  
OIC-Regional Director

|                       |               |                                |                       |
|-----------------------|---------------|--------------------------------|-----------------------|
| Filing Fee            | : Php 600.00  | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| Permit Fee            | : Php 2500.00 | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| PD1856                | : Php 10.00   | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| Documentary Stamp Tax | : Php 30.00   | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

| Fuel Burning |               |          |            |              |      |
|--------------|---------------|----------|------------|--------------|------|
| ID           | APSI          | Capacity | Brand name | Type of Fuel | APCD |
| 208619       | Generator Set | 25.0 KVA | ASCOT      | Diesel       | ---  |

|                       |               |                                |                       |
|-----------------------|---------------|--------------------------------|-----------------------|
| Filing Fee            | : Php 600.00  | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| Permit Fee            | : Php 2500.00 | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| PD1856                | : Php 10.00   | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |
| Documentary Stamp Tax | : Php 30.00   | O.R. No. : 226-03252022-677541 | Date : March 25, 2022 |



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.