



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-10-88

Permit No: PTO-OL-R08-2021-09396
Application Type: New

Date Issued: 09 Nov 2021
Date Expiration: 09 Nov 2026

PERMIT TO OPERATE
Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

Pongos Broiler Poultry Farm Project (Pongos Broiler Poultry Farm Project) **Puerto Bello, Merida, Leyte**

subject to the following terms and conditions:

TERMS AND CONDITIONS

1. This Permit is issued for the permittee to operate **one (1) unit "WEICHA POWER" Diesel Generator Set rated at 227.5 KVA (182 KW) and one (1) unit "MEGA POWER" Diesel Generator Set rated at 162.5 KVA (130 KW)**, for the purpose of **Standby Power** at the permittee's establishment identified on this Permit. (Refer to attached Annex at page 3)
2. Any application for renewal of this Permit shall be filed not less than **thirty (30) days** before the expiry date indicated on the previous page of the Permit.
3. The previous page of this Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
 - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749;
 - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
5. The permittee shall submit **Self-Monitoring Reports (SMR)** to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the first Report on or before **January 15, 2022**. (Online submission at <https://client.emb.gov.ph/smr>)
6. The permittee shall at all times have an appointed or designated **Pollution Control Officer (PCO)** pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall burn only **Diesel Fuel** in the **one (1) unit 227.5 KVA (182 KW) "WEICHA POWER" and one (1) unit 162.5 KVA (130 KW) "MEGA POWER" Standby Generator Sets** for not more than **500 annual operating hours per equipment** for the whole duration of the permit validity.


Recommended by:

Approved by:

Filing Fee	: Php 600.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Permit Fee	: Php 5000.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
PD1856	: Php 10.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.


MARIBEL B. MUNSAAYAC
Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
PIC-Regional Director

Filing Fee	: Php 600.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Permit Fee	: Php 5000.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
PD1856	: Php 10.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
158585	Stand by genset	227.5 kva	Weichai Power	Diesel	---
158590	Generator Set	162.5 kva	Mega-Power	Diesel	---

Filing Fee	: Php 600.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Permit Fee	: Php 5000.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
PD1856	: Php 10.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736388/4736584	Date : 4 Nov. 2021



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.