



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-1088 / (053) 832-2319
embr8_records@emb.gov.ph

Permit No: PTO-OL-R08-2022-02874-R
Application Type: Renewal

Date Issued: 08 Apr 2022
Date Expiration: 08 Apr 2027

PERMIT TO OPERATE
Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

ORAS DOCTORS HOSPITAL (ORAS DOCTORS HOSPITAL)

National Road, Tawagan (Pob.), Oras, Eastern Samar


subject to the following terms and conditions:

TERMS AND CONDITIONS

1. This Permit is issued for the permittee to operate **one (1) unit "CATERPILLAR" Diesel Generator Set** rated at **250 KVA (200 KW)** and **one (1) unit "DENYO" Diesel Generator Set** rated at **110 KVA (88 KW)** , for the purpose of **Standby Power**, respectively at the permittee's establishment identified on this Permit. *(Refer to attached Annex at page 2)*
2. Any application for renewal of this Permit shall be filed **not less than thirty (30) days** before the expiry date indicated on this Permit.
3. This Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
 - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749; and
 - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749.
5. The permittee shall submit Self-Monitoring Reports to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the **first Report** on or before **July 15, 2022**. (Online Submission at <https://client.emb.gov.ph/smr>)
6. The permittee shall at all times have an appointed or designated Pollution Control Officer (PCO) pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall burn only **Diesel Fuel Oil** in the **one (1) unit "CATERPILLAR" Diesel Generator Set** rated at **250 KVA (200 KW)** and **one (1) unit "DENYO" Diesel Generator Set** rated at **110 KVA (88 KW)** for not more than **500 annual operating hours** for the whole duration of the permit validity.

Recommended by:

Approved by:


ENGR. HENNY G. HAYAG
OIC-Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
OIC-Regional Director

Filing Fee : Php 600.00
Permit Fee : Php 5000.00
PD1856 : Php 10.00
Documentary Stamp Tax : Php 30.00

O.R. No. : 1949091,1944804
O.R. No. : 1949091,1944804
O.R. No. : 1949091,1944804
O.R. No. : 1949091,1944804

Date : March 30, 2022
Date : March 30, 2022
Date : March 30, 2022
Date : March 30, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
211625	GENERATOR SET	200.0 Kilowatt	CATERPILLAR	DIESEL	---
211627	GENERATOR SET	88.0 Kilowatt	DENYO	DIESEL	---

Filing Fee	: Php 600.00	O.R. No. : 1949091,1944804	Date : March 30, 2022
Permit Fee	: Php 5000.00	O.R. No. : 1949091,1944804	Date : March 30, 2022
PD1856	: Php 10.00	O.R. No. : 1949091,1944804	Date : March 30, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 1949091,1944804	Date : March 30, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.