

#### **ENVIRONMENTAL MANAGEMENT BUREAU REGION 8**



# **COMPLIANCE INSPECTION FOR AIR QUALITY MANAGEMENT**

**ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-WATER AIR QUALITY MONITORING SECTION** 

Report Control Number: \_\_\_\_\_

Date of Inspection: March 09, 2022

Mission Order No.: EMB-R8-2022-007318

1. GENERAL INFORMATION						
Name of Establishment: STA. M.	ARGARITA GASOLINE STATION					
Address: Brgy. Mombon, Sta. Ma	argarita, Samar	Geo Coordinates: Latitude: 12.2110 North				
Nature of Business: Retail of Automotive Fuel		Longitude: 124.3951 East				
PSIC Code: N/A	Product: FUELS	Year Established: 2015				
Operating hours/day: n/a	Operating days/week: n/a	Operating days/year: n/a				
Product Lines	Production Rate as Declared	Actual Production Rate				
	in the ECC					
N/D/A	N/D/A	N/D/A				
,	,_,					
Name of Managing Head:	N/D/A	<u> </u>				
Name of PCO:	N/D/A					
PCO Accreditation No.:	N/D/A	Date of Effectivity: N/A				
Phone/Fax:	NONE	Email: none				
	,					
2. PURPOSE OF INSPECTION						
Verify accuracy of information renewals, or modification	on submitted by the establishment	pertaining to new permit applications,				
New Renewal		New Renewal				
PMPIN Application						
Hazardous Waste ID Re	gistration					
Hazardous Waste Trans	_					
Hazardous waste TSD R						
x Permit to Operate Air	Pollution Control Installation					
Discharge Permit						
OthersAir Quality N	Management Monitoring					
Determine compliance statu	s with the environmental regulatio	ns, permit conditions, and other				
Requirements						
☐ Investigate community comp	plaints					
☐ Check status of voluntary cor	mmitment					
Industrial Ecowatch						
Philippine Environment	tal Partnership Program (PEPP)					
Pollution Adjudication Board (PAB)						
Others						
Others						
Name of Contact Person	N/A					
Position / Designation	N/A					

#### 3. COMPLIANCE STATUS

### 3.1 DENR Permits/Licenses/Clearance

Environmental Law		Permits	Date of Issue	Expiry Date
	ECC1	ECC-R08-1402-0011	2014-03-10	N/A
PD 1586	ECC2	N/A	N/A	N/A
	ECC3	N/A	N/A	N/A
	DENR Registry ID	N/A	N/A	N/A
DA 6060	PCL Compliance Certificate	N/A	N/A	N/A
RA 6969	CCO Registry	N/A	N/A	N/A
	Permit to Transport	N/A	N/A	N/A
RA 8749	POA No.	16-POA-H-0860-0210	8/6/2018	8/6/2023
RA 9003	ECC for Sanitary Landfill	N/A	N/A	N/A
RA 9275	DP No.	none	n/a	n/a

**MODULE AQM01: PRE-INSPECTION INFORMATION SHEET FOR EMISSION SOURCES** 

Emission Source Data Information						
Emission Source No. 1						
Type (Brand/Model) <b>DENYO</b>						
Rated Capacity 10.5 KVA (8.4) KW						
Fuel Type & Quantity Gasoline – 1 unit						
Operating Capacity As need arises						
Control Facility Muffler						
Notes: Not required for Permit to Operate						

Emission Source Data Information						
Emission Source No.	2					
Type (Brand/Model)	UGTs					
Rated Capacity						
Fuel Type & Quantity	10,00KL each, 20,000KL each Premium, Regular and Diesel- 4 units					
Operating Capacity	24 hrs.					
Control Facility	Breathable Pipes					
Notes:						

Legal Provision	Regulatory Requirements	Compliant			Notes
		Υ	N	N/A	
DAO 2004-26					
Rule 19 Section 1	All emission sources have a valid	/			
	Permit to Operate				
Rule 19 Section 3	As built design of the installation			/	
	conforms with submitted engineering				
	plans and specifications				
	Declared control facilities are	/			Installed beneath the wall
	installed and operational				of the UGT Breathable
					pipes
	Installation is located as proposed in	/			Installed in space open for
	the vicinity map (plant and machinery	-			inspection
	layout)				
	Facility design capacity is within the			/	
	capacity declared in the application				
	for permit to operate				
Rule 19 Section 5	Temporary Permit is still valid			/	
Rule 19 Section 6	Application for renewal has been			/	
	filed for expiring Permit to Operate				
	30 days before permit expiration date				
Rule 19 Section 9	Permit to Operate displayed			/	
	conspicuously upon the installation				
	or in an accessible / visible place				
	near the installation				
	Conditions of the Permit to Operate			/	
	are complied with				

Rulle 19 Section 11	Plant operational problems notification submitted to EMB within 24 hours of occurrence			/	
Rule 19 Section 12	Quarterly submission of self- monitoring report		/		Q <sub>1</sub> N/D/A Q <sub>2 N/D/A</sub> Q <sub>3</sub> N/D/A Q <sub>4 N/D/A</sub>
DAO 2000-81					
Part 7 Rule 25 Section 5 a#	Person in charge of the plant /			/	
1	equipment has sufficient measure to				
	ensure that no dark smoke is				
	discharging from any stack in the				
	establishment. E.g.: window view of				
	stack, mirror to reflect top of stack,				
D 17 D 1 05 O 11 5 11	smoke density indicator, CCTV, etc.				
Part 7 Rule 25 Section 5 a#	All oil-burning equipment have			/	
2	heaters capable of heating oil to a				
	temperature appropriate for the oil and burner				
	and burner				
Part 7 Rule 25 Section 5 a#	Establishment is fossil fuel-fired			,	
3	power plant over 10MW rating			/	
3	installed with CEMS for particulates,				
	sulfur oxide, and NOx				
	Establishment is petroleum refinery /			/	
	petrochemical industry installed with				
	CEMS for particulates, sulfur oxide, and NOx				
	Establishment is primary copper			/	
	smelter installed with CEMS for				
	particulates, sulfur oxide, and NOx				
	Establishment is steel plant installed			/	
	with CEMS for particulates and sulfur				
	oxide				
	Establishment is ferro-alloy			/	
	production facility installed with				
	CEMS for particulates			,	
	Establishment is cement plant installed with CEMS for particulates			/	
	Installed with CEIVIS for particulates				
Part 7 Rule 25 Section 5 b	Miscellaneous equipment like			/	
	reheating furnace, smoke oven, bake				
	oven, coffee heaters, varnish kettles,				
	etc. are installed with pollution				
D D	control facilities				
Part 7 Rule 25 Section 13 a	Establishment has precautionary			/	
	controls for dusts generated during				
	vehicular movement, transportation				
	of materials, construction, etc. (List controls identified)				
	,				
Part 7 Rule 25 Section 13 b	Establishment has precautionary			/	
	controls for volatile organic				
	compounds or organic solvent				
	emissions generated during storing,				
	pumping, handling, processing, etc. (Listcontrols identified)				
Part 7 Rule 25 Section 13 d	No open burning activity in the	/			
T GILT ING 20 OCCION IS U	establishment	/			
					1

## **EMB Memorandum Circulars**

MC 2009-04	Standby Gen sets with capacity greater than or equal to 1,250 KW undergo annual emission testing (with 3 test runs). These gen sets should not have the potential to emit more than 100tons/year of regulated pollutant.		<i>1</i>	
MC 2007-003 (2)	Boiler rated at greater than or equal to 251HP undergo bi-annual emission testing (with 3 test runs)		/	
	Other sources that have potential to emit equal to or greater than 100tons/year of regulated pollutant undergo bi-annual emission testing (with 3 test runs)		/	
	Boiler rated between 100 to 250 HP undergo annual emission testing (with 3 test runs)		/	
	Diesel generator rated at 600 to 1,249KW undergo annual testing (with 3 test runs)		/	
	Other sources that have potential to emit greater than 30 but less than 100tons/year of regulated pollutant undergo annual emission testing (with 3 test runs)		/	
	Sources of emissions of hazardous air pollutants included in PCL (DAO 1998 -58) undergo bi-annual emission testing (with 3 test runs)		/	
	Emission sources of petroleum refinery undergo bi-annual emission testing (with 3 test runs)		/	
	Emission sources of petrochemical works undergo bi-annual emission testing (with 3 test runs)		/	
	Emission sources of smelters undergo bi-annual emission testing (with 3 test runs)		/	
	Emission sources of cement kilns undergo bi-annual emission testing `with 3 test runs)		/	
	Emission sources of steel -making plants undergo bi-annual emission testing (with 3 test runs)		/	
	Emission sources of ferro-alloy- making plants undergo bi-annual emission testing (with 3 test runs)		/	
	U	·		L

	Emission sources of glass-making plants undergo bi-annual emission testing (with 3 test runs)	/	
	Boiler rated at 99HP or less undergo biennial emission testing (with 3 test runs)	/	
	Diesel generator rated at 599KW or less undergo biennial emission testing (with 3 test runs)	/	
	Other sources that have potential to emit at least 10tons/year but less than 30tons/year of regulated pollutant undergo biennial emission testing (with 3 test runs)	/	
	Source using Bunker Fuel Oil, blended fuels involving Bunker Fuel Oil, or sulfur content of 1% or more undergo bi-annual emission testing	/	
Appendix F (Quality A	ssurance Procedures)		
Section 6 (8)	Notification has been sent to EMB for any changes made in the CEMS installation	/	
	Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control plan	/	
Section 6 (5)	Each CEMS is audited and conducted in accordance to CFR 40 part 60 Appendix F.	/	
Section 6 (6)	Relative Accuracy Test Audit (RATA) is performed annually by industries in the presence of EMB personnel.	/	
	Establishment has sent thirty (30) day notice to EMB prior to the RATA testing schedule	/	
Section 6 (7)	Calibration gases are subject to audit or relative accuracy audit test every quarter	/	
	Other alternative quarterly audits employed by the establishment are approved by EMB.	/	

Section 6 (9)	EMB Director and Regional Director have been notified of CEMS malfunction that lasted longer than seven (7) consecutive days.			/			
Section 7 (1)	Records of occurrence and duration of any start-up, shut-down or malfunction in the operation of any source or control facility is available in the establishment.			1			
Section 7 (2)	Records of audits, performance testing, evaluations, calibration checks, adjustments and maintenance of any continuous emission monitors that have been installed pursuant to Rule IX Section 5 of DAO 2000-81 are available in the establishment.			/			
Section 8 (1)	SMR includes data on the time intervals, date and magnitude of excess emissions, nature and cause of excess, corrective actions taken, and preventive measures adopted.			_			
Section 8 (2)	SMR includes information on the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question.			/			
Section 8 (3)	SMR includes information on time and date for each period during which the continuous monitoring system was inoperative and the nature of system repairs and adjustments made in the CEMS/COMS			/			
Section 8 (4)	SMR data measurements are within 75% data capture?			/			
For Facilities Engaged with Consent Agreement							
EMS established within 18 months upon entering Consent Agreement with EMB	EMS established within 18 months upon entering Consent Agreement with EMB			1			
DAO 2000-81 Part 7 Rule 25 Section 9b	Environmental Management Plan derived from EMS process submitted within 6 months after entering Consent Agreement with EMB			/			

## Other Observations:

1. Closed during the time of inspection due to maintenance and no definite date to resume its operation.

#### **Remarks and Recommendation:**

- 1. As a matter of policy and per provision as stipulated in the conditions of ECC, the proponent and/or owner shall be required to inform the EMB in writing for the temporary shut down and/or closure of its operation.
- 2. For follow-up monitoring.

**List of Documents Reviewed:** 

Expired Permit to Operate, renewed local clearances and permits

Submitted by:

DR. ANTONIO A. PINO, Ph. D. Head, PEMU-SAMAR

Approval:

FOR. MANUEL A. SACEDA OIC, Chief-EMED Reviewed by:

Engr. CARLOS A. CAY ANONG Chief, WAQMS

Noted:

ENGR. REYNALDO B. BARRA, PME OIC, Regional Director

