



Republic of the Philippines
Department of Environmental and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-1088 / (053) 832-2319
embr8_records@emb.gov.ph

Date: Jan 05, 2022 Permit No.: DP-R08-22-00084
Renewal

WASTEWATER DISCHARGE PERMIT

Pursuant to Section 14, Article 2, of the RA 9275 otherwise known as the "Philippine Clean Water Act of 2004", this permit is hereby granted to **Ormoc Sugarcane Planters Association - Farmers' Medical Center** with office address at Carlota Hills, Can-Adieng, Ormoc City, Leyte for its establishment:

Ormoc Sugarcane Planters Association - Farmers' Medical Center	Carlota Hills Can-adieng ORMOC CITY
TIN No. 001-387-778-001	

To discharge **Commercial Wastewater** into **Ormoc Bay (Class SC)** subject to the following conditions:

1. The discharge rate of the effluent shall not exceed **97.24 m3/day** after treatment at the **Wastewater Treatment Facility (WTF)** and shall comply with the following standard:
- | Parameter | Standard | Parameter | Standard |
|-------------|------------|----------------|---------------|
| BOD | 100 mg/L | Ammonia | 4 mg/L |
| TSS | 100 mg/L | Oil & Grease | 10 mg/L |
| Temperature | 3°C Change | Nitrate | 20 mg/L |
| pH | 6.0-9.0 | Surfactants | 15 mg/L |
| Phosphate | 4 mg/L | Fecal Coliform | 400 MPN/100mL |
| Color | 150 TCU | - | - |
- * Reference for effluent parameters: DAO 2016-08 & DAO 2021-19; PSIC Code - 86, 87
2. Institute measures on the operation of your **WTF** so as to have effluent conforming with the prescribed standard.
3. The maximum wastewater generation of **68.07 m3/day** shall be from the process.
4. The maximum wastewater generation of **15.56 m3/day** shall be from the washing/cleaning activities.
5. The maximum wastewater generation of **13.61 m3/day** shall be from the domestic wastes.
6. Submit Self-Monitoring (SMR) based on the following schedule: (*Online submission at <https://client.emb.gov.ph/smr>*)
- | Quarter | Coverage | Submission | Quarter | Coverage | Submission |
|---------|----------|------------|---------|----------|------------|
| First | Jan-Mar | 1-15 Apr. | Third | Jul-Sep. | 1-15 Oct. |
| Second | Apr-Jun. | 1-15 Jul. | Fourth | Oct-Dec. | 1-15 Jan. |
7. Include effluent analysis of the **BOD, TSS, Fecal Coliform, Nitrate, & Phosphate** parameters, conducted by the **EMB VIII Laboratory**, at least **two (2) months** prior to the expiration of this permit.
8. Include effluent analysis on the other remaining parameters, conducted by Third Party Laboratory duly recognized by EMB, at least **two (2) months** prior to the expiration of this permit.
9. Submit **BOD & TSS** analysis of the abstracted water or source of your water supply. (e.g. deep well water, tap water, water distributed by peddlers, etc.) conducted by the **EMB VIII Laboratory**, at least **two (2) months** prior to the expiration of this permit.
10. Provide accessible sampling port at the effluent side of your **WTF** at all times.



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.


- 11. Channel your domestic wastewater generation (washing/cleaning and domestic) into your **Wastewater Treatment Facility**.
- 12. Renew the Certificate of PCO Accreditation not later than **December 3, 2024**.
- 13. Allow the entry of our duly authorized representative(s) to conduct inspection within your premises.
- 14. This permit, together with the corresponding Official Receipts of Payment, shall be adequately framed and posted in a conspicuous place at the plant/establishment.
- 15. This permit shall be renewed not less than **thirty (30) days** prior to its expiration.

This permit is valid up to Jan 05, 2023, unless revoked or suspended by this Office in writing.

Non-compliance with the above conditions and/or any pertinent provisions of RA 9275 otherwise known as "Philippine Clean Water Act of 2004", a corresponding penalty in the amount of P10,000-P200,000 per violation shall be imposed.

Recommended by:

Approved by:


ENGR. HENNENCY G. HAYAG
OIC-Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
OIC-Regional Director

Permit Fee	: Php 2500.00	O.R. No. : 1947885, 4739783	Date : Jan. 3, 2022
Water Discharge Fee	: Php 1925.35	O.R. No. : 1947885, 4739783	Date : Jan. 3, 2022
Filing Fee	: Php 55.00	O.R. No. : 1947885, 1945976, 1944445	Date : Jan. 3, 2022
PD1856	: Php 10.00	O.R. No. : 1947885, 1945976, 1944445	Date : Jan. 3, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 1947885, 1945976, 1944445	Date : Jan. 3, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.