



Republic of the Philippines  
Department of Environmental and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
**Region VIII**  
DENR Compound, Jones Street, Barangay 2, Tacloban City  
Tel No: (053) 832-10-88

Date: Mar 05, 2020

Permit No.: DP-R08-20-01281  
**Renewal**

**WASTEWATER DISCHARGE PERMIT**

Pursuant to Section 14, Article 2, of the RA 9275 otherwise known as the "Philippine Clean Water Act of 2004", this permit is hereby granted to **Mccarol Ventures-mcdonald Real** with office address at Real St. Cor. Avenida Veteranos, Barangay 47, Tacloban City (Capital), Leyte for its establishment:

<b>Mccarol Ventures-mcdonald's Real</b>	Real St. Cor. Avenida Veteranos Tacloban City
TIN No. 128-530-483-004	Barangay 47 TACLOBAN CITY (Capital)

To discharge **Commercial Wastewater** into **Cancabato Bay (Class SC)** subject to the following conditions:

- The discharge rate of the effluent shall not exceed **13.4 m3/day** and shall comply with the following standard

Parameter	Standard	Parameter	Standard
BOD	100 mg/L	Oil & Grease	10 mg/L
TSS	100 mg/L	Surfactants	15 mg/L

*\* Reference for effluent parameters: DAO 2016-08; PSIC Code - 56*
- Institute measures on the operation of your **WTF** so as to have effluent conforming with the prescribed standard.
- The maximum wastewater generation of **6.7** m3/day shall be from the washing/cleaning activities.
- The maximum wastewater generation of **6.7** m3/day shall be from the domestic wastes.
- Submit Self-Monitoring (SMR) based on the following schedule:

Quarter	Coverage	Submission	Quarter	Coverage	Submission
First	Jan-Mar	1-15 Apr.	Third	Jul-Sep.	1-15 Oct.
Second	Apr-Jun.	1-15 Jul.	Fourth	Oct-Dec.	1-15 Jan.
- Include effluent analysis on the above parameters, conducted by Third Party Laboratory duly recognized by EMB, at least **two (2) months** prior to the expiration of this permit.
- Submit **BOD & TSS** analysis of the abstracted water or source of your water supply. (e.g. deep well water, tap water, water distributed by peddlers, etc.) at least **two (2) months** prior to the expiration of this permit.
- Provide accessible sampling port at the effluent side of your **WTF**.
- Channel your wastewater generation (washing/cleaning and domestic) into your **Wastewater Treatment Facility**.
- Submit Certificate of desludging/siphoning of the **Septic Tank** and treatment of the same by an accredited service provider.
- Rene the Certificate of PCO Accreditation not later than **March 4, 2022**.
- Allow the entry of our duly authorized representative(s) to conduct inspection within your premises.
- This permit, together with the corresponding Official Receipts of Payment, shall be adequately framed and posted in a conspicuous place at the plant/establishment.
- This permit shall be renewed at least **thirty (30) days** prior to its expiration.

**This permit is valid up to Mar 05, 2021, unless revoked or suspended by this Office in writing.**




This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Non-compliance with the above conditions and/or any pertinent provisions of RA 9275 otherwise known as "Philippine Clean Water Act of 2004", a corresponding penalty in the amount of P10,000-P200,000 per violation shall be imposed.

Recommended by:

Approved by:

  
Maribel B. Munsayac  
Chief, Clearance and Permitting Division

  
Letecia R. Maceda  
Regional Director

Permit Fee	: Php 2200.00	O.R. No. : 5608998; 5606450	Date : Jan. 23, 2020
Water Discharge Fee	: Php 1350.72	O.R. No. : 5608998; 5606450	Date : Jan. 23, 2020
Filing Fee	: Php 55.00	O.R. No. : OR: 5609727; 5609781; 5609494	Date : Feb. 6, 2020
PD1856	: Php 10.00	O.R. No. : OR: 5609727; 5609781; 5609494	Date : Feb. 6, 2020
Documentary Stamp Tax	: Php 30.00	O.R. No. : OR: 5609727; 5609781; 5609494	Date : Feb. 6, 2020



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.