



Republic of the Philippines  
Department of Environmental and Natural Resources  
**ENVIRONMENTAL MANAGEMENT BUREAU**  
**Region VIII**  
DENR Compound, Jones Street, Barangay 2, Tacloban City  
Tel No: (053) 832-1088 / (053) 832-2319  
embr8\_records@emb.gov.ph

Date: Mar 08, 2022

Permit No.: DP-R08-22-01818

**Renewal**

**WASTEWATER DISCHARGE PERMIT**

Pursuant to Section 14, Article 2, of the RA 9275 otherwise known as the "Philippine Clean Water Act of 2004", this permit is hereby granted to **Sc Global Food Products, Inc.** with office address at Lot 8208-d, National Highway, Caridad, City Of Baybay, Leyte for its establishment:

<b>Sc Global Food Products, Inc.</b>	Lot 8208-d, National Highway Caridad CITY OF BAYBAY
TIN No. 008-205-127-000	

To discharge **Industrial Wastewater** into **Camotes Sea (Class SC)** subject to the following conditions:

1. The discharge rate of the effluent shall not exceed **8.0 m3/day** after treatment at the **Wastewater Treatment Facility (WTF)** and that its shall comply with the following standard:

Parameter	Standard	Parameter	Standard
BOD	100 mg/L	Ammonia	4 mg/L
TSS	100 mg/L	Oil & Grease	10 mg/L
Temperature	3°C Change	Nitrate	20 mg/L
pH	6.0-9.0	-	-

*\* Reference for effluent parameters: DAO 2016-08 & DAO 2021-19; PSIC Code - 104*

2. Institute measures on the operation of your **WTF** so as to have effluent conforming with the prescribed standard.
3. The maximum wastewater generation of **2.5 m3/day** shall be from the process.
4. The maximum wastewater generation of **1.0 m3/day** shall be from the washing/cleaning activities.
5. The maximum wastewater generation of **0.5 m3/day** shall be from the cooling.
6. The maximum wastewater generation of **1.5 m3/day** shall be from the domestic wastes.
7. The maximum wastewater generation of **2.5 m3/day** shall be from the others (e.g., evaporation, etc.)
8. Submit Self-Monitoring (SMR) based on the following schedule: (*Online submission at <https://client.emb.gov.ph/smr>*)

Quarter	Coverage	Submission	Quarter	Coverage	Submission
First	Jan-Mar	1-15 Apr.	Third	Jul-Sep.	1-15 Oct.
Second	Apr-Jun.	1-15 Jul.	Fourth	Oct-Dec.	1-15 Jan.

9. Include effluent analysis of the **BOD, TSS, Fecal Coliform, Nitrate, & Phosphate** parameters, conducted by the **EMB8 Laboratory**, at least **two (2) months** prior to the expiration of this permit.
10. Include effluent analysis on the other remaining parameters, conducted by Third Party Laboratory duly recognized by EMB, at least **two (2) months** prior to the expiration of this permit.
11. Submit **BOD & TSS** analysis of the abstracted water or source of your water supply. (e.g. deep well water, tap water, water distributed by peddlers, etc.) conducted by the **EMB8 Laboratory**, at least **two (2) months** prior to the expiration of this permit.
12. Provide accessible sampling port at the effluent side of your **WTF** at all times.
13. Channel your domestic wastewater generation (process & washing/cleaning) into your **Wastewater Treatment Facility**.




This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

- 14. Channel your domestic wastewater generation (domestic) into your **WTF - Septic Tank**.
- 15. Submit Certificate of desludging/siphoning of the **Septic Tank** and treatment of the same by an accredited service provider.
- 16. Renew the Certificate of PCO Accreditation not later than **January 2, 2023**.
- 17. Allow the entry of our duly authorized representative(s) to conduct inspection within your premises.
- 18. This permit, together with the corresponding Official Receipts of Payment, shall be adequately framed and posted in a conspicuous place at the plant/establishment.
- 19. This permit shall be renewed not less than **thirty (30) days** prior to its expiration.


**This permit is valid up to Sep 08, 2022, unless revoked or suspended by this Office in writing.**

*Non-compliance with the above conditions and/or any pertinent provisions of RA 9275 otherwise known as "Philippine Clean Water Act of 2004", a corresponding penalty in the amount of P10,000-P200,000 per violation shall be imposed.*

Recommended by:

  
**ENGR. HENNENCY G. HAYAG**  
OIC-Chief, Clearance and Permitting Division

Approved by:

  
**ENGR. REYNALDO B. BARRA**  
OIC-Regional Director

Permit Fee	: Php 2000.00	O.R. No. : 1947981, 4739795	Date : Feb. 15, 2022
Water Discharge Fee	: Php 4.80	O.R. No. : 1947981, 4739795	Date : Feb. 15, 2022
Filing Fee	: Php 55.00	O.R. No. : 1944567, 1946124, 1947981	Date : Feb. 15, 2022
PD1856	: Php 10.00	O.R. No. : 1944567, 1946124, 1947981	Date : Feb. 15, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 1944567, 1946124, 1947981	Date : Feb. 15, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.