



Republic of the Philippines
Department of Environment and Natural Resources
ENVIRONMENTAL MANAGEMENT BUREAU
Region VIII
DENR Compound, Jones Street, Barangay 2, Tacloban City
Tel No: (053) 832-1088 / (053) 832-2319
embr8_records@emb.gov.ph

Permit No: PTO-OL-R08-2022-00093-R
Application Type: Renewal

Date Issued: 05 Jan 2022
Date Expiration: 05 Jan 2027

PERMIT TO OPERATE
Air Pollution Source and Control Installations

Pursuant to Part IV, Rule XIX of the Rules and Regulations of R.A. 8749, authority is hereby granted to:

**Tongonan Geothermal Project (Tongonan
Geothermal Project)**

Tongonan, Ormoc City, Leyte

subject to the following terms and conditions:

TERMS AND CONDITIONS

1. This Permit is issued for the permittee to operate **two (2) units "CATERPILLAR" Air Compressor Diesel Engine**, each rated at **400 HP (328.24 KW)**, for the purpose of **Prime Mover** at the permittee's establishment identified on this Permit. *(Refer to attached Annex at page 3)*
2. Any application for renewal of this Permit shall be filed **not less than thirty (30) days** before the expiry date indicated on the previous page of the Permit.
3. This Permit shall be posted in a conspicuous location of the premises, and shall be adequately framed or otherwise protected against damage.
4. Without limiting the generality of the previous condition, the permittee shall ensure that the emissions from the permitted installations or processes comply with:
 - the National Emission Standards for Source Specific Air Pollutants as specified in Rule XXV of the IRRs of RA 8749;
 - the National Ambient Air Quality Standards for Source Specific Air Pollutants from Industrial Sources/Operations as specified in Rule XXVI of the IRRs of 8749; and
 - the emission limits specified in Permit condition No.9.
5. The permittee shall submit Self-Monitoring Reports to the Bureau in accordance with DENR Administrative Order No. 27 (Series of 2003) and any written instructions by the Bureau at three-monthly intervals, commencing with submission of the **first Report** on or before **April 15, 2022**. (Online Submission at <https://client.emb.gov.ph/smr>)
6. The permittee shall at all times have an appointed or designated Pollution Control Officer (PCO) pursuant to DAO 2014-02.
7. The permittee shall at all times allow authorized or accredited officers of the Department or the Bureau entry to the establishment and access to any part of the establishment to conduct inspections, gather information, test emissions or take samples.
8. The permittee shall not make or allow any alterations or modifications to operations, activities, installations, processes, plant or equipment at the establishment that might substantially change the nature or quantity of the associated emissions without obtaining the approval of the Bureau, including the obtaining of any necessary Permit to Operate.
9. The permittee shall ensure that the concentrations of the emissions from the stack/exhaust serving the **two (2) units 400 HP (328.24 KW) "CATERPILLAR" Air Compressor Diesel Engine** shall not exceed the following limits:
 - **Carbon Monoxide (CO): 500 milligrams per normal cubic meter**, and
 - **Nitrogen Oxide (NOx): 2000 milligrams per normal cubic meter**.
11. The permittee shall burn **only Diesel Fuel Oil** in the **two (2) units 400 HP (328.24 KW) "CATERPILLAR" Air Compressor Diesel Engine** for not more than **500 annual operating hours** for the whole duration of the permit validity.
12. The testing required by the previous condition shall be repeated and Emission Test Reports shall be submitted to the Bureau at **once every two years intervals**. The results of this testing shall be reported in the Self-Monitoring Reports

Filing Fee	: Php 600.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Permit Fee	: Php 5000.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
PD1856	: Php 10.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022




This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

submitted in accordance with Permit Condition No.5.

13. The permittee shall sample and analyze emissions of **Carbon Monoxide (CO) and Nitrogen Oxide (NOx)** from the stack/s serving the **two (2) units 400 HP (328.24 KW) "CATERPILLAR" Air Compressor Diesel Engine** in accordance with the methods specified in the IRRs of RA 8749 and including the submission of the **proposed test plan** to the Bureau **at least two (2) weeks** prior to the date of conduct of the emission test and shall submit an Emission Test Report on the results of this emission testing to the Bureau after **thirty (30) days** after the conduct of emission test. During the sampling of the emissions, the generator set shall be operated at an output of **30% or greater than the permitted capacity**. The following data on operating conditions shall be collected during the sampling period, and included in the Emission Test Report: (a) **the actual output of the (Diesel Engine)**; (b) **stack or exhaust dimensions (height and inside diameter)**; (c) **average annual operating hours**; and (d) **the rate of fuel consumption**.

Recommended by:

Approved by:


ENGR. HENNENCY G. HAYAG
OIC-Chief, Clearance and Permitting Division


ENGR. REYNALDO B. BARRA
OIC-Regional Director

Filing Fee	: Php 600.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Permit Fee	: Php 5000.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
PD1856	: Php 10.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.

Annex

Fuel Burning					
ID	APSI	Capacity	Brand name	Type of Fuel	APCD
176498	Air Compressor	440.0 HP	Caterpillar	Diesel	---
176499	Air Compressor	440.0 HP	Caterpillar	Diesel	---

Filing Fee	: Php 600.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Permit Fee	: Php 5000.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
PD1856	: Php 10.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022
Documentary Stamp Tax	: Php 30.00	O.R. No. : 4736437/1944444	Date : Jan. 3, 2022



This is a computer generated certificate. To verify the authenticity of this file, kindly scan the generated QR Code using your QR Code scanner/reader or visit the OPMS website for details.