

Report Control Number:

Date of Inspection:

ENVIRONMENTAL MANAGEMENT BUREAU REGION 8



COMPLIANCE INSPECTION FOR AIR QUALITY MANAGEMENT

ENVIRONMENTAL MONITORING AND ENFORCEMENT DIVISION-WATER AIR QUALITY MONITORING SECTION

March 15, 2022

Mission Order No.:	Desk Monitoring					
1. GENERAL INFORMATION						
Name of Establishment: LAO C	ONSTRUCTION BATCHING AND CRUS	SHING PLANT (VIC	ENTE T. LAO)			
Address: Brgy. Libertad, Palo	, Leyte	Geo Coordinates 11.2123687, 124				
Nature of Business: Aggregate	Processing					
PSIC Code:	Product:	Year Established:				
Operating hours/day:	Operating days/week:	Operating days/y	/ear:			
Product Lines	Production Rate as Declared in the ECC (unit/day)	Actual Pro	duction Rate (unit/day)			
Name of Managing Head:	ENGR. ORLANDO BAUTISTA					
Name of PCO:	DEMETRIA CAMPILAN					
PCO Accreditation No.:	CO Accreditation No.: Date of		e of Effectivity:			
Phone/Fax:	0966 560 9045	Email:				
2. PURPOSE OF INSPECTION						
 Verify accuracy of information renewals, or modification 	on submitted by the establishment po	ertaining to new p	ermit applications,			
New Renewal		New	Renewal			
PMPIN Application						
Hazardous Waste ID Re						
Hazardous Waste Tran						
Hazardous waste TSD I						
	Pollution Control Installation					
Discharge Permit			ī			
Others						
requirements Investigate community con Check status of voluntary c Industrial Ecowatch	ommitment	ns, permit conditio	ns, and other			
Pollution Adjudication						
Others						
Name of Contact Person	ENGR. ORLANDO BAUTISTA					
Position / Designation	Managing Head					

3. COMPLIANCE STATUS

3.1 DENR Permits/Licenses/Clearance

Environmental Law		Permits	Date of Issue	Expiry Date
	ECC1	ECC-R08-1403-0024	Apr. 1, 2014	
PD 1586	ECC2			
	ECC3			
	DENR Registry ID			
RA 6969	PCL Compliance Certificate			
	CCO Registry			
	Permit to Transport			
RA 8749	POA No.	14-POA-F-0837-0371	Aug. 7, 2014	Aug. 6, 2019
		15-POA-C-0837-0093	Mar. 16, 2015	Mar. 16, 2020
RA 9003	ECC for Sanitary Landfill			
RA 9275	DP No.	16-DP-J-0837-0394	Oct. 13, 2016	Oct. 13, 2017

MODULE AQM01: PRE-INSPECTION INFORMATION SHEETFOR EMISSION SOURCES

Emission Source Data Information	Emission Source Data Information		
Emission Source No.	Emission Source No.		
Type (Brand/Model)	Type (Brand/Model)		
Rated Capacity	Rated Capacity		
Fuel Type & Quantity	Fuel Type & Quantity		
Operating Capacity	Operating Capacity		
Control Facility	Control Facility		
Notes:	Notes:		

Legal Provision	Regulatory Requirements	Compliant			Notes
			N	N/A	
DAO 2004-26					
Rule 19 Section 1	All emission sources have a valid Permit to Operate		/		Issued permits have already expired. With pending NOV
Rule 19 Section 3	As built design of the installation conforms with submitted engineering plans and specifications			1	
	Declared control facilities are installed and operational			1	
	Installation is located as proposed in the vicinity map (plant and machinery layout)			1	
	Facility design capacity is within the capacity declared in the application for permit to operate			1	
Rule 19 Section 5	Temporary Permit is still valid			1	
Rule 19 Section 6	Application for renewal has been filed for expiring Permit to Operate 30 days before permit expiration date		1		No application received via OPMS

Rule 19 Section 9	Permit to Operate displayed			/	
	conspicuously upon the installation				
	or in an accessible / visible place				
	near the installation				
	Conditions of the Permit to Operate			1	
	are complied with				
Rulle 19 Section 11	Plant operational problems			1	
	notification submitted to EMB within				
	24 hours of occurrence				
Rule 19 Section 12	Quarterly submission of self-		1		
	monitoring report				
DAO 2000-81					
Part 7 Rule 25 Section 5 a#	Person in charge of the plant /		T	1	
1	equipment has sufficient measure to				
	ensure that no dark smoke is				
	discharging from any stack in the				
	establishment. E.g.: window view of				
	stack, mirror to reflect top of stack,				
	smoke density indicator, CCTV, etc.				
Part 7 Rule 25 Section 5 a#	All oil-burning equipment have	-		1	
	heaters capable of heating oil to a			,	
2					
	temperature appropriate for the oil				
	and burner				
Part 7 Rule 25 Section 5 a#	Establishment is fossil fuel-fired			1	
3	power plant over 10MW rating			′	
	installed with CEMS for particulates,				
	sulfur oxide, and NOx				
	Establishment is petroleum refinery		-	1	
	/ petrochemical industry installed			,	
	with CEMS for particulates, sulfur				
	oxide, and NOx				
	Establishment is primary copper		-	/	
	smelter installed with CEMS for			,	
	particulates, sulfur oxide, and NOx				
	Establishment is steel plant installed	-	-	,	
				1	
	with CEMS for particulates and				
	sulfur oxide				
	Establishment is ferro-alloy			/	
	production facility installed with				
	CEMS for particulates				
	Establishment is cement plant			/	
	installed with CEMS for particulates				
Part 7 Rule 25 Section 5 b	Miscellaneous equipment like			1	State equipment then control
	reheating furnace, smoke oven, bake				facility/ies.
	oven, coffee heaters, varnish kettles,				
	etc. are installed with pollution				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
	control facilities				

Part 7 Rule 25 Section 13 a	Establishment has precautionary		1	Example: It has tire bath
	controls for dusts generated during			Automated water sprinklers
	vehicular movement, transportation			
	of materials, construction, etc. (List			
	controls identified)			
Part 7 Rule 25 Section 13 b	Establishment has precautionary		/	
	controls for volatile organic			
	compounds or organic solvent			
	emissions generated during storing,			
	pumping, handling, processing, etc.			
	(List controls identified)			
Part 7 Rule 25 Section 13 d	No open burning activity in the	1		
	establishment			
EMB Memorandum Circula	rs	1		
MC 2009-04	Standby Gensets with capacity		/	
	greater than or equal to 1,250 KW			
	undergo annual emission testing			
	(with 3 test runs). These gensets			
	should not have the potential to emit			
	more than 100tons/year of regulated pollutant.			
MC 2007-003 (2)	Boiler rated at greater than or equal		1	
1110 2007 000 (2)	to 251HP undergo bi-annual		1	
	emission testing (with 3 test runs)			
	Other sources that have potential to		1	
	emit equal to or greater than			
	100tons/year of regulated pollutant			
	undergo bi-annual emission testing			
	(with 3 test runs)			
	Boiler rated between 100 to 250 HP		1	
	undergo annual emission testing			
	(with 3 test runs)			
	Diesel generator rated at 600 to		/	
	1,249KW undergo annual testing (with 3 test runs)			
	Other sources that have potential to		1	
	emit greater than 30 but less than		1	
	100tons/year of regulated pollutant			
	undergo annual emission testing			
	(with 3 test runs)			
	Sources of emissions of hazardous		1	
	air pollutants included in PCL (DAO			
	1998 -58) undergo bi-annual			
	emission testing (with 3 test runs)			
	Emission sources of petroleum		1	
	refinery undergo bi-annual emission			
	testing (with 3 test runs)			
	Emission sources of petrochemical		1	
	works undergo bi-annual emission		1	
	testing (with 3 test runs)			

	Emission sources of smelters undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of cement kilns undergo bi-annual emission testing 'with 3 test runs)	/	
	Emission sources of steel -making plants undergo bi-annual emission testing (with 3 test runs)	/	
	Emission sources of ferro-alloy- making plants undergo bi-annual emission testing (with 3 test runs)	1	
	Emission sources of glass-making plants undergo bi-annual emission testing (with 3 test runs)	/	
	Boiler rated at 99HP or less undergo biennial emission testing (with 3 test runs)	/	
	Diesel generator rated at 599KW or less undergo biennial emission testing (with 3 test runs)	/	
	Other sources that have potential to emit at least 10tons/year but less than 30tons/year of regulated pollutant undergo biennial emission testing (with 3 test runs)	/	
	Source using Bunker Fuel Oil, blended fuels involving Bunker Fuel Oil, or sulfur content of 1% or more undergo bi-annual emission testing	/	
Appendix F (Quality	Assurance Procedures)		
Section 6 (8)	Notification has been sent to EMB for any changes made in the CEMS installation	/	
	Notification has been sent to EMB for any changes made in the CEMS quality assurance and quality control plan	/	
Section 6 (5)	Each CEMS is audited and conducted in accordance to CFR 40 part 60 Appendix F.	1	

Section 6 (6)	Relative Accuracy Test Audit (RATA) is performed annually by industries in the presence of EMB personnel.	/	
	Establishment has sent thirty (30) day notice to EMB prior to the RATA testing schedule	1	
Section 6 (7)	Calibration gases are subject to audit or relative accuracy audit test every quarter	1	
	Other alternative quarterly audits employed by the establishment are approved by EMB.	1	
Section 6 (9)	EMB Director and Regional Director have been notified of CEMS malfunction that lasted longer than seven (7) consecutive days.	1	
Section 7 (1)	Records of occurrence and duration of any start-up, shut-down or malfunction in the operation of any source or control facility is available in the establishment.	1	
Section 7 (2)	Records of audits, performance testing, evaluations, calibration checks, adjustments and maintenance of any continuous emission monitors that have been installed pursuant to Rule IX Section 5 of DAO 2000-81 are available in the establishment.	1	
Section 8 (1)	SMR includes data on the time intervals, date and magnitude of excess emissions, nature and cause of excess, corrective actions taken, and preventive measures adopted.	1	
Section 8 (2)	SMR includes information on the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant/source category in question.	1	
Section 8 (3)	SMR includes information on time and date for each period during which the continuous monitoring system was inoperative and the nature of system repairs and adjustments made in the CEMS/COMS	1	
Section 8 (4)	SMR data measurements are within 75% data capture?	1	

EMS established within 18 months upon entering Consent Agreement with EMB	EMS established within 18 months upon entering Consent Agreement with EMB	/	
DAO 2000-81 Part 7 Rule 25 Section 9b	Environmental Management Plan derived from EMS process submitted within 6 months after entering Consent Agreement with EMB	1	

Other Observations:

- The project is issued with an Environmental Compliance Certificate with reference number: ECC-R08-1403-0024 issued on April 1, 2014 for operation of batching and crushing plant with production capacity of 50 MT/day.
- 2. The project was previously issued with a Notice of Violation for operating with expired permit to operate for air pollution sources and expired discharge permit as violation to ECC. NOV was issued on September 28, 2020. Technical Conference was conducted on October 2, 2020. Pending payment of penalty by proponent.
- No record of submission of SMR and CMR online.
- 4. As per previous monitoring report on March 12, 2020, the plant is not yet fully operational.

Remarks and Recommendation:

- 1. For proponent to settle pending violation to ECC conditions.
- 2. For conduct of on-site inspection to validate status of operation.

List of Documents Reviewed:

Submitted by:

SHARMAINE I

EMS I

Approval:

MANUEL J. S. OIC Chief, EMED

Recommending Approval:

Engr. CARLOS A. C

Engineer IV/Chief, WAQMS

Noted:

OIC, Regional Director



Republic of the Philippines Department of Environment and Natural Resources ENVIRONMENTAL MANAGEMENT BUREAU

Regional Office No. VIII
DENR 8 Compound, Brgy. 2, Jones Extension, Tacloban City



DISPOSITION FORM

Doc. Date : March 18, 2022

:R8-2022-008718

Company Name: VICENTE LAO CONSTRUCTION, BRGY. LIBERTAD,

PALO, LEYTE

Subject / Title: LAO CONSTRUCTION BATCHING AND CRUSHING PLANT - Air Monitoring

TO: All Officials/Personnel Concerned:

Please accomplish and route this properly with the corresponding attached communication/documents. The Official or employee in-charge to whom this document is routed shall act promptly and expeditiously without discrimination as prescribed in the SECSIME or within fifteen (15) working days from receipt thereof, failure to do is punishable by LAW under RA 6713 and negligence to Memorandum Circular No. 44 issued by the Office of the President of the Philippines "Directing all Government Agencies and Instrumentalities, including government-owned or controlled corporations to respond to all public requests and concerns within 15 days (15 from the receipt thereof)

For strict compliance.

IIS No.

		F	ROUTED	
BY (Official Code/ Sender Initial)	DATE (mm/dd/yy)	TO (Official Code/ Receiver Initial)	TIME (AM/PM)	ACTION REMARKS STATUS
Sharmaine I. Silleza	03/18/2022	Carlos A. Cayanong	09:31 AM	For initial/signature.
an	3-21	ms.	149	H
C.EMED	3-23	020	Sh	"
RD I	MAR 2 4 2022	EMED/	8:12m	Noted Signed
,,,		Nin		

Use code for comment/instruction and desired action:

A - For information / guidance / reference

B - For comments / recommendations

C - Pls. take up with me

D - Pls. draft answer memo

E - Pls. appropriatte action
I - For initial/signature

F - Pls. immediate investigation J - For study/evaluation G - Pls. Attach supporting papers K - Pls. release/file

H - Pls. for approval L - Update stat of case

Important Reminder!

Do not tamper. Continue on separate sheet if necessary. Attach this always with the document to be routed as this shall form an integral part of the document process.